Gas Nomination Cycles and Units Operating Parameters

MMUAC
December 1, 2023

Joel Romero Luna



NAESB Nomination Cycles

- Pipelines can require consumers to nominate gas per the NAESB cycles, based on reliability needs.
 - NAESB Cycles (Eastern Time):

	Timely	Evening	ID1	ID2	ID3
Nom Deadline	14:00	19:00	11:00	15:30	20:00
Confirmation Deadline	17:30	21:30	13:30	18:00	22:30
Scheduled Volumes Available	18:00	22:00	14:00	18:30	23:00
Start of Gas Flow	10:00	10:00	15:00	19:00	23:00

- Pipelines notices do not explicitly state such requirement.
- Pipelines use phrases such as balance deliveries and receipts or nominate before flowing.

Notification Time

- When pipelines enforce these deadlines, generators cannot start per their approved notification times.
 PJM's proxy PLS notification times for CTs and RICE is 6 minutes.
 - Except for units that have agreements for services that allow for more flexibility (i.e. no notice, storage).
- The times when pipelines enforce the NAESB nomination cycles deadlines is unclear.
 - In some cases, it is not clear if they apply to all consumers regardless of service acquired.

Notification Time

- PJM approves longer PLS notification times when more time is required to start, but no CT/RICE in PJM has a PLS notification time longer than 30 minutes.
 - Temporary exceptions can be requested to increase the approved limits.
- When pipelines enforce nomination deadlines, generators cannot begin their start sequence in 6 to 30 minutes. Instead the notification time is based on the time required by the pipelines to nominate gas.

Notification Time

 For example, the last nomination cycle available per NAESB is intraday 3 (ID3). The ID3 deadline is 20:00 EPT for gas that starts flowing at 23:00 (in three hours). The previous cycle, intraday 2 (ID2) deadline is at 15:30 EPT for gas that starts flowing at 19:00. A generator that has not nominated gas by ID2 cannot start until 23:00. Therefore, at 19:00, the unit has an implied time to start of four hours. Four hours is equal to 23:00 (the earliest the unit can start) minus 19:00.

Declining Hourly Notification Time

 In order to capture the correct notification time properly, generators have to reflect the nomination deadlines and the time that gas starts flowing in each cycle.

Hour	HE1	HE2	HE3	HE4	HE5	HE6	HE7	HE8	HE9	HE10	HE11	HE12
Notification Time	15	14	13	12	11	10	9	8	7	6	9	8
Time On (If Called)	15:00	15:00	15:00	15:00	15:00	15:00	15:00	15:00	15:00	15:00	19:00	19:00
Nearest Cycle	ID1	ID2	ID2									

Hour	HE13	HE14	HE15	HE16	HE17	HE18	HE19	HE20	HE21	HE22	HE23	HE24
Notification Time	7	6	9	8	7	6	5	20	19	18	17	16
Time On (If Called)	19:00	19:00	23:00	23:00	23:00	23:00	23:00	15:00	15:00	15:00	15:00	15:00
Nearest Cycle	ID2	ID2	ID3	ID3	ID3	ID3	ID3	ID1	ID1	ID1	ID1	ID1

 This times allow for up to one hour to schedule supply before the nomination deadline.

Elliott and Feb 3, 2023, Cold Weather Alert

- On Dec 23, DA, 5 gas plants (3,013 MW), submitted extended notification times due to gas nomination deadlines.
- On Dec 23, RT, 9 gas plants (5,290 MW), submitted extended notification times due to gas nomination deadlines.
- On Feb 3, DA, 8 gas plants (4,979 MW), submitted extended notification times due to gas nomination deadlines.
- On Feb 3, RT, 12 gas plants (6,998 MW), submitted extended notification times due to gas nomination deadlines.

Elliott and Feb 3, 2023, Cold Weather Alert

- In total, 13 plants used extended notification times between Dec 23-24, 2022, and Feb 3-4, 2023. Out of 13, 12 are based on the gas nomination cycles
 - Of the 12 plants, only three plants used the notification times correctly to match NAESB nomination deadlines.
 - Two of these three plants used it correctly, except for one hour.
 - The remaining 9 plants used notification times that did not match the nomination deadlines.
 - These units used the same notification time regardless of time of day.

Other Restrictions

- Usually, the requirement to nominate gas per the NAESB nomination cycles coincides with the requirement to nominate gas ratably (ratable takes).
- When these restrictions are imposed, generators have to nominate uniform gas volumes for every hour (or within a threshold).
- These restrictions may require the need to increase generators' minimum run times and reduce dispatchable range.

Minimum Run Time

Min Run Time

©2023

- When 24 hour ratable takes are imposed, it is expected that units will request a PLS exception to increase the min run time.
- After the evening cycle, the min run times should be reduced to reflect the gas that can flow on ID1, ID2, ID3.
 - The min run time for ID1 should be 19 hours (15:00 to 10:00).
 - The min run time for ID2 should be 15 hours (19:00 to 10:00).
 - The min run time for ID3 should be 11 hours (23:00 to 10:00).

www.monitoringanalytics.com

Hour	HE1	HE2	HE3	HE4	HE5	HE6	HE7	HE8	HE9	HE10	HE11	HE12	
Min Run Time	19	19	19	19	19	19	19	19	19	19	15	15	
Nearest Cycle	ID1	ID1	ID1	ID1	ID1	ID1	ID1	ID1	ID1	ID1	ID2	ID2	
Hour	HE13	HE14	HE15	HE16	HE17	HE18	HE19	HE20	HE21	HE22	HE23	HE24	
Min Run Time	15	15	11	11	11	11	11	19	19	19	19	19	
Nearest Cycle	ID2	ID2	ID3	ID3	ID3	ID3	ID3	ID1	ID1	ID1	ID1	ID1	
©2023	www.monitoringanalytics.com 10						Monitoring Analytics						

Turn Down Ratio

Turn Down Ratio

- When ratable takes are imposed, it is expected that units will request a PLS exception to reduce their turn down ratio.
- The expected turn down ratio will be a function of the flexibility allowed by the pipeline. If the pipeline does not allow any flexibility, the expected turn down ratio is one (1.0).

Reserves

- Longer notification times mean that units cannot provide offline reserves.
- Online gas units that cannot adjust output (increase or decrease) once gas is nominated cannot provide reserves either.
- Online gas units that cannot adjust output should not be counted towards reserves, and if this is known DA, these units should not be assigned DA reserves.

Implications

- These restrictions make flexible units (such as CCs and CTs) inflexible.
 - Long minimum run times, long notification times, block loaded.
- When these requirements are imposed and reflected in operating parameters, these units will not be able to provide reserves.
- Other units will be have to:
 - Be held offline as reserves (e.g. oil fired CTs).
 - Backed down (e.g. coal, other gas units).

Actions Taken by IMM/PJM

- On September 8, 2023, PJM and the IMM posted guidelines for the use of temporary exceptions when pipelines imposed restrictions.
- On September 11, 2023, PJM and the IMM filed a motion to expedite the replacement of real time values with temporary exceptions in real time by December 1, 2023.

Monitoring Analytics, LLC
2621 Van Buren Avenue
Suite 160
Eagleville, PA
19403
(610) 271-8050

MA@monitoringanalytics.com www.MonitoringAnalytics.com