

Unit Parameter Matrix

PJM Unit Parameter Matrix Summary					
Turn Down Ratio = Economic Maximum MW / Economic Minimum MW					
Parameter	Minimum Down Time (Hrs)	Minimum Run Time (Hrs)	Maximum Daily Starts	Maximum Weekly Starts	Turn Down Ratio
Small Frame CT and Aero CT Units - Up to 29 MW ICAP	2.0 or Less	2.0 or Less	2 or More	14 or More	1.0 or More
Medium Frame CT and Aero CT Units - 30 MW to 65 MW ICAP	2.0 or Less	3.0 or Less	2 or More	14 or More	1.0 or More
Medium-Large Frame CT Units - 65 MW to 125 MW ICAP	3.0 or Less	5.0 or Less	2 or More	14 or More	1.0 or More
Large Frame CT Units - 135 MW to 180 MW ICAP	4.0 or Less	5.0 or Less	2 or More	14 or More	1.0 or More
Combined Cycle Units	4.0 or Less	6.0 or Less	2 or More	11 or More	1.5 or More
Petroleum and Natural Gas Steam Units - Pre-1985	7.0 or Less	8.0 or Less	1 or More	7 or More	3.0 or More
Petroleum and Natural Gas Steam Units - Post-1985	3.5 or Less	5.5 or Less	2 or More	11 or More	2.0 or More
Sub-Critical Coal Units	9.0 or Less	15.0 or Less	1 or More	5 or More	2.0 or More
Super-Critical Coal Units	84.0	24.0 or Less	1 or More	2 or More	1.5 or More

