

Default ACR Values as of February, 2010

Technology Type	Avoidable Cost Rate (\$/MW-Day)			
	2010-2011 Avoidable Cost Rate (\$/MW-Day)	2011-2012 Avoidable Cost Rate (\$/MW-Day)	2012-2013 Avoidable Cost Rate (\$/MW-Day)	2013-2014 Avoidable Cost Rate (\$/MW-Day)
Nuclear	NA	NA	NA	NA
Pumped Storage	\$20.77	\$21.72	\$22.71	\$23.64
Hydro	\$71.01	\$74.24	\$77.62	\$80.80
Sub-Critical Coal	\$170.48	\$178.24	\$186.35	\$193.98
Super Critical Coal	\$176.13	\$184.15	\$192.53	\$200.41
Waste Coal - Small	\$224.83	\$235.06	\$245.75	\$255.81
Waste Coal - Large	\$83.15	\$86.94	\$90.89	\$94.61
Wind	NA	NA	NA	NA
CC - Two on One Frame F Technology	\$30.92	\$32.33	\$33.80	\$35.18
CC - Three on One Frame E/Siemens Technology	\$34.33	\$35.89	\$37.52	\$39.06
CC - Three or More on One or More Frame F Technology	\$26.76	\$27.98	\$29.26	\$30.46
CC - NUG Cogeneration Frame B or E Technology	\$114.93	\$120.16	\$125.62	\$130.76
CT - First & Second Generation Aero (P&W FT 4)	\$24.57	\$25.69	\$26.86	\$27.96
CT - First & Second Generation Frame B	\$24.28	\$25.38	\$26.54	\$27.63
CT - Second Generation Frame E	\$23.08	\$24.13	\$25.23	\$26.26
CT - Third Generation Aero (GE LM 6000)	\$55.87	\$58.42	\$61.07	\$63.57
CT - Third Generation Aero (P&W FT-8 TwinPak)	\$29.30	\$30.64	\$32.03	\$33.34
CT - Third Generation Frame F	\$23.69	\$24.77	\$25.90	\$26.96
Diesel	\$26.29	\$27.49	\$28.74	\$29.92
Oil and Gas Steam	\$65.21	\$68.18	\$71.28	\$74.20