

5 Capacity Market

In PJM, the capacity market exists to make the energy market work. Energy powers lights and computers and air conditioners. Capacity does not power anything. The capacity market needs to define the total MWh of energy that are needed to reliably serve load. The capacity market needs to provide the missing money. A primary reason to have a capacity market is that the energy market does not provide adequate net revenues to provide incentives for entry and for maintaining existing units. The obligation of load serving entities (LSEs) to own capacity equal to the peak demand plus a reserve margin was a longstanding feature of the PJM Operating Agreement before the creation of the PJM markets. The initial impetus to a capacity market in PJM, a request by the Pennsylvania PUC, was to support retail competition by ensuring that small new entrant competitive LSEs would have access to capacity at a competitive price without having to build capacity or purchase capacity bilaterally from incumbent generation owners at monopoly prices. The PJM Capacity Market was created by FERC in order to prevent the exercise of market power that resulted from a bilateral market in which the ownership of capacity was concentrated. That logic continues to apply today. The first, the daily capacity market, created in 1999, was replaced in 2007 by the current design based on the recognition that the energy market resulted in a shortfall in net revenues compared to that necessary to attract and retain adequate resources for the reliable operation of the energy market. The exogenous reliability requirement to have a level of capacity in excess of the level that would result from the operation of an energy market alone reduces the level and volatility of energy market prices and reduces the duration of high energy market prices. This reduces net revenue to generation owners which reduces the incentive to invest. In order for the PJM markets to be self sustaining, the net revenues from PJM energy, ancillary services and capacity markets must be adequate for those resources. That adequacy requires a capacity market. The capacity market plays the essential role of equilibrating the revenues necessary to incent competitive entry and exit of the resources needed for reliability, with the revenues from the energy and ancillary services markets.

The only goal of the detailed design of the capacity market is to ensure that the opportunity for that revenue equilibration exists through a competitive process. PJM's most recent filing to modify the definition of the capacity market demand curve (VRR curve) explicitly fails to recognize that equilibration logic and undercuts that revenue equilibration mechanism by failing to include a full net revenue offset in the definition of the maximum price on the demand curve.

The Capacity Performance (CP) design was a radical change to the capacity market paradigm. The CP design is a failed experiment. The fundamental mistake of the CP design was to attempt to recreate energy market incentives in the capacity market. The CP model was an explicit attempt to bring energy market shortage pricing into the capacity market design. The CP model was designed on the unfounded assumption that shortage prices in the energy market were not high enough and needed to be increased via the capacity market.

PJM's introduction of its significantly modified ELCC method in the 2025/2026 BRA was another radical change to the capacity market design. While it is a good idea to evaluate unit specific performance and a good idea to recognize that risk occurs in the winter as well as the summer and that risks may be correlated, ELCC was implemented before it could be fully tested and unintended consequences evaluated. The results of the 2025/2026 BRA and subsequent BRAs illustrate the extreme sensitivity of the market outcomes to a range of assumptions and decisions about market design details that were not adequately tested or reviewed with stakeholders.¹

The challenge is to create a straightforward capacity market design that meets the simple objectives of a capacity market and that does not become a vehicle for energy market incentives or rent seeking or attempts to limit the ways in which specific types of generation participate in PJM markets. Energy market incentives should remain in the energy market.

¹ The MMU prepared a series of reports on the 2025/2026, 2026/2027 and 2027/2028 BRA results which can be found on the Monitoring Analytics website here: <<https://www.monitoringanalytics.com/reports/Reports/2024.shtml>>, <<https://www.monitoringanalytics.com/reports/Reports/2025.shtml>>; and <<https://www.monitoringanalytics.com/reports/Reports/2026.shtml>>

The PJM market design is based on the must offer and must buy obligations of capacity resources. All capacity resources are required to offer into the capacity auctions. The categorical exemption for intermittent resources, capacity storage resources, and hybrid resources from the RPM must offer requirement was eliminated for all resources except demand resources in February 2025.² All LSEs must buy capacity equal to their peak load plus a reserve margin through the market.

Each organization serving PJM load must meet its capacity obligations through the PJM Capacity Market, where load serving entities (LSEs) must pay the locational capacity price for their zone. LSEs can also construct generation and offer it into the capacity market, enter into bilateral contracts, develop demand resources and offer them into the capacity market, or construct transmission upgrades and offer them into the capacity market.

There are significant market design issues in the PJM Capacity Market that currently prevent the market from achieving competitive results.

One of the most important issues currently facing the PJM Capacity Market is the addition of large amounts of data center load, both actual and forecast. The MMU concludes that the failure to recognize and address the role of large data center loads is a direct cause of higher prices and will continue to result in even higher prices unless the related issues are addressed. PJM should not simply permit the interconnection of large data center loads if it cannot do so reliably, with adequate generation capacity to meet those loads.

The Market Monitoring Unit (MMU) analyzed market design, market structure, participant conduct and market performance in the PJM Capacity Market, including supply, demand, concentration ratios, pivotal suppliers, volumes, prices, outage rates and reliability.³ The conclusions for 2025 and the first

three months of 2026 are a result of the MMU's evaluation of the 2025/2026, 2026/2027, and 2027/2028 Base Residual Auctions.^{4 5 6 7 8 9 10 11 12 13 14}

Table 5-1 The capacity market results were not competitive

Market Element	Evaluation	Market Design
Market Structure: Aggregate Market	Not Competitive	
Market Structure: Local Market	Not Competitive	
Participant Behavior	Not Competitive	
Market Performance	Not Competitive	Mixed

- The aggregate market structure was evaluated as not competitive. For almost all auctions held from 2007 to the present, the PJM capacity market failed the three pivotal supplier test (TPS), which is conducted at the time of the auction.¹⁵ Structural market power is endemic to the capacity market.
- The local market structure was evaluated as not competitive. For almost every auction held, all LDAs have failed the TPS test, which is conducted at the time of the auction.¹⁶

⁴ See "Analysis of the 2025/2026 RPM Base Residual Auction - Part A," (September 20, 2024) <https://www.monitoringanalytics.com/reports/Reports/2024/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_A_20240920.pdf>

⁵ See "Analysis of the 2025/2026 RPM Base Residual Auction - Part B," (October 15, 2024) <https://www.monitoringanalytics.com/reports/Reports/2024/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_B_20241015.pdf>

⁶ See "Analysis of the 2025/2026 RPM Base Residual Auction - Part C," (October 15, 2024) <https://www.monitoringanalytics.com/reports/Reports/2024/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_C_20241106.pdf>

⁷ See "Analysis of the 2025/2026 RPM Base Residual Auction - Part D," (December 6, 2024) <https://www.monitoringanalytics.com/reports/Reports/2024/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_D_20241206.pdf>

⁸ See "Analysis of the 2025/2026 RPM Base Residual Auction - Part E," (January 31, 2025) <https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_E_20250131.pdf>

⁹ See "Analysis of the 2025/2026 RPM Base Residual Auction - Part F," (February 4, 2025) <https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_F_20250204.pdf>

¹⁰ See "Analysis of the 2025/2026 RPM Base Residual Auction - Part G Revised," (June 3, 2025) <https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_G_20250603_Revised.pdf>

¹¹ See "Analysis of the 2025/2026 RPM Base Residual Auction - Part H," (July 31, 2025) <https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_H_20250731.pdf>

¹² See "Analysis of the 2026/2027 RPM Base Residual Auction - Part A," (October 1, 2025) <https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20262027_RPM_Base_Residual_Auction_Part_A_20251001.pdf>

¹³ See "Analysis of the 2026/2027 RPM Base Residual Auction - Part B," (March 3, 2026) <https://www.monitoringanalytics.com/reports/Reports/2026/IMM_Analysis_of_the_20262027_RPM_Base_Residual_Auction_Part_B_20260303.pdf>

¹⁴ See "Analysis of the 2027/2028 RPM Base Residual Auction - Part A," (January 5, 2026) <https://www.monitoringanalytics.com/reports/Reports/2026/IMM_Analysis_of_the_20272028_RPM_Base_Residual_Auction_Part_A_20260105.pdf>

¹⁵ In the 2008/2009 RPM Third Incremental Auction, 18 participants in the RTO market passed the TPS test. In the 2018/2019 RPM Second Incremental Auction, 35 participants in the RTO market passed the test. In the 2023/2024 RPM Third Incremental Auction, 36 participants in the RTO passed the TPS test.

¹⁶ In the 2012/2013 RPM Base Residual Auction, six participants included in the incremental supply of EMAAC passed the TPS test. In the 2014/2015 RPM Base Residual Auction, seven participants in the incremental supply in MAAC passed the TPS test. In the 2021/2022 RPM First Incremental Auction, two participants in the incremental supply in EMAAC passed the TPS test. In the 2021/2022 RPM Second Incremental Auction, two participants in the incremental supply in EMAAC passed the TPS test. In the 2023/2024 RPM Third Incremental Auction, eight participants in MAAC passed the TPS test.

² FERC approved extending the RPM must offer requirement to intermittent resources, capacity storage resources, and hybrid resources but not to demand resources on February 20, 2025. 190 FERC ¶ 61,117.

³ The values stated in this report for the RTO and LDAs refer to the aggregate level including all nested LDAs unless otherwise specified. For example, RTO values include the entire PJM market and all LDAs. Rest of RTO values are RTO values net of nested LDA values.

- Participant behavior was evaluated as not competitive in the 2026/2027 BRA. Effective with the 2026/2027 Delivery Year, the market seller offer cap definition was modified to include unit specific standalone Capacity Performance Quantifiable Risk (CPQR) and segmented unit specific offer caps.¹⁷ The offers in the 2026/2027 BRA included those based on standalone CPQR offer caps. Market power mitigation measures were applied when the capacity market seller failed the market power test for the auction, the submitted sell offer exceeded the defined offer cap, and the submitted sell offer, absent mitigation, would increase the market clearing price.
- Market performance was evaluated as not competitive based on the 2026/2027 Base Residual Auction as a result of the flaws in the Effective Load Carrying Capability (ELCC) design including the failure to correctly define the reliability contribution of thermal resources in the winter, and the failure to recognize and address the role of large data center loads is a direct cause of higher prices and will continue to result in even higher prices unless the related issues are addressed.
- Market design was evaluated as mixed because while there are many positive features of the capacity market design and some of the MMU's recommendations were implemented in the 2026/2027 BRA, there are several features of the RPM design which still threaten competitive outcomes. These include the lack of a queue for the addition of large new data center loads, details of PJM's ELCC implementation, the definition of market seller offer caps, the failure to apply the RPM must offer requirement to demand resources, the inclusion of performance assessment interval (PAI) penalties, the use of gross CONE as the maximum price on the VRR curve, the definition of DR which permits inferior products to substitute for capacity, the replacement capacity issue, the definition of unit offer parameters, and the inclusion of imports which are not substitutes for internal capacity resources.¹⁸

¹⁷ 190 FERC ¶ 61,117 (2025).

¹⁸ While PJM filed for and FERC accepted the inclusion of RMR resources Brandon Shores and Wagner plants in the 2026/2027 BRA and 027/2028 BRA, that does not require that RMR resources be included in capacity market auction clearing in future auctions for these or other RMR resources. See Letter Order, FERC Docket No. ER25-682-001 (April 29, 2025).

Overview

RPM Capacity Market

Market Design

The Reliability Pricing Model (RPM) Capacity Market is a three year forward looking, annual, locational market, with a must offer requirement for Existing Generation Capacity Resources and a must buy requirement for load, with performance incentives, that includes clear market power mitigation rules and that permits the direct participation of demand side resources.¹⁹ PJM introduced the Capacity Performance design for the 2017/2018 BRA. PJM introduced a new ELCC method for defining capacity MW offered in the 2025/2026 BRA.²⁰

Under RPM, capacity obligations are annual.²¹ By design, Base Residual Auctions (BRA) are held for delivery years that are three years in the future despite recent auction delays. First, Second and Third Incremental Auctions (IA) are held for each delivery year.²² First, Second, and Third Incremental Auctions are conducted 20, 10, and three months prior to the delivery year although some incremental auctions have not been held as a result of delays in holding BRAs.²³ A Conditional Incremental Auction may be held if there is a need to procure additional capacity resulting from a delay in a planned large transmission upgrade that was modeled in the BRA for the relevant delivery year.²⁴ A Reliability Backstop Auction may be conducted if tariff defined criteria are met to resolve reliability criteria violations caused by lack of sufficient capacity procured through RPM auctions.²⁵ If the installed reserve margin resulting from the total UCAP committed through self supply or BRAs for three consecutive years is more than one percentage point lower than the approved PJM installed reserve margin, PJM will make a filing with FERC to conduct a Reliability Backstop Auction. If the total UCAP committed

¹⁹ The terms *PJM Region*, *RTO Region* and *RTO* are synonymous in this report and include all capacity within the PJM footprint

²⁰ See 186 FERC ¶ 61,080 (2024), *reh'g order*, 189 FERC ¶ 61,043 (2024).

²¹ Effective for the 2020/2021 and subsequent delivery years, the RPM market design incorporated seasonal capacity resources. Summer period and winter period capacity must be matched either through commercial aggregation or through the optimization in equal MW amounts in the LDA or the lowest common parent LDA.

²² See 126 FERC ¶ 61,275 at P 86 (2009).

²³ See Letter Order, FERC Docket No. ER10-366-000 (January 22, 2010).

²⁴ See 126 FERC ¶ 61,275 at P 88 (2009). There have been no Conditional Incremental Auctions.

²⁵ See OATT Attachment DD § 16.

for all base load generation resources in BRAs for three consecutive years is less than the forecasted minimum hourly load, PJM will make a filing with FERC to conduct a Reliability Backstop Auction.

The 2026/2027 RPM Third Incremental Auction was conducted in the first three months of 2026.

Market Structure

- **RPM Installed Capacity.** In the first three months of 2026, RPM installed capacity decreased 30.0 MW or 0.0 percent, from 184,220.8 MW on January 1, to 184,190.8 MW on March 31. Installed capacity includes net capacity imports and exports and can vary on a daily basis.
- **Reserves.** Total reserves on June 1, 2025, were 19,999.9 MW, which is 205.1 MW (UCAP) short of the required reserve level of 20,205.0 MW (UCAP). On June 1, 2025, the target installed reserve margin was 17.8 percent, and the actual reserve margin was only 17.6 percent.
- **RPM Installed Capacity by Fuel Type.** Of the total installed capacity on March 31, 2026, 48.2 percent was gas; 20.3 percent was coal; 17.5 percent was nuclear; 4.4 percent was hydroelectric; 2.2 percent was oil; 2.4 percent was wind; 0.3 percent was solid waste; and 4.6 percent was solar.
- **Market Concentration.** In the 2026/2027 RPM Third Incremental Auction, all participants in the total PJM market as well as the LDA RPM markets failed the three pivotal supplier (TPS) test.²⁶ Offer caps were applied to all sell offers for resources which were subject to mitigation when the capacity market seller did not pass the test, the submitted sell offer exceeded the defined offer cap, and the submitted sell offer, absent mitigation, increased the market clearing price.^{27 28 29}

²⁶ There are 27 Locational Deliverability Areas (LDAs) identified to recognize locational constraints as defined in "Reliability Assurance Agreement Among Load Serving Entities in the PJM Region," Schedule 10.1. PJM determines, in advance of each BRA, whether the defined LDAs will be modeled in the given delivery year using the rules defined in OATT Attachment DD § 5.10(a)(ii).

²⁷ See OATT Attachment DD § 6.5.

²⁸ Prior to November 1, 2009, existing DR and EE resources were subject to market power mitigation in RPM Auctions. See 129 FERC ¶ 61,081 at P 30 (2009).

²⁹ Effective January 31, 2011, the RPM rules related to market power mitigation were changed, including revising the definition for Planned Generation Capacity Resource and creating a new definition for Existing Generation Capacity Resource for purposes of the must offer requirement and market power mitigation, and treating a proposed increase in the capability of a generation capacity resource the same in terms of mitigation as a Planned Generation Capacity Resource. See 134 FERC ¶ 61,065 (2011).

- **Imports and Exports.** Of the 1,144.8 MW of imports offered in the 2027/2028 RPM Base Residual Auction, 1,005.9 MW cleared. Of the cleared imports, 695.6 MW (69.2 percent) were from MISO.
- **Demand Resources.** Committed DR was 5,782.9 MW for June 1, 2025, as a result of cleared capacity for demand resources in RPM auctions for the 2025/2026 Delivery Year (6,265.9 MW) less replacement capacity (483.0 MW).
- **Energy Efficiency Resources.** EE is not a capacity resource but is paid the capacity market clearing price as a subsidy through the 2025/2026 Delivery Year. Committed EE was 1,481.6 MW for June 1, 2025, as a result of MW offered at a price less than or equal to the RPM auction clearing price in RPM auctions for the 2025/2026 Delivery Year (1,493.2 MW) less replacement MW (11.6 MW).

Market Conduct

- **2026/2027 RPM Third Incremental Auction.** Of the 985 generation resources that submitted Capacity Performance offers, unit specific offer caps were calculated for four generation resources (0.4 percent).

Market Performance

- The 2026/2027 RPM Third Incremental Auction was conducted in the first three months of 2026. The weighted average capacity price for the 2025/2026 Delivery Year is \$296.98 per MW-day, including all RPM auctions for the 2025/2026 Delivery Year. The weighted average capacity price for the 2026/2027 Delivery Year is \$324.88 per MW-day, including all RPM auctions for the 2026/2027 Delivery Year. The weighted average capacity price for the 2027/2028 Delivery Year is \$333.44 per MW-day, including all RPM auctions for the 2027/2028 Delivery Year.
- For the 2025/2026 Delivery Year, RPM annual charges to load are \$14.9 billion.
- In the 2027/2028 RPM Base Residual Auction, the market performance was determined to be not competitive.

Part V Reliability Service (RMR)

- Of the nine companies (28 units) that have provided service following deactivation requests, two companies (seven units) filed to be paid under the deactivation avoidable cost rate (DACR), the formula rate. The other seven companies (21 units) filed to be paid under the cost of service recovery rate.

Generator Performance

- **Forced Outage Rates.** The average PJM EFORd in the first three months of 2026 was 8.6 percent, an increase from 6.0 percent in the first three months of 2025.³⁰
- **Generator Performance Factors.** The PJM aggregate equivalent availability factor in the first three months of 2026 was 84.4 percent, a decrease from 86.1 percent in the first three months of 2025.

Recommendations³¹

Definition of Capacity

- The MMU recommends elimination of the key remaining components of the CP model because they interfere with competitive outcomes in the capacity market and create unnecessary complexity and risk. (Priority: High. First reported 2022. Status: Not adopted.)
- The MMU recommends the enforcement of a consistent definition of capacity resources. The MMU recommends that the tariff requirement to be a physical resource be enforced and enhanced. The requirement to be a physical resource should apply at the time of auctions and should also constitute a commitment to be physical in the relevant delivery year. The requirement to be a physical resource should be applied to all resource types, including planned generation, demand resources, and imports.^{32 33} (Priority: High. First reported 2013. Status: Not adopted.)

³⁰ The generator performance analysis includes all PJM capacity resources for which there are data in the PJM generator availability data systems (GADS) database. Data was downloaded from the PJM GADS database on April 22, 2026. EFORd data presented in state of the market reports may be revised based on data submitted after the publication of the reports as generation owners may submit corrections at any time with permission from PJM GADS administrators.

³¹ The MMU has identified serious market design issues with RPM and the MMU has made specific recommendations to address those issues. These recommendations have been made in public reports. See Table 5-2.

³² See also Comments of the Independent Market Monitor for PJM, Docket No. ER14-503-000 (December 20, 2013).

³³ See "Analysis of Replacement Capacity for RPM Commitments: June 1, 2007 to June 1, 2019," <http://www.monitoringanalytics.com/reports/Reports/2019/IMM_Analysis_of_Replacement_Capacity_for_RPM_Commitments_June_1_2007_to_

- The MMU recommends that DR providers be required to have a signed contract with specific customers for specific facilities for specific levels of DR at least six months prior to any capacity auction in which the DR is offered. (Priority: High. First reported 2016. Status: Not adopted.)
- The MMU recommends that Energy Efficiency Resources (EE) not be included in the capacity market construct because PJM's load forecasts have accounted for EE since the 2016 load forecast for the 2019/2020 Delivery Year. EE is not a capacity resource as defined in the tariff, and there is no reason to continue to pay large subsidies to EE providers.³⁴ (Priority: Medium. First reported 2016. Status: Adopted 2024.)³⁵
- The MMU recommends that PJM require all market participants to meet their deliverability requirements under the same rules. PJM should end the practice of giving away winter CIRs to intermittent resources that appear to exist because other resources paid for the supporting network upgrades. (Priority: High. First reported 2017. Status: Not adopted.)³⁶
- The MMU recommends that the must offer rule in the capacity market apply to all capacity resources. There is no reason to exempt intermittent and capacity storage resources, including hydro, and demand resources from the must offer requirement. The same rules should apply to all capacity resources in order to ensure open access to the transmission system and prevent the exercise of market power through withholding. (Priority: High. First reported 2021. Status: Partially adopted.)
- The MMU recommends that PJM require all market sellers of proposed generation capacity resources, including thermal and intermittent, to submit a binding notice of intent to offer at least six months prior to the base residual auction. This is consistent with the overall MMU recommendation that all capacity resources have a must offer obligation in the capacity market auctions. (Priority: High. First reported 2023. Status: Partially adopted.)

³⁴ [June_1_2019_20190913.pdf](#) (September 13, 2019).

³⁵ "PJM Manual 19: Load Forecasting and Analysis," § 3.2 Development of the Forecast, Rev. 38 (Dec. 17, 2025).

³⁶ See 189 FERC ¶ 61,095 (2024).

³⁶ This recommendation was first made in the 2020/2021 BRA report in 2017. See the "Analysis of the 2020/2021 RPM Base Residual Auction," <http://www.monitoringanalytics.com/reports/Reports/2017/IMM_Analysis_of_the_20202021_RPM_BRA_20171117.pdf> (November 11, 2017).

- The MMU recommends that PJM's application of the ELCC approach be replaced with an ELCC approach that is based on the actual hourly availability of all individual generators for accreditation and for payment. The MMU recommends short term modifications to PJM's approach to include hourly data that would permit unit specific ELCC ratings, to weight summer and winter risk in a more balanced manner, to eliminate PAI risks, and to pay for actual hourly performance rather than based on inflexible class capacity accreditation ratings derived from a small number of nonrepresentative hours of poor performance from PV1 and WSE. (Priority: High. First reported 2023. Status: Not adopted.)

Market Design and Parameters

- The MMU recommends that PJM establish a load queue for large new data center loads to ensure that such loads are not added until there is adequate generation capacity to serve them. The MMU recommends that an expedited queue option that would permit both the load and the generation to be added without delays be available to large data centers if they bring their own new generation with locational and temporal characteristics reasonably matched to their load profile. (Priority: High. First reported Q2, 2025. Status: Not adopted.)
- The MMU recommends that PJM reevaluate the shape of the VRR curve. The shape of the VRR curve directly results in load paying substantially more for capacity than load would pay with a vertical demand curve. More specifically, the MMU recommended that the VRR curve be rotated half way towards the vertical demand curve at the reliability requirement in the 2022 Quadrennial Review. (Priority: High. First reported 2021. Status: Partially adopted.)
- The MMU recommends that the maximum price on the VRR curve be defined as 1.5 times Net CONE, capped at Gross CONE. (Priority: Medium. First reported 2019. Status: Not adopted.)
- The MMU recommends that the reference resource be a CT rather than a CC. The MMU recommends that the ELCC value used to convert the gross CONE in ICAP terms for a CT to the gross CONE in UCAP terms be the

ELCC based on winter ratings. (Priority: High. First reported 2024. Status: Adopted 2025.)

- The MMU recommends that the test for determining modeled Locational Deliverability Areas (LDAs) in RPM be redefined. A detailed reliability analysis of all at risk units should be included in the redefined model including transmission constraints inside LDAs. The market design should clear and pay units that are needed for reliability per PJM's transmission reliability analysis in order to forestall RMRs. (Priority: Medium. First reported 2013. Status: Not adopted.)
- The MMU recommends that PJM clear the capacity market based on nodal capacity resource locations and the characteristics of the transmission system inside and outside LDAs consistent with the actual electrical facts of the grid. Absent a fully nodal capacity market clearing process, the MMU recommends that PJM use a non-nested model with all LDAs modeled including VRR curves for all LDAs. Each LDA requirement should be met with the capacity resources located within the LDA and exchanges from neighboring LDAs up to the transmission limit. LDAs should be allowed to price separate if that is the result of the LDA supply curves and the transmission constraints between LDAs. (Priority: Medium. First reported 2017. Status: Not adopted.)
- The MMU recommends that the net revenue offset calculation used by PJM to calculate the net Cost of New Entry (CONE) and net ACR be based on a forward looking calculation of expected energy and ancillary services net revenues using historical net revenues that are scaled based on forward prices for energy and fuel. (Priority: High. First reported 2014. Status: Not adopted.)³⁷
- The MMU recommends that PJM reduce the number of incremental auctions to a single incremental auction held three months prior to the start of the delivery year and reevaluate the triggers for holding conditional incremental auctions. (Priority: Medium. First reported 2013. Status: Not adopted.)

³⁷ This recommendation was first made during the Quadrennial Review in 2014, including the PJM Capacity Senior Task Force (CSTF), the MRC and the MC. <<https://www.pjm.com/committees-and-groups/closed-groups/cstf>>.

- The MMU recommends that PJM not sell back any capacity in any IA procured in a BRA. If PJM continues to sell back capacity, the MMU recommends that PJM offer to sell back capacity in incremental auctions only at the BRA clearing price for the relevant delivery year. (Priority: Medium. First reported 2017. Status: Not adopted.)
- The MMU recommends that PJM not buy any capacity in any IA if PJM has already procured excess reserves. (Priority: Medium. First reported 2023. Status: Not adopted.)
- The MMU recommends changing the RPM solution method to explicitly incorporate the cost of uplift (make whole) payments in the objective function. (Priority: Medium. First reported 2014. Status: Not adopted.)
- The MMU recommends that the Fixed Resource Requirement (FRR) rules, including obligations and performance requirements, be revised and updated to ensure that the rules reflect current market realities and that FRR entities do not unfairly take advantage of those customers paying for capacity in the PJM capacity market. (Priority: Medium. First reported 2019. Status: Not adopted.)
- The MMU recommends that the value of CTRs be defined by the total MW cleared in the capacity market, the internal MW cleared and the imported MW cleared, and not redefined later prior to the delivery year. (Priority: Medium. First reported 2021. Status: Not adopted.)
- The MMU recommends that the market clearing results be used in settlements rather than the reallocation process currently used, or that the process of modifying the obligations to pay for capacity be reviewed. (Priority: Medium. First reported 2021. Status: Not adopted.)³⁸
- The MMU recommends that PJM improve the clarity and transparency of its CETL calculations. The MMU also recommends that CETL for capacity imports into PJM be based on the ability to import capacity only where PJM capacity exists and where that capacity has a must offer requirement in the PJM Capacity Market. (Priority: Medium. First reported 2021. Status: Partially adopted 2022.)

³⁸ This recommendation was first made in the 2023/2024 BRA report in 2022. See "Analysis of the 2023/2024 RPM Base Residual Auction Revised," <http://www.monitoringanalytics.com/reports/Reports/2022/IMM_Analysis_of_the_20232024_RPM_Base_Residual_Auction_20221028.pdf> (October 28, 2022).

Offer Caps, Offer Floors, and Must Offer

- The MMU recommends using the lower of the cost or price-based energy market offer to calculate energy costs in the calculation of the historical net revenues which are an offset to gross ACR in the calculation of unit specific capacity resource offer caps based on net ACR. (Priority: Medium. First reported 2021. Status: Not adopted.)
- The MMU recommends that modifications to existing resources, including relatively small proposed increases in the capability of a Generation Capacity Resource be treated as an existing resource and subject to the corresponding market power mitigation rules and no longer be treated as planned and exempt from offer capping. (Priority: Medium. First reported 2012. Status: Not adopted.)³⁹
- The MMU recommends that the RPM market power mitigation rules be modified to apply offer caps in all cases when the three pivotal supplier test is failed and the sell offer is greater than the offer cap. This will ensure that market power does not result in an increase in uplift (make whole) payments for seasonal products. (Priority: Medium. First reported 2017. Status: Not adopted.)
- The MMU recommends that any combined seasonal resources be required to be in the same LDA and at the same location, in order for the energy market and capacity market to remain synchronized and reliability metrics correctly calculated. (Priority: Medium. First reported 2021. Status: Not adopted.)
- The MMU recommends that the definition of avoidable costs in the tariff be corrected to be consistent with the economic definition. Avoidable costs are costs that are neither short run marginal costs, like fuel or consumables, nor fixed costs like depreciation and rate of return. Avoidable costs are the marginal costs of capacity and therefore the competitive offer level for capacity resources and therefore the market seller offer cap. Avoidable costs are the marginal costs of capacity for both new resources

³⁹ This recommendation was first made in the 2014/2015 BRA report in 2012. See "Analysis of the 2014/2015 RPM Base Residual Auction," <http://www.monitoringanalytics.com/reports/Reports/2012/Analysis_of_2014_2015_RPM_Base_Residual_Auction_20120409.pdf> (April 9, 2012).

and existing resources. (Priority: Medium. First reported 2017. Status: Not adopted.)⁴⁰

- The MMU recommends that major maintenance costs be included in the definition of avoidable costs and removed from energy offers because such costs are avoidable costs and not short run marginal costs. (Priority: High. First reported 2019. Status: Not adopted.)
- The MMU recommends that capacity market sellers be required to explicitly request and support the use of minimum MW quantities (inflexible sell offer segments) and that the requests only be permitted for defined physical reasons. (Priority: Medium. First reported 2018. Status: Not adopted.)
- The MMU recommends that, as part of the MOPR unit specific standard of review, all projects be required to use the same basic modeling assumptions. That is the only way to ensure that projects compete on the basis of actual costs rather than on the basis of modeling assumptions.⁴¹ (Priority: High. First reported 2013. Status: Not adopted.)
- The only function the current MOPR is serving now is to create unnecessary administrative work in the application and compliance screening and to create barriers to entry for generation resources. Absent a meaningful change to MOPR, the MMU recommends eliminating the MOPR. (Priority: High. First reported 2025. Status: Not adopted.)

Performance Incentive Requirements of RPM

- The MMU recommends that any unit not capable of supplying energy equal to its day-ahead must offer requirement (ICAP) be required to reflect an appropriate outage and associated performance penalty. (Priority: Medium. First reported 2009. Status: Not adopted.)

⁴⁰ This recommendation was first made in the 2023/2024 BRA report in 2022. See "Analysis of the 2023/2024 RPM Base Residual Auction Revised," <http://www.monitoringanalytics.com/reports/Reports/2022/IMM_Analysis_of_the_20232024_RPM_Base_Residual_Auction_20221028.pdf> (October 28, 2022).

⁴¹ See 143 FERC ¶ 61,090 (2013) ("We encourage PJM and its stakeholders to consider, for example, whether the unit-specific review process would be more effective if PJM requires the use of common modeling assumptions for establishing unit-specific offer floors while, at the same time, allowing sellers to provide support for objective, individual cost advantages. Moreover, we encourage PJM and its stakeholders to consider these modifications to the unit-specific review process together with possible enhancements to the calculation of Net CONE."); see also, Comments of the Independent Market Monitor for PJM, Docket No. ER13-535-001 (March 25, 2013); Complaint of the Independent Market Monitor for PJM v. Unnamed Participant, Docket No. EL12-63-000 (May 1, 2012); Motion for Clarification of the Independent Market Monitor for PJM, Docket No. ER11-2875-000, et al. (February 17, 2012); Protest of the Independent Market Monitor for PJM, Docket No. ER11-2875-002 (June 2, 2011); Comments of the Independent Market Monitor for PJM, Docket Nos. EL11-20 and ER11-2875 (March 4, 2011).

- The MMU recommends that retroactive replacement transactions associated with a failure to perform during a PAI not be allowed and that, more generally, retroactive replacement capacity transactions not be permitted. (Priority: Medium. First reported 2016. Status: Not adopted.)
- The MMU recommends that there be an explicit requirement that capacity resource offers in the day-ahead energy market be competitive, where competitive is defined to be the short run marginal cost of the units, including flexible operating parameters. (Priority: Low. First reported 2013. Status: Not adopted.)
- The MMU recommends that Capacity Performance resources be required to perform without excuses. Resources that do not perform should not be paid regardless of the reason for nonperformance. (Priority: High. First reported 2019. Status: Not adopted.)
- The MMU recommends that PJM require actual seasonal tests as part of the Summer/Winter Capability Testing rules, that the number of tests be limited, and that the ambient conditions under which the tests are performed be defined to reflect seasonal extreme conditions. (Priority: Medium. First reported 2022. Status: Not adopted.)
- The MMU recommends that PJM select the time and day that a unit undergoes Net Capability Verification Testing, not the unit owner, and that this information not be communicated in advance to the unit owner. (Priority: Medium. First reported 2022. Status: Not adopted.)

Capacity Imports and Exports

- The MMU recommends that all capacity imports be required to be deliverable to PJM load in an identified LDA, zonal or subzonal, or defined combinations of specific zones, e.g. MAAC, prior to the relevant delivery year to ensure that they are full substitutes for internal, physical capacity resources. Pseudo ties alone are not adequate to ensure deliverability to PJM load. (Priority: High. First reported 2016. Status: Not adopted.)
- The MMU recommends that all costs incurred as a result of a pseudo tied unit be borne by the unit itself and included as appropriate in unit

offers in the capacity market. (Priority: High. First reported 2016. Status: Not adopted.)

- The MMU recommends that the PJM Tariff be modified to explicitly state that in order to qualify, a Capacity Market Seller requesting a must offer exception based on a financially and physically firm commitment to an external sale of its capacity must provide a confirmed firm transmission reservation, covering the entire path from source to sink, for the full requested ICAP MW of the external sale that covers the entire delivery year, by the tariff defined deadline. The MMU recommends that this language apply to all external sales of Generation Capacity Resources, including those where an external balancing authority does not require this level of transmission service in order to consider a PJM resource as a network resource. (Priority: High. First reported 2025. Status: Not adopted.)

Deactivations/Retirements

- The MMU recommends that the notification requirement for deactivations be extended from the current one quarter prior (See Table 5-31) to 12 months prior to an auction in which the unit will not be offered due to deactivation; and no less than 12 months prior to the date of deactivation (Priority: Low. First reported 2012. Status: Partially adopted.)
- The MMU recommends that the same reliability standard be used in capacity auctions as is used by PJM transmission planning. One result of the current design is that a unit may fail to clear in a BRA, decide to retire as a result, but then be found to be needed for reliability by PJM planning and paid under Part V of the OATT (RMR) to remain in service while transmission upgrades are made. (Priority: High. First reported 2023. Status: Not adopted.)
- The MMU recommends elimination of both the cost of service recovery rate option and the deactivation avoidable cost rate option for providing Part V reliability service (RMR), and their replacement with clear language that provides for the recovery of 100 percent of the actual incremental costs required to operate to provide the service plus a defined incentive. (Priority: High. First reported 2017. Status: Not adopted.)
- The MMU recommends that units recover all and only the incremental costs, including incremental investment costs without a cap, required to provide Part V reliability service (RMR service) that the unit owner would not have incurred if the unit owner had deactivated its unit as it proposed, plus a defined incentive payment. Customers should bear no responsibility for paying previously incurred (sunk) costs, including a return on or of prior investments. (Priority: High. First reported 2010. Status: Not adopted.)
- The MMU recommends that if units that are paid under Part V of the OATT (RMR) are included in the calculation of CETO and/or reliability in the relevant LDA, the capacity of the RMR resources should also be included in capacity market supply at zero cost, but without all the obligations of a capacity resource, in order to ensure that the capacity market price signal reflects the appropriate supply and demand conditions. (Priority: High. First reported 2023. Status: Partially adopted.)
- The MMU recommends that units that are paid under Part V of the OATT (RMR) not be included in the calculation of CETO or reliability in the relevant LDA, in order to ensure that the capacity market price signal reflects the appropriate supply and demand conditions, until a decision is made to build transmission as a replacement, and then should be included. (Priority: High. First reported 2023. Status: Not adopted.)
- The MMU recommends that all CIRs be returned to the pool of available interconnection capability on the retirement date of generation resources in order to facilitate timely and competitive entry into the PJM markets, open access to the transmission system and maintain the priority order defined by the queue process. (Priority: High. First reported 2023. Status: Not adopted.)

Conclusion

The analysis of the PJM Capacity Market begins with market design and market structure, which provide the framework for the actual behavior or conduct of market participants. The analysis examines participant behavior within that market design and market structure. Regardless of the ownership structure of a market, the market design can result in noncompetitive outcomes. In a

good market design and a competitive market structure, market participants are constrained to behave competitively. In a market with endemic structural market power like the PJM Capacity Market, effective market power mitigation rules are required in order to constrain market participants to behave competitively. The analysis examines market performance, measured by price and the relationship between price and marginal cost, that results from the interaction of market structure and participant behavior. The analysis also examines the impact of market design choices on market performance.

The MMU concludes that the results of the 2026/2027 RPM Base Residual Auction were significantly affected by flawed market design elements including the lack of a queue for the addition of large new data center loads, by the performance assessment interval (PAI) penalties that are part of the CP design, by PJM's ELCC approach, by the definition of market seller offer caps, by the failure to extend the RPM must offer requirement to demand resources, and by the product definition and lack of market power mitigation for demand resources. The BRA prices do not reflect supply and demand fundamentals but reflect, in significant part, PJM decisions about the definition of supply and demand. PJM filed changes that were approved by FERC and included in the 2026/2027 BRA to adopt two of the MMU's recommendations, the inclusion of specific RMR resources as supply in the next two BRAs and the elimination of the categorical exemption to the RPM must offer requirement, although PJM failed to include elimination of the categorical exemption for demand resources.^{42 43}

The capacity market is, by design, always tight in the sense that total supply is generally only slightly larger than demand. While the market may be long at times, that is not the equilibrium state. Market power is and will remain endemic to the structure of the PJM Capacity Market. Nonetheless, a competitive outcome can be assured by appropriate market power mitigation rules within an effective market design. Detailed market power mitigation rules are included in the PJM Open Access Transmission Tariff (OATT or Tariff). Reliance on the RPM design for competitive outcomes means reliance on the market power mitigation rules.

⁴² See Letter Order, FERC Docket No. ER25-682-001 (April 29, 2025).
⁴³ 190 FERC ¶ 61,117 (2025).

The basic conclusion of Part A of the MMU's analysis of the 2026/2027 BRA is that data center load growth is the primary reason for recent and expected capacity market conditions, including total forecast load growth, the tight supply and demand balance, and high prices. But for data center growth, both actual and forecast, the PJM Capacity Market would not have seen the same tight supply demand conditions, the same high prices observed in the 2025/2026 BRA and 2026/2027 BRA or the currently expected tight supply conditions and high prices for subsequent capacity auctions. The combined total increase in capacity market revenues resulting from data center load, both actual and forecast, for the 2025/2026 BRA and the 2026/2027 BRA was \$16,603,301,829.^{44 45} This total will continue to grow until the issues associated with the additions of large data center loads are addressed.

It is misleading to assert that the capacity market results are simply just a reflection of supply and demand. The current conditions are not the result of organic load growth. The current conditions in the capacity market are almost entirely the result of large load additions from data centers, both actual historical and forecast. The growth in data center load and the expected future growth in data center load are unique and unprecedented and uncertain and require a different approach than simply asserting that it is just supply and demand.

It is equally misleading to assert that the PJM Capacity Market does not work as a result of the impact of existing and forecast large data center load additions. Despite all the issues with PJM's changes to the capacity market design, the PJM Capacity Market would have provided for reliability at prices consistent with organic load growth and the cost of new capacity were it not for the paradigm shift represented by the almost inexhaustible demand for power from data centers.

Data center load growth is the core reliability issue facing PJM markets at present. There is still time to address the issue but failure to do so will result in very high costs for other PJM customers and could also result in a switch

⁴⁴ See, "Analysis of the 2025/2026 RPM Base Residual Auction - Part G Revised," <https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_2025_2026_RPM_Base_Residual_Auction_Part_G_20250603_Revised.pdf> (June 3, 2025).
⁴⁵ See "Analysis of the 2026/2027 RPM Base Residual Auction - Part A," ("Part A") <https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20262027_RPM_Base_Residual_Auction_Part_A_20251001.pdf> (October 1, 2025).

from competitive markets to cost of service regulation or other distortions of the market design. Customers are already bearing billions of dollars in higher costs as a direct result of existing and forecast data center load as the Market Monitor demonstrated in Part G of the 2025/2026 BRA Analysis report and Part A of the 2026/2027 BRA Analysis Report.^{46 47}

PJM should not continue to interconnect large new data center load if that load cannot be served reliably. The goal should be to serve all load that can be served reliably. The MMU recommends that PJM establish a load queue for large new data center loads to ensure that such loads are not added until there is adequate generation capacity to serve them. The MMU recommends that an expedited queue option that would permit both the load and the generation to be added without delays be available to large data centers if they bring their own new generation with locational and temporal characteristics reasonably matched to their load profile.

For the first time since the introduction of the RPM capacity market design, the 2026/2027 BRA used a VRR curve with both a defined maximum price and a defined minimum price. The maximum and minimum prices were based on the Agreement between Governor Shapiro of Pennsylvania and PJM that was incorporated in a PJM filing with FERC.⁴⁸ That VRR curve with the defined maximum and minimum price is referred to in this report as the actual (or restricted) VRR curve. The VRR curve that would have been used absent the Agreement is referred in this report as the unrestricted VRR curve.

The Agreement resulted in a reduction of 2026/2027 BRA revenues of \$3,169,915,210, or 16.4 percent, compared to the revenues that would have resulted from the unrestricted VRR curve, holding everything else constant. If the 2026/2027 BRA had been run with an unrestricted VRR curve, total revenues would have been \$19,294,286,100, an increase of \$3,169,915,210,

⁴⁶ Post Technical Conference Comments of the Independent Market Monitor for PJM (July 7, 2025) *Resource Adequacy Meeting the Challenge of Resource Adequacy in Regional Transmission Organization and Independent System Operator Regions*, Docket No. AD25-7.

⁴⁷ See "Analysis of the 2026/2027 RPM Base Residual Auction - Part A," (October 1, 2025) <https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20262027_RPM_Base_Residual_Auction_Part_A_20251001.pdf>.

⁴⁸ On December 30, 2024, in Docket No. EL25-46-000, Governor Josh Shapiro and the Commonwealth of Pennsylvania filed a complaint against PJM asserting that the maximum price for PJM's capacity auctions is unjust and unreasonable. The Governor and PJM reached an Agreement. On February 20, 2025, in Docket No. ER25-1357-000, pursuant to FPA section 205, PJM submitted proposed revisions to its Tariff to establish a specific maximum price and minimum price for all RPM auctions for the 2026/2027 and 2027/2028 Delivery Years, consistent with the Agreement.

or 19.7 percent, compared to the actual auction revenues of \$16,124,370,889. The Agreement resulted in a reduction of 2027/2028 BRA revenues of \$9,913,272,621, or 37.7 percent, compared to the revenues that would have resulted from the unrestricted VRR curve, holding everything else constant. If the 2027/2028 BRA had been run with an unrestricted VRR curve, total revenues would have been \$26,324,850,846, an increase of \$9,913,272,621, or 60.4 percent, compared to the actual auction revenues of \$16,411,578,225. The Agreement resulted in a reduction of combined 2026/2027 and 2027/2028 BRA revenues of \$13,083,187,831, or 28.7 percent, compared to the revenues that would have resulted from the unrestricted VRR curve, holding everything else constant.

The demand for capacity includes expected peak load plus a reserve margin, and points on the demand curve, called the Variable Resource Requirement (VRR) curve, exceed peak load plus the reserve margin. The maximum price on the VRR curve has a significant impact on market prices particularly when the market is tight. The shape of the VRR curve results in the purchase of excess capacity and higher payments by customers. The VRR curves used in the 2025/2026 BRA included a maximum price equal to gross CONE for most LDAs that resulted in a significant increase in customer payments for load as a result of paying a price above the competitive level. Demand for capacity is almost entirely inelastic because the market rules require loads to purchase their share of the system capacity requirement. The VRR demand curve is everywhere inelastic. The result is that any supplier that owns more capacity than the typically small difference between total supply and the defined demand is individually pivotal and therefore has structural market power.

For the 2026/2027 RPM Base Residual Auction, total reserves were 21,353.2 MW, which is 208.7 MW (UCAP) short of the required reserve level of 21,561.9 MW (UCAP). The level of committed demand resources in the 2026/2027 BRA was 5,530.6 MW, meaning the PJM markets will rely on demand resources as part of the required reserve margin, rather than as excess above the required reserve margin. This is not consistent with the defined obligations of DR compared to other capacity resources. DR capacity resources do not have a must offer obligation in the energy market. DR capacity resources do not have

a must offer obligation in the capacity market. The definition of performance for DR is not to provide a defined incremental level of MW when called but is only to be at a defined level of demand. DR capacity resources have significantly under performed during recent cold weather and hot weather events. DR capacity resources do not have a defined market seller offer cap. PJM markets for the first time in the 2025/2026 and 2026/2027 Delivery Years will rely on demand response resources as part of the required reserve margin, rather than as excess above the required reserve margin. PJM markets for the first time in the 2025/2026 and 2026/2027 Delivery Years will experience the implications of the definition of demand resources as a purely emergency capacity resource, when demand resources are a significant share of required reserves. Nonetheless, as another significant flaw in the market design, PJM does not include DR in its definition of primary or secondary reserves in the energy market. DR, for all these reasons, is an inferior resource in the capacity market. PJM does not have clear rules defining when the operators must call on DR.

There are currently two important gaps in the market power rules for the PJM Capacity Market related to demand resources. The RPM must offer requirement is not applied to demand resources. There are no market power mitigation rules that apply to demand resources.

For the 2026/2027 BRA, all participants to which the three pivotal supplier (TPS) test was applied (in the RTO RPM market) failed the three pivotal supplier test. The result was that offer caps were applied to all sell offers for Existing Generation Capacity Resources when the capacity market seller did not pass the test, the submitted sell offer exceeded the tariff defined offer cap, and the submitted sell offer, absent mitigation, would have resulted in a higher market clearing price.^{49 50}

The correct definition of a competitive offer in the capacity market is the marginal cost of capacity, net ACR, where gross ACR includes an explicit

accounting for the costs of mitigating risk, including the risk associated with mitigating rational capacity market nonperformance penalties, and the relevant costs of acquiring fuel, including natural gas, and net ACR includes all energy and ancillary services net revenues as an offset against every element of gross ACR.

The MMU recommends elimination of the key remaining components of the CP model because they interfere with competitive outcomes in the capacity market and create unnecessary complexity and risk. The use of Net CONE as the basis for the PAI penalty rate is unsupported by economic logic. The use of Net CONE to establish penalties is a form of arbitrary administrative pricing that creates arbitrarily high risk for generators, creates complexity in the calculation of CPQR and increases CPQR above rational levels, and ultimately raises the price of capacity above the competitive level. Given PJM's recent decision to rely on conservative operations during tight market conditions as evidenced during Polar Vortex 2025 in January 2025, the probability of a PAI is extremely small. In addition, PJM tightened the definition of a PAI and capped the total annual penalty at 1.5 times the resource's capacity market BRA clearing price. There is no effective performance incentive remaining in the capacity market. In the absence of the EFORD design and with the absence of actual or expected regular PAI events, there is no capacity market consequence for failing to perform.

Rather than penalizing capacity resources at extremely high levels for nonperformance only during PAI events, capacity resources should be paid the daily price of capacity only to the extent that they are available to produce energy or provide reserves, as required by PJM on a daily/hourly basis, based on their cleared capacity (ICAP). This is a positive performance incentive based on the market price of capacity rather than a penalty based on an arbitrary assumption. This would mean that capacity resources are paid to provide energy and reserves based on their full ICAP and are not paid a bonus for doing so. The reduced payments for capacity would directly reduce customers' bills for capacity. This would also end the pretense that there will be penalty payments to fund bonus payments. This would also end the need for complex CPQR calculations based on the penalty rate and assumptions

⁴⁹ Prior to November 1, 2009, existing DR and EE were subject to market power mitigation in RPM Auctions. See 129 FERC ¶ 61,081 (2009) at P 30.

⁵⁰ Effective January 31, 2011, the RPM rules related to market power mitigation were changed, including revising the definition for Planned Generation Capacity Resource and creating a new definition for Existing Generation Capacity Resource for purposes of the must-offer requirement and market power mitigation, and treating a proposed increase in the capability of a Generation Capacity Resource the same in terms of mitigation as a Planned Generation Capacity Resource. See 134 FERC ¶ 61,065 (2011).

about the number and timing of PAI events. CP has not worked as the theory suggested. PAI events are high impact, low probability events. The failure of the PAI incentives to prevent a very high level of outages during Winter Storm Elliott illustrates the weakness of incentives based on this type of event. In addition, the actual performance standards were unacceptably weakened in the CP model. The standard of performance in the CP model is $(B) * (ELCC \text{ accredited UCAP factor for a unit})$, where B is the balancing ratio and the ELCC accredited UCAP factor is the derating factor. For example, if B were 80 percent, the actual required performance for a unit with an 80 percent ELCC accredited UCAP factor would be only 64 percent of ICAP ($.80 * .80$). For units with low ELCC accredited UCAP factors, the required performance is even lower. The obligation to perform should equal the full ICAP value of a unit, consistent with the associated must offer obligation in the energy market for capacity resources.

The MMU is required to identify market issues and to report them to the Commission and to market participants. The Commission decides on any action related to the MMU's findings.

The MMU has identified serious market design issues with RPM and the MMU has made specific recommendations to address those issues.^{51 52 53 54 55 56 57 58 59}

51 See "Analysis of the 2018/2019 RPM Base Residual Auction Revised," (July 6, 2016) <http://www.monitoringanalytics.com/reports/Reports/2016/IMM_Analysis_of_the_20182019_RPM_Base_Residual_Auction_20160706.pdf>
 52 See "Analysis of the 2019/2020 RPM Base Residual Auction Revised," (August 31, 2016) <http://www.monitoringanalytics.com/reports/Reports/2016/IMM_Analysis_of_the_20192020_RPM_BRA_20160831-Revised.pdf>
 53 See "Analysis of the 2020/2021 RPM Base Residual Auction," (November 11, 2017) <http://www.monitoringanalytics.com/reports/Reports/2017/IMM_Analysis_of_the_20202021_RPM_BRA_20171117.pdf>
 54 See "Analysis of the 2021/2022 RPM Base Residual Auction - Revised," (August 24, 2018) <http://www.monitoringanalytics.com/reports/Reports/2018/IMM_Analysis_of_the_20212022_RPM_BRA_Revised_20180824.pdf>
 55 See "Analysis of the 2022/2023 RPM Base Residual Auction," (February 22, 2022) <https://www.monitoringanalytics.com/reports/Reports/2022/IMM_Analysis_of_the_20222023_RPM_BRA_20220222.pdf>
 56 See "Analysis of the 2023/2024 RPM Base Residual Auction," (October 28, 2022) <https://www.monitoringanalytics.com/reports/Reports/2022/IMM_Analysis_of_the_20232024_RPM_Base_Residual_Auction_20221028.pdf>
 57 See the "Analysis of the 2024/2025 RPM Base Residual Auction," (October 30, 2023) <https://www.monitoringanalytics.com/reports/Reports/2023/IMM_Analysis_of_the_20242025_RPM_Base_Residual_Auction_20231030.pdf>
 58 See "Analysis of Replacement Capacity for RPM Commitments: June 1, 2007 to June 1, 2017," (December 14, 2017) <http://www.monitoringanalytics.com/reports/Reports/2017/IMM_Report_on_Capacity_Replacement_Activity_4_20171214.pdf>
 59 See "Analysis of Replacement Capacity for RPM Commitments: June 1, 2007 to June 1, 2019," (September 13, 2019) <http://www.monitoringanalytics.com/reports/Reports/2019/IMM_Analysis_of_Replacement_Capacity_for_RPM_Commitments_June_1_2007_to_June_1_2019_20190913.pdf>

^{60 61 62 63 64} In 2025 and the first three months of 2026, the MMU prepared a number of RPM related reports and testimony, shown in Table 5-2.

The PJM markets have worked to provide incentives to entry and to retain capacity. A majority of capacity investments in PJM were financed by market sources. Of the 57,618.3 MW of additional capacity that cleared in RPM auctions for the 2007/2008 through 2024/2025 Delivery Years, 43,653.8 MW (76.0 percent) were based on market funding. Of the 22,187.4 MW of additional capacity that cleared in RPM auctions for the 2025/2026 through the 2027/2028 Delivery Years, 18,225.0 MW (82.1 percent) were based on market funding. Those investments were made based on the assumption that markets would be allowed to work and that inefficient units would exit.

It is essential that any approach to the PJM markets incorporate a consistent view of how the preferred market design is expected to provide competitive results in a sustainable market design over the long run. A sustainable market design means a market design that results in appropriate incentives to competitive market participants to retire units and to invest in new units over time such that reliability is ensured as a result of the functioning of the market.

In order to attract and retain adequate resources for the reliable operation of the energy market, revenues from PJM energy, ancillary services and capacity markets must be adequate for those resources. That adequacy requires a capacity market. The capacity market plays the essential role of equilibrating the revenues necessary to incent competitive entry and exit of the resources needed for reliability, with the revenues from the energy market that are directly affected by nonmarket sources.

60 See "Analysis of the 2025/2026 RPM Base Residual Auction - Part A," (September 20, 2024) <https://www.monitoringanalytics.com/reports/Reports/2024/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_A_20240920.pdf>
 61 See "Analysis of the 2025/2026 RPM Base Residual Auction - Part B," (October 15, 2024) <https://www.monitoringanalytics.com/reports/Reports/2024/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_B_20241015.pdf>
 62 See Monitoring Analytics, LLC, Analysis of the 2025/2026 Base Residual Auction, Parts A through H, <<https://www.monitoringanalytics.com/reports/Reports/2024.shtml>> and <<https://www.monitoringanalytics.com/reports/Reports/2025.shtml>>
 63 See "Analysis of the 2026/2027 RPM Base Residual Auction - Part A," (October 1, 2025) <https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20262027_RPM_Base_Residual_Auction_Part_A_20251001.pdf>
 64 See "Analysis of the 2027/2028 RPM Base Residual Auction - Part A," (January 5, 2026) <https://www.monitoringanalytics.com/reports/Reports/2026/IMM_Analysis_of_the_20272028_RPM_Base_Residual_Auction_Part_A_20260105.pdf>

Table 5-2 RPM related MMU reports: 2025 through March 2026

Date	Name
January 6, 2025	IMM Comments re Capacity Market Rules Docket No. ER25-682 https://www.monitoringanalytics.com/filings/2025/IMM_Comments_Docket_No_ER25-682_20250106.pdf
January 10, 2025	IMM Comments re Must Offer Exemption for Capacity Resources Docket No. ER25-785 https://www.monitoringanalytics.com/filings/2025/IMM_Comments_Docket_No_ER25-785_20250110.pdf
January 14, 2025	IMM Answer to Motion to Extend re PA BRA Complaint Docket No. EL25-46 https://www.monitoringanalytics.com/filings/2025/IMM_Answer_to_Motion_to_Extend_Docket_No_EL25-46_20250114.pdf
January 23, 2025	IMM Comments re JCA Capacity Complaint Docket No. EL25-18 https://www.monitoringanalytics.com/filings/2025/IMM_Comments_Docket_No_EL25-18_20250123.pdf
January 31, 2025	Analysis of the 2025/2026 RPM Base Residual Auction – Part E https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_E_20250131.pdf
February 4, 2025	Analysis of the 2025/2026 RPM Base Residual Auction – Part F https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_F_20250204.pdf
February 7, 2025	PA/PJM Agreement re Maximum and Minimum RPM Prices https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_MC_PA_PJM_Agreement_Max_Min_RPM_Prices_20250207.pdf
February 7, 2025	Data Submission Window Opening for the 2026/2027 RPM Base Residual Auction https://www.monitoringanalytics.com/reports/Market_Messages/RPM_Material/IMM_Data_Submission_Window_Opening_2026-2027_RPM_Base_Residual_Auction_20250207.pdf
February 10, 2025	IMM Answer to PJM re Capacity Market Rules Docket No. ER25-682 https://www.monitoringanalytics.com/filings/2025/IMM_Answer_to_PJM_Answer_Docket_No_ER25-682_20250210.pdf
February 18, 2025	IMM Answer re Must Offer Exemption for Capacity Resources Docket No. ER25-785 https://www.monitoringanalytics.com/filings/2025/IMM_Answer_to_Answer_Docket_No_ER25-785_20250218.pdf
February 25, 2025	Generation Capacity Resources in PJM Region Subject to RPM Must Offer Obligation for 2025/2026 Delivery Year https://www.monitoringanalytics.com/reports/Market_Messages/RPM_Material/IMM_Notice_re_RPM_Must_Offer_Obligations_20250225.pdf
March 6, 2025	Data Submission Window Opening for the 2026/2027 RPM Base Residual Auction – Updated https://www.monitoringanalytics.com/reports/Market_Messages/RPM_Material/IMM_Data_Submission_Window_Opening-20262027_Base_Residual_Auction_Updated_2_20250306.pdf
March 17, 2025	IMM Comments re PJM VRR Docket Nos. ER25-1357 and EL25-46, not consolidated https://www.monitoringanalytics.com/filings/2025/IMM_Comments_Docket_Nos_ER25-1357_and_EL25-46_20250317.pdf
March 19, 2025	IMM Request for Rehearing re Market Seller Offer Caps for Capacity Resources Docket No. ER25-785 https://www.monitoringanalytics.com/filings/2025/IMM_Request_for_Rehearing_Docket_No_ER25-785_20250319.pdf
April 10, 2025	IMM Determinations Posted for the PJM 2026/2027 RPM Base Residual Auction https://www.monitoringanalytics.com/reports/Market_Messages/RPM_Material/IMM_Determinations_on_RPM_Requests_2026-2027_Base_Residual_Auction_Revised_20250410.pdf
May 9, 2025	IMM Comments re Mitigating Variability in ELCC Accreditation between RPM Auctions Docket No. ER25-2002 https://www.monitoringanalytics.com/filings/2025/IMM_Comments_Docket_No_ER25-2002_20250509.pdf
May 19, 2025	Quadrennial Review Issues https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_MIC_Quadrennial_Review_20250519.pdf
May 28, 2025	IMM Answer re Warrior Run Waiver Request Docket No. ER25-2197 https://www.monitoringanalytics.com/filings/2025/IMM_Answer_re_Warrior_Run_Docket_No_ER25-2197_20250528.pdf
May 28, 2025	IMM Answer re Sayreville Waiver Request Docket No. ER25-2162 https://www.monitoringanalytics.com/filings/2025/IMM_Answer_re_Sayreville_Docket_No_ER25-2162_20250528.pdf
May 28, 2025	IMM Answer re Morgantown Waiver Request Docket No. ER25-2190 https://www.monitoringanalytics.com/filings/2025/IMM_Answer_re_Morgantown_Docket_No_ER25-2190_20250528.pdf
June 3, 2025	Analysis of the 2025/2026 RPM Base Residual Auction – Part G Revised https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_G_20250603_Revised.pdf
June 9, 2025	IMM Comments re NCEMC Complaint Docket No. EL25-79 https://www.monitoringanalytics.com/filings/2025/IMM_Comments_Docket_No_EL25-79_20250609.pdf
June 9, 2025	IMM Answer to Answer re PJM BRA ELCC Values Docket No. ER25-2002 https://www.monitoringanalytics.com/filings/2025/IMM_Answer_to_Answer_Docket_No_ER25-2002_20250609.pdf
June 16, 2025	IMM Answer to PJM Answer re PJM BRA ELCC Values Docket No. ER25-2002 https://www.monitoringanalytics.com/filings/2025/IMM_Answer_to_PJM_Docket_No_ER25-2002_20250616.pdf
June 30, 2025	Generation Capacity Resources in PJM Region Subject to RPM Must Offer Obligation for 2026/2027 Delivery Year https://www.monitoringanalytics.com/reports/Market_Messages/IMM_Notice_re_RPM_Must_Offer_Obligations_20250630.pdf
June 30, 2025	Quadrennial Review Proposal and Issues https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_MIC_Quadrennial_Review_Issues_20250630.pdf
July 7, 2025	Data Submission Window Opening for the 2027/2028 RPM Base Residual Auction https://www.monitoringanalytics.com/reports/Market_Messages/IMM_Data_Submission_Window_Opening_2027-2028_RPM_Base_Residual_Auction_20250707.pdf
July 8, 2025	Generation Capacity Resources in PJM Region Subject to RPM Must Offer Obligation for 2026/2027 Delivery Year https://www.monitoringanalytics.com/reports/Market_Messages/IMM_Notice_re_RPM_Must_Offer_Obligations_20250708.pdf
July 9, 2025	Quadrennial Review Issues https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_MIC_Quadrennial_Review_Issues_20250709.pdf
July 7, 2025	Data Submission Window Opening for the 2027/2028 RPM Base Residual Auction (PDF) https://www.monitoringanalytics.com/reports/Market_Messages/IMM_Data_Submission_Window_Opening_2027-2028_RPM_Base_Residual_Auction_20250707.pdf
July 8, 2025	Generation Capacity Resources in PJM Region Subject to RPM Must Offer Obligation for 2026/2027 Delivery Year (PDF) https://www.monitoringanalytics.com/reports/Market_Messages/IMM_Notice_re_RPM_Must_Offer_Obligations_20250708.pdf
July 11, 2025	Executive Summary for the IMM ELCC Proposal https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_ELCCSTF_IMM_Executive_Summary_IMM_Proposal_20250711.pdf
July 15, 2025	IMM Answer re EE PIMV Reports Docket No. EL25-87 https://www.monitoringanalytics.com/filings/2025/IMM_Answer_Docket_No_EL25-87_20250715.pdf
July 25, 2025	IMM Response to PJM ELCC Memo (PDF) https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_ELCCSTF_IMM_Response_20250725.pdf
July 31, 2025	Analysis of the 2025/2026 RPM Base Residual Auction – Part H (PDF) https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20252026_RPM_Base_Residual_Auction_Part_H_20250731.pdf
August 22, 2025	IMM Quadrennial Review Proposal (PDF) https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_MIC_Quadrennial_Review_IMM_Gross_and_Net_CONE_20250822.pdf
September 2, 2025	IMM Comments re Large Load Additions ClFF (PDF) https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_ClFF_Large_Load_Additions_Comments_re_ClFF_scope_20250827.pdf
September 5, 2025	IMM Determinations Posted for the PJM 2027/2028 RPM Base Residual Auction (PDF) https://www.monitoringanalytics.com/reports/Market_Messages/RPM_Material/IMM_Determinations_on_RPM_Requests_2027-2028_Base_Residual_Auction_20250905.pdf
September 8, 2025	IMM Protest re Dairyland Waiver Request Docket No. ER25-3124 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Protest_Waiver_Request_Docket_No_ER25-3124_20250908.pdf
September 10, 2025	IMM Gross and Net CONE Impact of Extended Project Schedule (PDF) https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_MIC_Gross_and_Net_CONE_Impact_of_Extended_Project_Schedule_20250910.pdf
September 24, 2025	IMM Protest re Cordova RPM Must Offer Waiver Request Docket No. ER25-3375 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Protest_Docket_No_ER25-3375_20250924.pdf
September 25, 2025	Quadrennial Review Issues (PDF) https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_MRC_MC_Quadrennial_Review_Issues_20250925.pdf
September 26, 2025	Data Submission Window Opening for the 2026/2027 RPM Third Incremental Auction (PDF) https://www.monitoringanalytics.com/reports/Market_Messages/IMM_Data_Submission_Window_Opening_2026-2027_Third_Incremental_Auction_20250926.pdf

Continued

Date	Name
October 10, 2025	Analysis of the 2026/2027 RPM Base Residual Auction – Part A (PDF) https://www.monitoringanalytics.com/reports/Reports/2025/IMM_Analysis_of_the_20262027_RPM_Base_Residual_Auction_Part_A_20251001.pdf
October 14, 2025	IMM CIFP Large Load Additions Proposal Memo (PDF) https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_CIFP_LLA_Proposal_Memo_20251014.pdf
October 14, 2025	IMM CIFP Large Load Additions (LLA) Proposal Presentation (PDF) https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_CIFP_LLA_Proposal_Presentation_20251014.pdf
October 16, 2025	IMM Answer and Motion for Leave to Answer re Dairyland Power Cooperative Waiver Request Docket No. ER25-3124 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Answer_Docket_No_ER25-3124_20251016.pdf
October 22, 2025	IMM Bowring Testimony re PAPUC Public Hearing HB1834 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_PAPUC_Bowring_Testimony_HB1834_20251022.pdf
October 28, 2025	IMM Comments re Voltus/Mission:data Complaint Docket No. EL26-4 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Comments_Docket_No_EL26-4_20251028.pdf
November 4, 2025	IMM Answer to Answer re PECO-Amazon TSA Docket No. ER25-3492 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Answer_to_Answer_Docket_No_ER25-3492_20251104.pdf
November 5, 2025	M18 Revisions: Issues for DER in RPM Auctions (PDF) https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_MIC_M18_Revisions_DER_in_RPM_Auctions_20251105.pdf
November 10, 2025	IMM Protest re Susquehanna CIR Waiver Docket No. ER26-313 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Comments_Docket_No_ER26-313_20251110.pdf
November 10, 2025	IMM Proposal CIFP Executive Summary (PDF) https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_CIFP_Executive_Summary_20251110.pdf
November 25, 2025	IMM Determinations Posted for the PJM 2026/2027 RPM Third Incremental Auction (PDF) https://www.monitoringanalytics.com/reports/Market_Messages/Messages/IMM_Determinations_on_RPM_Requests-2026-2027_Third_Incremental_Auction_20251125.pdf
November 25, 2025	IMM Comments re Large Load Additions ANOPR Docket No. RM26-4 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Comment_Docket_No_RM26-4_20251125.pdf
November 25, 2025	IMM Complaint re Large Load Additions Docket No. EL26-30 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Complaint_re_Data_Center_Loads_Docket_No_EL26-XX_20251125.pdf
November 26, 2025	IMM Protest, Motion for Leave to Answer and Answer re AEP FRR Waiver Request Docket No. ER26-444 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Comments_Docket_No_ER26-444_20251126.pdf
December 3, 2025	IMM Notice re RPM Must Offer Obligations 20251203.pdf https://www.monitoringanalytics.com/reports/Market_Messages/RPM_Material/IMM_Notice_re_RPM_Must_Offer_Obligations_20251203.pdf
December 3, 2025	Advanced Commitments Design Components https://www.monitoringanalytics.com/reports/Presentations/2025/IMM_MIC_Advanced_Commitments_Design_Components_20251203.pdf
December 5, 2025	IMM Reply Comments re Large Load Additions ANOPR Docket No. RM26-4-000 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Reply_Comments_re_ANOPR_Docket_No_RM26-4_20251205.pdf
December 8, 2025	IMM Protest re Quadrennial Review VRR Curve Docket No. ER26-455 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Protest_re_PJM_205_Docket_No_ER26-455_20251208.pdf
December 19, 2025	IMM Answer to Answers re IMM Large Load Complaint Docket No. EL26-30 (PDF) https://www.monitoringanalytics.com/filings/2025/IMM_Answer_to_Answers_Docket_No_EL26-30_20251219.pdf
January 5, 2026	Analysis of the 2027/2028 RPM Base Residual Auction – Part A (PDF) https://www.monitoringanalytics.com/reports/Reports/2026/IMM_Analysis_of_the_20272028_RPM_Base_Residual_Auction_Part_A_20260105.pdf
January 9, 2026	IMM Comments re Economic Load Response Regulation Only Participants Docket No. ER26-846 (PDF) https://www.monitoringanalytics.com/filings/2026/IMM_Answer_to_Economic_Load_Response_Regulation_Only_Participants_Docket_No_ER26-846_20260109.pdf
January 12, 2026	IMM Answer to PJM re Warrior Run Waiver Request Docket No. ER26-880 (PDF) https://www.monitoringanalytics.com/filings/2026/IMM_Answer_to_PJM_Docket_No_ER26-880_20260112.pdf
January 12, 2026	RMR Matrix Issues: Scope Areas 4, 5 and 6 (PDF) https://www.monitoringanalytics.com/reports/Presentations/2026/IMM_DESTF_RMR_Matrix_Issues_Scope_Areas_4_5_6_20260112.pdf
January 20, 2026	IMM Answer to PJM re Quadrennial Review VRR Curve Docket No. ER26-455 (PDF) https://www.monitoringanalytics.com/filings/2026/IMM_Answer_to_PJM_Answer_Docket_No_ER26-455_20260120.pdf
January 20, 2026	DR Nonperformance Penalties (PDF) https://www.monitoringanalytics.com/reports/Presentations/2026/IMM_MIC_DR_Nonperformance_Penalties_20260120.pdf
January 28, 2026	Supply Uncertainty (PDF) https://www.monitoringanalytics.com/reports/Presentations/2026/IMM_RCSTF_Supply_Uncertainty_20260128.pdf
February 4, 2026	DR Nonperformance Penalty and Performance Adjustment Factor Example (PDF) https://www.monitoringanalytics.com/reports/Presentations/2026/IMM_MIC_Nonperformance_Penalty_and_Performance_Adjustment_Factor_Examples_20260204.pdf
February 5, 2026	IMM Answer to CEG re Co-located Load Docket No. EL25-49, et al (PDF) https://www.monitoringanalytics.com/filings/2026/IMM_Answer_to_CEG_RFC_Docket_No_EL25-49_et_al_20260205.pdf
February 17, 2026	IMM Backstop Auction Design Proposal (PDF) https://www.monitoringanalytics.com/reports/Presentations/2026/IMM_Reliability_Backstop_WS_Backstop_Auction_Design_Proposal_20260217.pdf
February 25, 2026	Reliability Backstop Auction Design Proposal –V2 (PDF) https://www.monitoringanalytics.com/reports/Presentations/2026/IMM_Reliability_Backstop_WS_Backstop_Auction_Design_Proposal-V2_20260224.pdf
March 3, 2026	Analysis of the 2026/2027 RPM Base Residual Auction – Part B (PDF) https://www.monitoringanalytics.com/reports/Reports/2026/IMM_Analysis_of_the_20262027_RPM_Base_Residual_Auction_Part_B_20260303.pdf
March 11, 2026	DR Penalties Matrix Additions (PDF) https://www.monitoringanalytics.com/reports/Presentations/2026/IMM_MIC_DR_penalties_matrix_additions_20260311.pdf
March 20, 2026	IMM Comments re PJM Price Collar Extension Docket No. ER26-1556 (PDF) https://www.monitoringanalytics.com/filings/2026/IMM_Comments_Docket_No_ER26-1556_20260320.pdf
March 25, 2026	IMM Reply Brief re Co-Location Order Paper Hearing Docket No. EL25-49, et al (PDF) https://www.monitoringanalytics.com/filings/2026/IMM_Reply_Brief_Docket_No_EL25-49_et_al_20250325.pdf
April 6, 2026	IMM Answer to Answer re PJM Price Collar Extension Docket No. ER26-1556 (PDF) https://www.monitoringanalytics.com/filings/2026/IMM_Answer_Docket_No_ER26-1556_20260406.pdf
April 22, 2026	IMM Comments on Proposed DR Penalties (PDF) https://www.monitoringanalytics.com/reports/Presentations/2026/IMM_MRC_Comments_on_Proposed_DR_Penalties_20260422.pdf

Market Design

With the earlier introduction of the Capacity Performance model and the recent introduction of the ELCC model, combined with a tightening of the capacity supply and demand balance in ICAP terms, it is clear that PJM's choices about the details of market design have a potentially dominant impact on capacity market outcomes in PJM. The ongoing decision to allow the addition of a significant number of large new data center loads that cannot be served reliably due to inadequate capacity is the most recent and most significant example.

RPM prices are locational by LDA and may vary depending on transmission constraints into LDAs and local supply and demand conditions.⁶⁵ The capacity market is not fully locational. The capacity market locational differences exist only between and among LDAs. The capacity market design assumes that there are no transmission or operational constraints within LDAs and treats all capacity resources within an LDA as perfect substitutes even when they are not. The lack of a fully locational design is a market design flaw that has resulted in the designation of units as RMRs based on internal constraints that were not recognized in the market clearing process. Existing generation that qualifies as a capacity resource must be offered into RPM auctions, except for categorically exempt demand resources, and except for resources in a fixed resource requirement (FRR) plan. All load is required to pay for capacity. Participation by LSEs is mandatory, except for those entities that elect the FRR option. There is an administratively determined demand curve that defines scarcity pricing levels and that, with the supply curve derived from capacity offers, determines market prices in each BRA. There are explicit market power mitigation rules that define structural market power, that define offer caps based on the marginal cost of capacity, and that have flexible criteria for competitive offers by new entrants. Demand resources may be offered directly into RPM auctions but do not have a requirement to be identifiable physical resources, do not have a must offer obligation, do not have a corresponding must offer obligation in the energy market for cleared resources, do not have market seller offer caps, and receive the clearing price.

⁶⁵ Transmission constraints are local capacity import capability limitations (low capacity emergency transfer limit (CETL) margin over capacity emergency transfer objective (CETO)) caused by transmission facility limitations, voltage limitations or stability limitations.

The results of the 2026/2027 RPM Base Residual Auction were significantly affected by flawed market design elements including the lack of a queue for the addition of large new data center loads, by the performance assessment interval (PAI) penalties that are part of the CP design, by PJM's ELCC approach, by the definition of market seller offer caps, by the failure to extend the RPM must offer requirement to demand resources, and by the product definition and lack of market power mitigation for demand resources. The BRA prices do not reflect supply and demand fundamentals but reflect, in significant part, PJM decisions about the definition of supply and demand. PJM filed changes that were approved by FERC and included in the 2026/2027 BRA to adopt two of the MMU's recommendations, the inclusion of specific RMR resources as supply in the next two BRAs and the elimination of the categorical exemption to the RPM must offer requirement, although PJM failed to include elimination of the categorical exemption for demand resources.

The fundamental mistake of the CP design was to attempt to recreate energy market incentives in the capacity market. The CP model was an explicit attempt to bring energy market shortage pricing into the capacity market design. The CP model was designed on the unsupported assumption that shortage prices in the energy market were not high enough and needed to be increased via the capacity market. The CP design focused on a small number of critical hours (performance assessment hours or PAH, translated into five minute intervals as PAI) and imposed large penalties on generators that failed to produce energy only during those hours. The use of capacity market penalties rather than energy market incentives created a new risk. While there are differences of opinion about how to value the risk, this CP risk is not risk that is fundamental to the operation of a wholesale power market. This is risk created by the CP design in order to provide an incentive to produce energy during high demand hours that is even higher than the energy market incentive, amplified by an operating reserve demand curves (ORDC). The risk created by CP is not limited to risk for individual generators, but extends to the viability of the market. If penalties create bankruptcies that threaten the viability of required energy output from the affected units, there is a risk to the market.

The CP PAI incentives are not effective market incentives. PAI incentives are administrative and nonmarket incentives that are not compatible with an effective market design. The energy market clearing, in contrast, is transparent and efficient and timely. While there are issues with the details of energy market pricing that must be addressed, including shortage pricing, the energy market does not include or create the significant and long lasting uncertainty created by the PAI rules as exhibited most dramatically by the results of Winter Storm Elliott. The PAI design creates an administrative process that adds unacceptable uncertainty to the process and that can never approach the effectiveness of the energy market in providing price signals and timely settlement. In addition, the imposition of PAI penalties on intermittent resources when those resources cannot perform is illogical.

The MMU recommends that PJM's application of the ELCC approach be replaced with an ELCC approach that is based on the actual hourly availability of all individual generators for accreditation and for payment. The MMU recommends short term modifications to PJM's approach to include hourly data that would permit unit specific ELCC ratings, to weight summer and winter risk in a more balanced manner, to eliminate PAI risks, and to pay for actual hourly performance rather than based on inflexible class capacity accreditation ratings derived from a small number of nonrepresentative hours of poor performance from PV1 and WSE. In the short run capacity accreditation should eliminate the performance during PV1 and WSE and should recognize the winter capability of thermal resources rather than limiting such resources to summer ratings. Most of the risk recognized in the ELCC model is winter risk but the ELCC accreditation values for thermal resources are capped at the summer ratings. That unnecessarily limits supply and changes the ELCC values for all other resources and changes the system accredited unforced capacity and therefore AUCAP, the maximum level of load that can be served by the existing resources and therefore the reliability requirement. The CIRs of such resources are currently limited by the summer ratings but those rules can and should be changed given the use of the ELCC approach. There is no reason that excess winter CIRs cannot be assigned to these resources immediately.

The initial VRR curve, introduced in 2007, had a maximum price equal to 1.5 times the Net Cost of New Entry (Net CONE), determined annually based on the fixed cost of new generating capacity, or Gross Cost of New Entry (Gross CONE), net of the three year average energy and ancillary service revenues. That VRR curve was structured to yield auction clearing prices equal to the 1.5 times Net CONE when the amount of capacity cleared was less than 99 percent of the target reserve margin, and below 1.5 times Net CONE when the amount of capacity cleared was greater than 99 percent of the target reserve margin. The use of Net CONE was based on the logic of the capacity market, to ensure that the cost of entry was covered between the energy and capacity markets. Net CONE was the missing money that needed to be recoverable in the capacity market. Net CONE was the equilibrating factor between the capacity market and energy market. The use of Gross CONE is inconsistent with that basic capacity market logic. Gross CONE was introduced as the maximum price based on concerns that Net CONE would be too low. The maximum point on the VRR curve for the 2025/2026 BRA was the higher of Gross CONE or 1.5 times Net CONE and Gross CONE was used. For the first time since the introduction of the RPM capacity market design, the 2026/2027 BRA used a VRR curve with both a defined maximum price and a defined minimum price.⁶⁶ However, if the logic of the markets implies a low Net CONE, that is the right answer. There is nothing inherently wrong with a low Net CONE that requires abandoning the basic capacity market logic. The use of Gross CONE rather than 1.5 times Net CONE was an intervention designed to increase capacity market prices despite the fact that the basic economic logic did not support that increase. If there is an issue with the calculation of Net CONE, it should be addressed directly rather than by ignoring its central role in the design of the capacity market. As Gross CONE numbers are reasonably well defined, much more focus on the correct calculation of the net revenues used in the forward auctions is required in order to ensure that market participants have confidence in the Net CONE values used in the auctions.

PJM ended the long standing categorical exemption of intermittent resources, capacity storage resources, and hybrid resources from the RPM must offer requirement. Consistent with the MMU's recommendations, that exemption

⁶⁶ On April 21, 2025, FERC issued an order accepting PJM's proposal to establish a temporary capacity market price cap and floor for the 2026/2027 and 2027/2028 Delivery Years. 191 FERC ¶ 61,066 (April 21, 2025).

was eliminated for all but demand resources. There is no reason to continue to exempt demand resources from the RPM must offer requirement. The same rules should apply to all capacity resources. The purpose of the RPM must offer rule, which has been in place since the beginning of the capacity market in 1999, is to ensure that the capacity market works, and therefore that the energy market works, based on the inclusion of all demand and all supply, to ensure competitive entry, to ensure open access to the transmission system, and to prevent the exercise of market power via withholding of capacity supply.

For these reasons, existing resources are required to return CIRs to the market within one year after retirement. The MMU recommends that resources return CIRs to the market on the day of retirement.⁶⁷

Consistent with the must offer obligation, performance penalties should not be applied to solar and wind resources when they are not capable of performing based on ambient conditions. For example, solar resources should be subject to performance penalties if they fail to perform when the sun is shining but should not be subject to performance penalties in the middle of the night. That would be the result under the incentive approach recommended by the MMU. If PAI is retained, this would be a rational application of the PAI penalties that recognizes the physical capabilities of resources and is therefore not discriminatory.

Demand resources (DR) have always been treated more favorably than generation capacity resources. Demand resources do not have an RPM must offer requirement. Demand resources, unlike all other capacity resources, are not subject to market seller offer caps to protect against the exercise of market power in the capacity market. When demand resources are pivotal, as they were for the 2026/2027 BRA, they have structural market power and can and do exercise market power. That conclusion does not depend on whether withholding directly benefits those resources through a portfolio effect. The result of the failure to offer can be a significant increase in the market price of capacity above the competitive level when that supply is pivotal. If the

⁶⁷ See Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM, Docket No. ER25-2162-000 (May 28, 2025); Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM, Docket No. ER25-2190-000 (May 28, 2025); and Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM, Docket No. ER25-2197-000 (May 28, 2025).

resources clear, it benefits the resources directly. Even if the resources do not clear, higher prices can benefit the owners of capacity portfolios that include such resources as well as resources with an RPM must offer requirement. The MMU recommends that demand resources have defined and enforced market seller offer caps in the capacity market, like all other capacity resources.

PJM filed tariff changes that transfer risk caused by the volatile ELCC ratings from generation owners to the load. ELCC ratings may increase or decrease significantly between the time a generator clears in the RPM Base Residual Auction and the final ELCC rating just prior to the start of the delivery year. Under the new tariff rules, generators will be excused from paying the Capacity Resource Deficiency Charge for a deficiency caused by a decrease in the final ELCC rating. Under the prior rules, a Capacity Market Seller was required to cover its short position by acquiring additional capacity or pay a deficiency penalty equal to 20 percent of the base residual auction clearing price for each MW of shortage. The tariff change was filed by PJM on April 18, 2025, and approved by FERC on June 17, 2025.^{68 69} The MMU opposed the change because the new rule does not mitigate the risk as asserted by PJM but simply transfers the ELCC rating volatility risk to the load.⁷⁰ The change is inconsistent with basic market logic under which investors bear the risk associated with the ownership of generation.

Installed Capacity

On January 1, 2026, RPM installed capacity was 184,220.8 MW (Table 5-3).⁷¹ Over the next three months, new generation, unit deactivations, facility reratings, plus import and export shifts resulted in RPM installed capacity of 184,190.8 MW on March 31, 2026, a decrease of 30.0 MW or 0.0 percent from the January 1 level.^{72 73} The 30.0 MW decrease was the net result of new or

⁶⁸ *Proposal to Mitigate Impacts From Updates to ELCC Accreditation between the Base Residual Auction and the Final ELCC Accreditation Values*, PJM Interconnection LLC, Docket ER25-2002 (April 18, 2025).

⁶⁹ 191 FERC ¶ 61,203 (June 17, 2025).

⁷⁰ See *Comments of the Independent Market Monitor for PJM* (May 9, 2025), *Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM* (June 9, 2025), *Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM* (June 16, 2025), Docket ER25-2002-000.

⁷¹ Percent values shown in Table 5-3 are based on unrounded, underlying data and may differ from calculations based on the rounded values in the tables.

⁷² Unless otherwise specified, the capacity described in this section is the summer installed capacity rating of all PJM generation capacity resources, as entered into the Capacity Exchange system, regardless of whether the capacity cleared in the RPM auctions.

⁷³ Wind resources accounted for 4,370.6 MW, and solar resources accounted for 8,559.8 MW of installed capacity in PJM on March 31, 2026. Prior to the 2023/2024 Delivery Year, PJM administratively reduced the capabilities of all wind generators to 14.7 percent for wind farms in mountainous terrain and 17.6 percent for wind farms in open terrain, and solar generators to 42.0 percent for ground mounted

reactivated generation (253.9 MW) and net capacity modifications (6.0 MW), offset by an increase in exports (0.2), derates (258.1 MW), and deactivations or changes in capacity resource status (31.6 MW).

At the beginning of the new delivery year on June 1, 2025, RPM installed capacity was 181,221.6 MW, an increase of 4,056.0 MW or 2.3 percent from the May 31, 2025, level of 177,165.6 MW. This change occurred as a result of deactivations, derates, capacity modifications, and import/export contracts beginning and/or ending at the start of the new delivery year.

Table 5-3 Installed capacity (By fuel source): January 1, January 31, February 28, and March 31, 2026^{74 75}

	01-Jan-26		31-Jan-26		28-Feb-26		31-Mar-26	
	MW	Percent	MW	Percent	MW	Percent	MW	Percent
Battery	24.0	0.0%	24.0	0.0%	35.7	0.0%	35.7	0.0%
Coal	37,544.6	20.4%	37,544.6	20.4%	37,395.0	20.3%	37,394.8	20.3%
Gas	88,888.4	48.3%	88,888.4	48.2%	88,813.0	48.2%	88,812.9	48.2%
Hybrid	10.2	0.0%	10.2	0.0%	10.2	0.0%	10.2	0.0%
Hydroelectric	8,215.2	4.5%	8,215.2	4.5%	8,168.1	4.4%	8,168.1	4.4%
Nuclear	32,176.2	17.5%	32,176.2	17.5%	32,163.6	17.5%	32,163.6	17.5%
Oil	4,066.5	2.2%	4,066.5	2.2%	4,065.7	2.2%	4,065.7	2.2%
Solar	8,315.7	4.5%	8,409.9	4.6%	8,559.8	4.6%	8,559.8	4.6%
Solid waste	609.4	0.3%	609.4	0.3%	609.4	0.3%	609.4	0.3%
Wind	4,370.6	2.4%	4,370.6	2.4%	4,370.6	2.4%	4,370.6	2.4%
Total	184,220.8	100.0%	184,315.0	100.0%	184,191.1	100.0%	184,190.8	100.0%

Figure 5-1 shows the share of installed capacity by fuel source for the first day of each delivery year, from June 1, 2007, to June 1, 2025, as well as the expected installed capacity for the 2026/2027 and 2027/2028 Delivery Years. On June 1, 2007, coal comprised 40.7 percent of the installed capacity, reached a maximum of 42.9 percent in 2012, decreased to 20.71 percent on June 1, 2025, and is projected to decrease to 17.0 percent on June 1, 2027. The

fixed panel, 60.0 percent for ground mounted tracking panel, and 38.0 percent for other than ground mounted solar arrays, of nameplate capacity when determining the installed capacity because wind and solar resources cannot be assumed to be available on peak and cannot respond to dispatch requests. As data became available, unforced capability of wind and solar resources was to be calculated using actual data. There are additional wind and solar resources not reflected in total capacity because they are energy only resources and do not participate in the PJM Capacity Market. See "PJM Manual 21B: PJM Rules and Procedures for Determination of Generating Capability," § 4 Calculations of ELCC Class Rating, ELCC Resource Performance Adjustment, Accredited UCAP, and Accredited UCAP Factor, Rev. 05 (Jan. 22, 2026). The derating approach has been replaced with ELCC starting in the 2023/2024 Delivery Year.

⁷⁴ The data for hybrid solar/battery resources are included in the solar data for confidentiality reasons.

⁷⁵ Installed capacity is based on imports, exports, and PJM's capacity modification ("capmod") database that tracks new and reactivated generation, unit uprates and derates, and deactivations/changes to capacity resource status. Demand Resources are not tracked in this way and are not included here. For analysis of Demand Resources in the capacity market, see the Demand Resources discussion later in this section.

share of gas increased from 29.1 percent on June 1, 2007, reached a maximum of 50.2 percent in 2024, decreased to 49.0 percent on June 1, 2025, and is projected to increase to 49.1 on June 1, 2027.

Figure 5-1 Percent of installed capacity (By fuel source): June 1, 2007 through June 1, 2027⁷⁶




Table 5-4 shows the RPM installed capacity on January 1, 2026, through March 31, 2026, for the top five generation capacity resource owners, excluding FRR committed MW. Dominion Resources, Inc. was an FRR entity for the 2022/2023 through 2024/2025 Delivery Years and shifted their participation from FRR to RPM with the 2025/2026 Delivery Year.

⁷⁶ Prior to June 1, 2025, PJM set ICAP equal to UCAP for solar and wind units. Starting June 1, 2025, PJM began setting ICAP equal to CIRs for solar and wind units.

Table 5-4 Installed capacity by parent company: January 1, January 31, February 28, and March 31, 2026

Parent Company	01-Jan-26			31-Jan-26			28-Feb-26			31-Mar-26		
	ICAP (MW)	Percent of Total ICAP	Rank	ICAP (MW)	Percent of Total ICAP	Rank	ICAP (MW)	Percent of Total ICAP	Rank	ICAP (MW)	Percent of Total ICAP	Rank
Dominion Resources, Inc.	21,947.0	12.8%	1	21,947.0	12.8%	2	21,959.4	12.9%	2	21,959.4	12.9%	2
Constellation Energy Generation, LLC	20,279.1	11.9%	2	24,446.8	14.3%	1	24,385.2	14.3%	1	24,385.2	14.3%	1
Vistra Energy Corp.	13,929.1	8.2%	3	13,929.1	8.1%	3	13,929.1	8.2%	3	13,928.4	8.2%	3
Talen Energy Corporation	12,673.1	7.4%	4	12,673.1	7.4%	4	12,669.2	7.4%	4	12,665.9	7.4%	4
LS Power Equity Partners, L.P.	10,667.9	6.2%	5	4,461.3	2.6%	8	4,451.4	2.6%	8	4,451.4	2.6%	8
NRG Energy, Inc.	1,949.0	1.1%	21	8,155.6	4.8%	5	8,155.6	4.8%	5	8,155.6	4.8%	5

The sources of funding for generation owners can be categorized as one of two types: market and nonmarket. Market funding is from private investors bearing the investment risk without guarantees or support from any public sources, subsidies or guaranteed payment by ratepayers. Providers of market funding rely entirely on market revenues. Nonmarket funding is from guaranteed revenues, including cost of service rates for a regulated utility and subsidies. Table 5-5 shows the RPM installed capacity on January 1, 2026, to March 31, 2026, by funding type.

Table 5-5 Installed capacity by funding type: January 1, January 31, February 28, and March 31, 2026

Funding Type	01-Jan-26		31-Jan-26		28-Feb-26		31-Mar-26	
	ICAP (MW)	Percent of Total ICAP	ICAP (MW)	Percent of Total ICAP	ICAP (MW)	Percent of Total ICAP	ICAP (MW)	Percent of Total ICAP
Market	133,490.8	72.5%	133,585.0	72.5%	133,620.1	72.5%	132,347.7	71.9%
Nonmarket	50,730.0	27.5%	50,730.0	27.5%	50,571.0	27.5%	51,843.1	28.1%
Total	184,220.8	100.0%	184,315.0	100.0%	184,191.1	100.0%	184,190.8	100.0%

Fuel Diversity

Figure 5-2 shows the fuel diversity index (FDI_c) for RPM installed capacity.⁷⁷ The FDI_c is defined as $\frac{1}{n} \sum_{i=1}^n s_i^2$, where s_i is the percent share of fuel type i . The minimum possible value for the FDI_c is zero, corresponding to all capacity from a single fuel type. The maximum possible value for the FDI_c is achieved when each fuel type has an equal share of capacity. For a capacity mix of eight fuel

⁷⁷ The MMU developed the FDI to provide an objective metric of fuel diversity. The FDI metric is similar to the HHI used to measure market concentration. The FDI is calculated separately for energy output and for installed capacity. The FDI_c includes derated capacity values for intermittent capacity subject to derating.

types, the maximum achievable index is 0.875. The fuel type categories used in the calculation of the FDI_c are in Table 5-3. FDI_c calculations prior to June 1, 2023 included eight fuel types. Batteries were added to the resource mix on June 1, 2023, and hybrid solar resources were added on January 1, 2024. The maximum achievable index with nine fuel types is 0.889. The maximum achievable index with ten fuel types is 0.900. The FDI_c is stable and does not exhibit any long-term trends. The only significant deviation occurred with the expansion of the PJM footprint. On April 1, 2002, PJM expanded with the addition of Allegheny Power System, which added about 12,000 MW of generation.⁷⁸ The reduction in the FDI_c resulted from an increase in coal capacity resources. A similar but more significant reduction occurred in 2004 with the expansion into the COMED, AEP, and DAY Control Zones.⁷⁹ The FDI_c on March 31, 2026 increased 2.3 percent in comparison with the FDI_c on March 31, 2025. Figure 5-2 also includes the expected FDI_c through March 31, 2027. The expected FDI_c is indicated in Figure 5-2 by the dotted orange line.

The FDI_c is used to measure the impact on fuel diversity of potential retirements in 2026 through 2030. A total of 10,963 MW of capacity are at risk of retirement, consisting of 8,330 MW currently planning to retire and 2,633 MW expected to be uneconomic.⁸⁰ The dotted green line in Figure 5-2 shows the FDI_c assuming that the capacity from the expected 2026 retirements


⁷⁸ On April 1, 2002, the PJM Region expanded with the addition of Allegheny Power System under a set of agreements known as "PJM-West." See page 4 in the 2002 *Annual State of the Market Report for PJM* for additional details.

⁷⁹ See the 2019 *Annual State of the Market Report for PJM*, Volume 2, Appendix A, "PJM Geography" for an explanation of the expansion of the PJM footprint. The integration of the COMED Control Area occurred in May 2004 and the integration of the AEP and DAY Control Zones occurred in October 2004.

⁸⁰ See the 2025 *Annual State of the Market Report for PJM*, Volume 2, Section 7: Net Revenue.

were replaced by gas fired capacity.⁸¹ The counterfactual FDI_c on March 31, 2027 under these assumptions is 0.9 percent lower than the expected FDI_c on March 31, 2027. The dotted blue line in Figure 5-2 shows the FDI_c assuming that the capacity from the expected retirements through 2030 were replaced by wind and solar capacity.⁸² The counterfactual FDI_c on March 31, 2027 in this scenario is 2.3 percent higher.

Figure 5-2 Fuel Diversity Index for installed capacity: January 1, 2002 through March 31, 2027



81 It is assumed that all of the replacement capacity is from gas units. In previous reports, solar and wind capacity have also been used for replacement capacity with the amounts based on the expected increase in the PJM RPS obligation for the upcoming year. But the PJM RPS obligation will decrease in 2027 in comparison to 2026 due to the termination of the Ohio RPS in 2027.

82 The split between solar (80.6 percent) and wind (19.4 percent) is based on queue data. In previous reports, the replacement capacity included gas units in addition to solar and wind with the amount of solar and gas replacement capacity being based on the expected increase in the PJM RPS obligation in 2030 in comparison to current year. But the RPS increase for 2030 exceeds the expected retirements and only solar and wind are used for replacement capacity in this scenario.

RPM Capacity Market

The RPM Capacity Market, implemented June 1, 2007, is a three year forward looking, annual, locational market, with a must offer requirement for existing generation capacity resources, except for demand response resources, and except for resources owned by entities that elect the fixed resource requirement (FRR) option, and mandatory participation by load, with performance incentives, that includes clear market power mitigation rules and that permits the direct participation of demand side resources.

The standard schedule is that annual base residual auctions are held in May for delivery years that are three years in the future. Effective January 31, 2010, First, Second, and Third Incremental Auctions are conducted 20, 10, and three months prior to the delivery year.⁸³ In the first three months of 2026, the 2026/2027 RPM Third Incremental Auction was conducted. The auction schedule has diverged significantly from the standard schedule in recent years.

Market Structure

Supply

Table 5-6 shows generation capacity changes since the implementation of the Reliability Pricing Model through the 2024/2025 Delivery Year. The 13,506.2 MW increase was the result of new generation capacity resources (46,491.1 MW), reactivated generation capacity resources (1,380.4 MW), uprates (9,746.8 MW), integration of external zones (21,967.5 MW), a net decrease in capacity exports (538.9 MW), offset by a net decrease in capacity imports (1,513.1 MW), deactivations (58,847.3 MW) and derates (6,258.1 MW).

Table 5-7 shows the calculated RPM reserve margin and reserve in excess of, or short of, the target installed reserve margin (IRM) for June 1, 2022, through June 1, 2027, and accounts for cleared capacity, replacement capacity, and deficiency MW for all auctions held and the most recent peak load forecast for each delivery year. The completion of the replacement process using cleared buy bids from RPM incremental auctions includes two transactions. The first

83 See Letter Order, Docket No. ER10-366-000 (January 22, 2010).

step is for the entity to submit and clear a buy bid in an RPM incremental auction. The next step is for the entity to complete a separate replacement transaction using the cleared buy bid capacity. Prior to the 2025/2026 Delivery Year, replacement capacity transactions can be completed only after the EFORds for the delivery year are finalized, on November 30 in the year prior to the delivery year, but before the start of the delivery day. Effective with the 2025/2026 Delivery Year, replacement capacity transactions can be completed only after the accredited UCAP factors for the delivery year are finalized, but before the start of the delivery day. Early replacement transactions can be approved for defined physical replacements.

Changes in Generation Capacity⁸⁴

As shown in Table 5-6, for the period from the introduction of the RPM capacity market design in the 2007/2008 Delivery Year through the 2024/2025 Delivery Year, internal installed capacity decreased by 7,487.1 MW after accounting for new capacity resources, reactivations, and uprates (57,618.3 MW) and capacity deactivations and derates (65,105.4 MW).⁸⁵

For the 2025/2026 Delivery Year, new generation capacity is defined as capacity that cleared an RPM auction for the first time for the specified delivery year. Based on expected completion rates of cleared new generation capacity (6,089.7 MW) and pending deactivations (1,132.5 MW), PJM capacity is expected to increase by 4,957.2 MW through the 2026/2027 Delivery Year.

Table 5-6 Generation capacity changes: 2007/2008 through 2024/2025⁸⁶

	ICAP (MW)									
	New	Reactivations	Uprates	Integration	Net Change in Capacity Imports	Net Change in Capacity Exports	Deactivations	Derates	Net Change	
2007/2008	45.0	0.0	691.5	0.0	70.0	15.3	380.0	417.0	(5.8)	
2008/2009	815.4	238.3	987.0	0.0	473.0	(9.9)	609.5	421.0	1,493.1	
2009/2010	406.5	0.0	789.0	0.0	229.0	(1,402.2)	108.4	464.3	2,254.0	
2010/2011	153.4	13.0	339.6	0.0	137.0	367.7	840.6	223.5	(788.8)	
2011/2012	3,096.4	354.5	507.9	16,889.5	(1,183.3)	(1,690.3)	2,542.0	176.2	18,637.1	
2012/2013	1,784.6	34.0	528.1	47.0	342.4	84.0	5,536.0	317.8	(3,201.7)	
2013/2014	198.4	58.0	372.8	2,746.0	934.3	28.9	2,786.9	288.3	1,205.4	
2014/2015	2,276.8	20.7	530.2	0.0	2,335.7	177.3	4,915.6	360.3	(289.8)	
2015/2016	4,291.8	90.0	449.0	0.0	511.4	(117.8)	8,338.2	215.8	(3,094.0)	
2016/2017	3,679.3	532.0	419.2	0.0	575.6	722.9	659.4	206.7	3,617.1	
2017/2018	4,127.3	5.0	562.1	0.0	(1,025.1)	(695.1)	2,657.4	148.5	1,558.5	
2018/2019	8,127.5	4.0	330.9	2,120.0	(3,217.0)	212.7	6,730.0	89.2	333.5	
2019/2020	4,612.0	13.3	494.9	165.0	(1,196.6)	401.3	3,296.0	116.8	274.5	
2020/2021	403.1	11.6	575.4	0.0	(37.9)	(111.6)	3,572.0	206.4	(2,714.6)	
2021/2022	3,309.3	6.0	412.2	0.0	38.5	1,066.1	2,197.6	125.5	376.8	
2022/2023	4,743.2	0.0	417.0	0.0	(469.3)	(868.0)	7,460.5	302.0	(2,203.6)	
2023/2024	2,696.8	0.0	420.5	0.0	(47.9)	1,067.8	5,149.2	1,441.1	(4,588.7)	
2024/2025	1,724.3	0.0	919.5	0.0	17.1	212.0	1,068.0	737.7	643.2	
Total	46,491.1	1,380.4	9,746.8	21,967.5	(1,513.1)	(538.9)	58,847.3	6,258.1	13,506.2	

⁸⁴ For more details on future changes in generation capacity, see "2020 PJM Generation Capacity and Funding Sources 2007/2008 through 2021/2022 Delivery Years," <http://www.monitoringanalytics.com/reports/Reports/2020/IMM_2020_PJM_Generation_Capacity_and_Funding_Sources_20072008_through_20212022_DY_20200915.pdf> (September 15, 2020).

⁸⁵ These results are for internal capacity only and do not include, for example, imports or exports or the impact of integrations of new areas.

⁸⁶ The capacity changes in this report are calculated based on June 1 through May 31.

As shown in Table 5-7, total reserves on June 1, 2025, were 19,999.9 MW, which is 205.1 MW (UCAP) short of the required reserve level of 20,205.0 MW (UCAP). In the 2026/2027 BRA, total reserves were 21,353.2 MW, which is 208.7 MW (UCAP) short of the required reserve level of 21,561.9 MW (UCAP). In the 2027/2028 BRA, total reserves were 16,977.4 MW, which is 6,516.6 MW (UCAP) short of the required reserve level of 23,494.0 MW (UCAP). The level of committed demand resources was 5,530.6 MW in the 2026/2027 BRA and 7,298.6 in the 2027/2028 BRA, meaning the PJM markets will rely on demand resources as part of the required reserve margin, rather than as excess above the required reserve margin.

The fact that more than one quarter (25.6 percent of total reserves in the 2026/2027 BRA and 31.1 percent of total reserves in the 2027/2028 BRA) of the PJM reserves depend on demand resources that are not subject to the RPM must offer requirement, a core part of the capacity market design, means that reliability is significantly less certain than the stated reserve margins indicate.

Table 5-7 RPM reserve margin: June 1, 2023, to June 1, 2027^{87 88}

	01-Jun-23	01-Jun-24	01-Jun-25	01-Jun-26	01-Jun-27	
Forecast peak load ICAP (MW)	149,382.2	151,631.1	154,534.1	156,760.6	164,579.0	A
FRR peak load ICAP (MW)	29,554.6	30,431.0	11,720.3	11,668.7	12,201.9	B
PRD ICAP (MW)	235.0	305.0	224.0	115.0	115.0	C
Installed reserve margin (IRM)	14.9%	17.7%	17.8%	18.6%	20.0%	D
Pool wide average EFORD	4.87%	5.10%				E
Pool wide accredited UCAP factor			79.63%	78.34%	77.17%	F
Forecast pool requirement (FPR)	1.093	1.117	0.938	0.929	0.926	$G=(1+D)*(1-E)$ or $G=(1+D)*F$
RPM committed less deficiency UCAP (MW) (generation and DR)	136,401.8	138,318.6	133,544.1	136,511.6	134,478.1	H
RPM committed less deficiency ICAP (MW) (generation and DR)	143,384.6	145,751.9	167,705.8	174,255.3	174,262.1	$J=H/(1-E)$ or $J=H/F$
RPM peak load ICAP (MW)	119,592.6	120,895.1	142,589.7	144,976.9	152,262.1	$K=A-B-C$
Reserve margin ICAP (MW)	23,792.0	24,856.9	25,116.0	29,278.4	22,000.0	$L=J-K$
Reserve margin (%)	19.9%	20.6%	17.6%	20.2%	14.4%	$M=L/K$
Reserve margin in excess of IRM ICAP (MW)	5,972.7	3,458.4	(264.9)	2,312.7	(8,452.4)	$N=L-D*K$
Reserve margin in excess of IRM (%)	5.0%	2.9%	(0.2%)	1.6%	(5.6%)	$P=N/K$
RPM peak load UCAP (MW)	113,768.4	114,729.4	113,544.2	113,574.9	117,500.7	$Q=K*(1-E)$ or $Q=K*F$
RPM reliability requirement UCAP (MW)	130,714.7	135,039.8	133,749.2	134,698.0	140,994.7	$R=K*G$
Reserve margin UCAP (MW)	22,633.4	23,589.2	19,999.9	22,936.7	16,977.4	$S=H-Q$
Reserve cleared in excess of IRM UCAP (MW)	5,687.1	3,278.8	(205.1)	1,813.6	(6,516.6)	$T=H-R$
Projected replacement capacity UCAP (MW)	0.0	0.0	0.0	1,852.1	0.0	U
Projected reserve margin	19.9%	20.6%	17.6%	18.6%	14.4%	$V=(J-U)/(1-E)/K-1$ or $V=(J-U/F)/K-1$

Sources of Funding⁸⁹

Developers use a variety of sources to fund their projects, including Power Purchase Agreements (PPA), cost of service rates, and private funds (from internal sources or private lenders and investors). PPAs can be used for a variety of purposes and the use of a PPA does not imply a specific source of funding.

⁸⁷ The calculated reserve margins in this table do not include EE on the supply side or the EE addback on the demand side. The EE excluded from the supply side for this calculation includes annual EE and summer EE. This is how PJM calculates the reserve margin. Effective with the 2026/2027 Deliver Year, EE resources no longer participate in the PJM capacity market. See 189 FERC ¶ 61,095 (November 5, 2024).

⁸⁸ These reserve margin calculations do not consider Fixed Resource Requirement (FRR) load.

⁸⁹ For more details on sources of funding for generation capacity, see "2020 PJM Generation Capacity and Funding Sources 2007/2008 through 2021/2022 Delivery Years," <http://www.monitoringanalytics.com/reports/Reports/2020/IMM_2020_PJM_Generation_Capacity_and_Funding_Sources_2007/2008_through_2021/2022_DY_20200915.pdf> (September 15, 2020).

New and reactivated generation capacity from the 2007/2008 Delivery Year through the 2024/2025 Delivery Year (Table 5-8) totaled 47,871.5 MW (83.1 percent of all additions), with 36,670.1 MW from market funding and 11,201.4 MW from nonmarket funding. Uprates to existing generation capacity from the 2007/2008 Delivery Year through the 2024/2025 Delivery Year totaled 9,746.8 MW (16.9 percent of all additions), with 6,983.7 MW from market funding and 2,763.1 MW from nonmarket funding. In summary, of the 57,618.3 MW of additional capacity from new, reactivated, and uprated generation that cleared in RPM auctions for the 2007/2008 through 2024/2025 Delivery Years, 43,653.8 MW (76.0 percent) were based on market funding.

Table 5-8 Sources of funding: 2007/2008 through 2024/2025 Delivery Years

ICAP MW						
2007/2008 DY through 2024/2025 DY	New and Reactivated	Percent of Grand Total	Uprate	Percent of Grand Total	Total	Percent of Grand Total
Market	36,670.1	63.6%	6,983.7	12.1%	43,653.8	75.8%
Nonmarket	11,201.4	19.4%	2,763.1	4.8%	13,964.5	24.2%
Total	47,871.5	83.1%	9,746.8	16.9%	57,618.3	100.0%

Of the 21,915.0 MW of the additional generation capacity (new resources, reactivated resources, and uprates) that cleared in RPM auctions for the 2025/2026 through the 2027/2028 Delivery Years (Table 5-9), 7,587.0 MW are not yet in service, with 7,380.9 MW of those having market funding. Applying the historical completion rates, 63.9 percent of all the projects in development are expected to go into service, 4,710.1 MW of the 7,380.9 MW in development market funded projects, and 134.3 MW of the 206.1 MW in development non market funded projects.⁹⁰

Of the 14,328.0 MW of the additional generation capacity that cleared in RPM auctions for the 2025/2026 through the 2027/2028 Delivery Years and are already in service, 10,510.8 MW (73.4 percent) are based on market funding and 3,817.2 MW (26.6 percent) are based on nonmarket funding.

In summary, 17,891.7 MW (81.6 percent) of the additional generation capacity (7,380.9 MW not yet in service and 10,510.8 MW in service) that cleared in RPM auctions for the 2025/2026 through the 2027/2028 Delivery Years are

⁹⁰ See the 2025 Annual State of the Market Report for PJM, Volume 2, Section 12: Generation and Transmission Planning.

based on market funding. Capacity additions based on nonmarket funding are 4,023.3 MW (18.4 percent) of generation that cleared the RPM auctions for the 2025/2026 and 2027/2028 Delivery Years.

Table 5-9 Sources of funding: 2025/2026 through 2027/2028 Delivery Years

ICAP MW								
2025/2026 DY through 2027/2028 DY	Not Yet in Service	Percent of Grand Total	Percent of Grand Total	In Service	Percent of Grand Total	Percent of Grand Total	Total	Percent of Grand Total
Market	7,380.9	97.3%	33.7%	10,510.8	73.4%	48.0%	17,891.7	81.6%
Nonmarket	206.1	2.7%	0.9%	3,817.2	26.6%	17.4%	4,023.3	18.4%
Total	7,587.0	100.0%	34.6%	14,328.0	100.0%	65.4%	21,915.0	100.0%

Demand

The MMU analyzed market sectors in the PJM Capacity Market to determine how they met their load obligations. The PJM Capacity Market was divided into the following sectors:

- **PJM EDC.** EDCs with a franchise service territory within the PJM footprint. This sector includes traditional utilities, electric cooperatives, municipalities and power agencies.
- **PJM EDC Generating Affiliate.** Affiliate companies of PJM EDCs that own generating resources.
- **PJM EDC Marketing Affiliate.** Affiliate companies of PJM EDCs that sell power and have load obligations in PJM, but do not own generating resources.
- **Non-PJM EDC.** EDCs with franchise service territories outside the PJM footprint.
- **Non-PJM EDC Generating Affiliate.** Affiliate companies of non-PJM EDCs that own generating resources.
- **Non-PJM EDC Marketing Affiliate.** Affiliate companies of non-PJM EDCs that sell power and have load obligations in PJM, but do not own generating resources.
- **Non-EDC Generating Affiliate.** Affiliate companies of non-EDCs that own generating resources.

- **Non-EDC Marketing Affiliate.** Affiliate companies of non-EDCs that sell power and have load obligations in PJM, but do not own generating resources.


On June 1, 2025, PJM EDCs and their affiliates maintained a majority market share of load obligations under RPM, together totaling 57.8 percent (Table 5-10), up from 56.4 percent on June 1, 2024. The combined market share of LSEs not affiliated with any EDC and of non-PJM EDC affiliates was 42.2 percent, down from 43.6 percent on June 1, 2024. The share of capacity market load obligation fulfilled by PJM EDCs and their affiliates, and LSEs not affiliated with any EDC and non-PJM EDC affiliates from June 1, 2007, to June 1, 2025, is shown in Figure 5-3. PJM EDCs’ and their affiliates’ share of load obligation has decreased from 77.5 percent on June 1, 2007, to 57.8 percent on June 1, 2025. The share of load obligation held by LSEs not affiliated with any EDC and non-PJM EDC affiliates increased from 22.5 percent on June 1, 2007, to 42.2 percent on June 1, 2025.⁹¹

Table 5-10 Capacity market load obligation served: June 1, 2024 and June 1, 2025

	01-Jun-24		01-Jun-25		Change	
	Obligation (MW)	Percent of total obligation	Obligation (MW)	Percent of total obligation	Obligation (MW)	Percent of total obligation
PJM EDCs and Affiliates	106,462.1	56.4%	86,471.6	57.8%	(19,990.5)	1.4%
LSEs not affiliated with any EDC + non EDC Affiliates	82,180.1	43.6%	63,166.5	42.2%	(19,013.6)	(1.4%)
Total	188,642.2	100.0%	149,638.1	100.0%	(39,004.1)	0.0%

⁹¹ Prior to the 2012/2013 Delivery Year, obligation was defined as cleared and make whole MW in the Base Residual Auction and the Second Incremental Auction plus ILR forecast obligations. Effective with the 2012/2013 Delivery Year, obligation is defined as the sum of the unforced capacity obligations satisfied through all RPM auctions for the delivery year.

Figure 5-3 Capacity market load obligation served: June 1, 2007 through June 1, 2025



Capacity Transfer Rights (CTRs)

Capacity Transfer Rights (CTRs) are used to return capacity market congestion revenues to load. Load pays congestion. Capacity market congestion revenues are the difference between the total dollars paid by load for capacity and the total dollars received by capacity market sellers. The MW of CTRs available for allocation to LSEs in an LDA are equal to the Unforced Capacity imported into the LDA, less any MW of CETL paid for directly by market participants in the form of Qualifying Transmission Upgrades (QTUs) cleared in an RPM Auction, and Incremental Capacity Transfer Rights (ICTRs). There are two types of ICTRs, those allocated to a New Service Customer obligated to fund a transmission facility or upgrade and those associated with Incremental Rights-Eligible Required Transmission Enhancements.

The total required capacity in an LDA is provided by a mix of internal capacity and imported capacity. The imported capacity equals the total required capacity minus the internal capacity. The value of CTRs is based on the fact that load in an LDA pays the clearing price for all cleared capacity but that generators who provide imported capacity are paid a lower price based on the LDA in which they are located. The value of CTRs equals the imported MW times the price difference. This excess is paid by load and is returned to load using CTRs. CTRs are intended to permit customers to receive the benefit of importing cheaper capacity using transmission capability.

But PJM does not use the actual MW cleared in the BRA and three incremental auctions, the actual internal MW and the actual imported MW, when defining what customers pay and when defining the value of CTRs. Under the current rules, PJM defines the total MW needed for reliability in an LDA when clearing the BRA based on forecast demand at the time of the BRA. But PJM actually charges customers for the total MW needed for reliability based on forecast demand three years later, prior to the actual delivery year, and applies a zonal allocation. PJM also defines the internal capacity as the internal capacity after the final incremental auction conducted three years after the BRA, when auctions follow the traditional schedule. The difference between the updated MW needed for reliability and the updated internal capacity is the updated imported MW, adjusted for the final zonal allocation. In cases where the updated imported MW are smaller than the imported MW from the actual auction clearing, the total value of CTRs is lower than it would be if the actual auction clearing MW were used.

The actual load charges are allocated to each zone based on the ratio of the zonal forecast peak load to the RTO forecast peak load used for the third incremental auction conducted three months prior to the delivery year.

The CTR issue implies a broader issue with capacity market clearing and settlements. The capacity market is cleared based on a three year ahead forecast of load and offers of capacity. Payments to capacity resources in the delivery year are based on the capacity market clearing prices and quantities. But payments by customers in the delivery year are not based on market clearing prices and quantities. Payments by customers in each zone are based on the

ratio of zonal forecast peak load to the RTO forecast peak load used for the Third Incremental Auction, run three months prior to the delivery year when auctions follow the traditional schedule.⁹² The allocation sometimes creates significant differences between the capacity cleared to meet the reliability requirement and the capacity obligation allocated to the customers in a zone. For example, ComEd Zone, which is identical to ComEd LDA, cleared 27,932.1 MW including 5,574.0 MW of imports in the 2021/2022 RPM BRA. The ComEd Zone's capacity obligation, immediately after the clearing of the Base Residual Auction was 24,983.0 MW. The final ComEd Zone's capacity obligation for the 2021/2022 Delivery Year after the Third Incremental Auction was 22,721.2 MW.

As with CTRs, the underlying reasons for not using the market clearing results are not clear. Although not stated explicitly, the goal appears to be to reflect the fact that actual loads change between the auction and the delivery year. But the simple reallocation of capacity obligations based on changes in the load forecast does not reflect the BRA market results. The MMU recommends that the market clearing results be used in settlements rather than the reallocation process currently used or that the process of modifying the obligations to pay for capacity be reviewed.

For LDAs in which the RPM auctions for a delivery year resulted in a positive average weighted Locational Price Adder, an LSE with CTRs corresponding to the LDA is entitled to a payment or charge equal to the Locational Price Adder multiplied by the MW of the LSEs' CTRs. The definition of the MW does not reflect auction clearing MW.

In the 2025/2026 RPM Third Incremental Auction, BGE had 5,024.2 MW of CTRs with a total value of \$360.6 million and DOM had 1,752.6 MW of CTRs with a total value of \$112.8 million. BGE had 65.7 MW of customer funded ICTRs with a total value of \$4.7 million. BGE had 306.0 MW of ICTRs due to Incremental Rights Eligible Required Transmission Enhancements with a value of \$22.0 million.

⁹² See "PJM Manual 18: PJM Capacity Market," § 7.2.3 Final Zonal Unforced Capacity Obligations, Rev. 62 (Dec. 17, 2025).

The 2026/2027 RPM Base Residual Auction cleared at \$329.17 per MW-day with no price separation and therefore the value of CTRs is \$0.

The 2027/2028 RPM Base Residual Auction cleared at \$333.44 per MW-day with no price separation and therefore the value of CTRs is \$0.

Demand Curve

A central feature of PJM's Reliability Pricing Model (RPM) design is that the demand curve, or Variable Resource Requirement (VRR) curve, has a downward sloping segment. In the RPM market design, the supply of three year forward capacity is cleared against this VRR curve. A VRR curve is defined for each Locational Deliverability Area (LDA). This shape replaced the vertical demand curve at the reliability requirement. The downward sloping segment begins at the MW level that is approximately 1.0 percent less than the reliability requirement.⁹³ Figure 5-4 shows the shape of the VRR curve for the 2026/2027 RPM Base Residual Auction.

The initial VRR curve, introduced in 2007, had a maximum price equal to 1.5 times the Net Cost of New Entry (Net CONE), determined annually based on fixed cost of new generating capacity, which is the Gross Cost of New Entry (Gross CONE), net of the three year average historical energy and ancillary service revenues. That VRR curve was structured to yield auction clearing prices equal to 1.5 times Net CONE when the amount of capacity cleared was less than 99 percent of the target reserve margin and below 1.5 times Net CONE when the amount of capacity cleared was greater than 99 percent of the target reserve margin.

Effective for the 2018/2019 through 2021/2022 Delivery Years, a revised VRR curve was implemented after PJM conducted a triennial review.⁹⁴ ⁹⁵ PJM defines the reliability requirement as the capacity needed to satisfy the one event in ten years loss of load expectation (LOLE) for the RTO and capacity needed to satisfy the one event in 25 years loss of load expectation for the each LDA. PJM increased the maximum price on the VRR curve to be the

⁹³ The formula for the MW level where the VRR curve begins the downward slope is given by $(\text{Reliability Requirement}) \times [1 - 1.2\% / (\text{Installed Reserve Margin})]$.

⁹⁴ "Third Triennial Review of PJM's Variable Resource Requirement Curve," The Brattle Group, May 15, 2014, <<http://www.pjm.com/media/library/reports-notices/reliability-pricing-model/20140515-brattle-2014-pjm-vrr-curve-report.aspx?la=en>>.

⁹⁵ 153 FERC ¶ 61,035 (October 15, 2015).

greater of Gross CONE or 1.5 times Net CONE for all unforced capacity MW between 0 and 99.8 percent of the reliability requirement. The first downward sloping segment was from 99.8 percent and 102.5 percent of the reliability requirement. The second downward sloping segment was from 102.5 percent and 107.6 percent of the reliability requirement.

Effective for the 2022/2023 through 2025/2026 Delivery Years, another revised VRR curve was implemented after PJM conducted a quadrennial review.⁹⁶ The maximum price on the VRR curve was the greater of Gross CONE or 1.5 times Net CONE for all unforced capacity MW between 0 and 98.9 percent of the reliability requirement. The first downward sloping segment was from 98.9 percent and 101.6 percent of the reliability requirement. The second downward sloping segment was from 101.6 percent and 106.8 percent of the reliability requirement (Figure 5-4).

Effective for the 2026/2027 through 2029/2030 Delivery Years, another revised VRR curve was implemented after PJM conducted a quadrennial review.⁹⁷ PJM increased the maximum price on the VRR curve to the greater of Gross CONE or 1.75 times Net CONE for all unforced capacity MW between 0 and 99.0 percent of the reliability requirement. The first downward sloping segment is from 99.0 percent and 101.5 percent of the reliability requirement. The second downward sloping segment is from 101.5 percent and 104.5 percent of the reliability requirement.

The VRR curve was then changed significantly based on PJM's filing to establish the maximum price point on the VRR curve equal to "approximately" \$325/MW-day in UCAP with a new MW point that is inconsistent with the tariff definition, a new minimum price point on the VRR curve of "approximately" \$175/MW-day in UCAP for an unlimited number of MW that is inconsistent with the tariff, and a VRR curve shape not consistent with the tariff definition, for all Reliability Pricing Model ("RPM") Auctions, including Base Residual Auctions and Incremental Auctions, for the 2026/2027 and 2027/2028 Delivery Years.⁹⁸ The VRR curve has always had a maximum price. The VRR

⁹⁶ 167 FERC ¶ 61,029 (April 15, 2019).

⁹⁷ 182 FERC ¶ 61,073 (Feb. 14, 2023).

⁹⁸ PJM Filing, Proposal for Revised Price Cap and Price Floor for the 2026/2027 and 2027/2028 Delivery Years, and Request for a Waiver of the 60-Days' Notice Requirement to Allow for a March 31, 2025 Effective Date, Docket No. ER25-1357 (Feb. 20, 2025). The modified

curve has always had a minimum price equal to zero. The proposal would set the maximum price level at somewhat higher than 1.5 times Net CONE. The MMU position is that the maximum price should be equal to the lesser of 1.5 times Net CONE or Gross CONE.⁹⁹ The MMU opposed the imposition of a completely unsupported floor price that is inconsistent with the longstanding VRR curve design.


The initial VRR curve, introduced in 2007, had a maximum price equal to 1.5 times the Net Cost of New Entry (Net CONE). The use of Net CONE was based on the logic of the capacity market, to ensure that between the energy and capacity markets the cost of entry was covered. Net CONE was the missing money from the energy and ancillary services markets that needed to be recoverable in the capacity market. The inclusion of the net energy and ancillary services markets revenue in the calculation of Net CONE was the equilibrating factor between the capacity market and energy market. The use of Gross CONE is inconsistent with that basic capacity market logic as is the use of 1.75 times Net CONE which is frequently greater than Gross CONE. Gross CONE was introduced as the maximum price based on PJM's unsupported assertions that Net CONE would somehow be too low. The maximum point on the VRR curve for the 2025/2026 BRA was the higher of Gross CONE or 1.5 times Net CONE, and Gross CONE was actually used. However, if the logic of the markets implies a low Net CONE, that is the right answer. There is nothing inherently wrong with a low Net CONE that requires abandoning the basic capacity market logic. Gross CONE was an intervention designed to increase capacity market prices based on a judgment about what prices should be despite the fact that the basic economic logic did not support that increase. If there is an issue with the calculation of Net CONE, it should be addressed directly rather than by ignoring its central role in the design of the capacity market. As Gross CONE numbers are reasonably well defined, much more focus on getting the net revenues used in the forward auctions is required in order to ensure that market participants have confidence in the Net CONE values used in the auctions.

⁹⁹ maximum price and the addition of a price floor were based on the Agreement between Governor Josh Shapiro of the Commonwealth of Pennsylvania and PJM.

⁹⁹ See Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM, (April 16, 2025). <https://www.monitoringanalytics.com/filings/2025/IMM_Answer_to_Answer_Docket_No_ER25-1357_20250416.pdf>.

Figure 5-4 shows the RTO VRR curve and RTO reliability requirement for the 2026/2027 RPM BRA.

Figure 5-4 Shape of the VRR curve relative to the reliability requirement: 2026/2027 Delivery Year



Market Concentration

Auction Market Structure

As shown in Table 5-11, in the 2026/2027 RPM Third Incremental Auction, all participants in the total PJM market as well as the LDA RPM markets failed the three pivotal supplier (TPS) test.¹⁰⁰ Offer caps were applied to all sell offers for resources which were subject to mitigation when the capacity market seller did not pass the test, the submitted sell offer exceeded the defined offer cap,

¹⁰⁰ The market definition used for the TPS test includes all offers with costs less than or equal to 1.50 times the clearing price. See *MMU Technical Reference for PJM Markets*, at "Three Pivotal Supplier Test" for additional discussion.

and the submitted sell offer, absent mitigation, increased the market clearing price.^{101 102 103}

In applying the market structure test, the relevant supply for the RTO market includes all supply offered at less than or equal to 150 percent of the RTO cost-based clearing price. The relevant supply for the constrained LDA markets includes the incremental supply inside the constrained LDAs which was offered at a price higher than the unconstrained clearing price for the parent LDA market and less than or equal to 150 percent of the cost-based clearing price for the constrained LDA. The relevant demand consists of the MW needed inside the LDA to relieve the constraint.

Table 5-11 presents the results of the TPS test. A generation owner or owners are pivotal if the capacity of the owners' generation facilities is needed to meet the demand for capacity. The results of the TPS are measured by the residual supply index (RSI_x). The RSI_x is a general measure that can be used with any number of pivotal suppliers. The subscript denotes the number of pivotal suppliers included in the test. If the RSI_x is less than or equal to 1.0, the supply owned by the specific generation owner, or owners, is needed to meet market demand and the generation owners are pivotal suppliers with a significant ability to influence market prices. If the RSI_x is greater than 1.0, the supply of the specific generation owner or owners is not needed to meet market demand and those generation owners have a reduced ability to unilaterally influence market price.

¹⁰¹ See OATT Attachment DD § 6.5.

¹⁰² Prior to November 1, 2009, existing DR and EE resources were subject to market power mitigation in RPM Auctions. See 129 FERC ¶ 61,081 at P 30 (2009).

¹⁰³ Effective January 31, 2011, the RPM rules related to market power mitigation were changed, including revising the definition for planned generation capacity resource and creating a new definition for existing generation capacity resource for purposes of the must offer requirement and market power mitigation, and treating a proposed increase in the capability of a generation capacity resource the same in terms of mitigation as a planned generation capacity resource. See 134 FERC ¶ 61,065 (2011).

Table 5-11 RSI results: 2023/2024 through 2027/2028 RPM Auctions¹⁰⁴

RPM Markets	RSI1, 1.05	RSI3	Total Participants	Failed RSI3 Participants
2023/2024 Base Residual Auction				
RTO	0.78	0.68	134	134
MAAC	0.78	0.40	11	11
DPL South	0.00	0.00	1	1
BGE	0.00	0.00	1	1
2023/2024 Third Incremental Auction				
RTO	0.77	0.76	51	15
MAAC	0.41	0.76	17	9
EMAAC	0.45	0.18	10	10
BGE	0.00	0.00	1	1
2024/2025 Base Residual Auction				
RTO	0.77	0.64	133	133
MAAC	0.59	0.11	9	9
EMAAC	0.48	0.00	2	2
DPL South	0.00	0.00	1	1
BGE	0.00	0.00	1	1
DEOK	0.00	0.00	1	1
2024/2025 Third Incremental Auction				
RTO	0.88	0.59	64	64
MAAC	0.60	0.17	10	10
EMAAC	0.00	0.00	1	1
BGE	0.00	0.00	1	1
2025/2026 Base Residual Auction				
RTO	0.82	0.62	128	128
BGE	0.00	0.00	0	0
Dominion	0.00	0.00	0	0
2025/2026 Third Incremental Auction				
RTO	0.60	0.31	75	75
BGE	0.00	0.00	0	0
2026/2027 Base Residual Auction				
RTO	0.82	0.64	153	153
2026/2027 Third Incremental Auction				
RTO	0.82	0.67	120	120
2027/2028 Base Residual Auction				
RTO	0.82	0.63	155	155

¹⁰⁴ The RSI shown is the lowest RSI in the market.

Locational Deliverability Areas (LDAs)

Under the PJM Tariff, PJM determines, in advance of each BRA, whether defined Locational Deliverability Areas (LDAs) will be modeled in the auction. Effective with the 2012/2013 Delivery Year, an LDA is modeled as a potentially constrained LDA for a delivery year if the Capacity Emergency Transfer Limit (CETL) is less than 1.15 times the Capacity Emergency Transfer Objective (CETO), such LDA had a locational price adder in one or more of the three immediately preceding BRAs, or such LDA is determined by PJM in a preliminary analysis to be likely to have a locational price adder based on historic offer price levels. The rules also provide that starting with the 2012/2013 Delivery Year, EMAAC, SWMAAC, and MAAC LDAs are modeled as potentially constrained LDAs regardless of the results of the above three tests.¹⁰⁵ In addition, PJM may establish a constrained LDA even if it does not qualify under the above tests if PJM finds that “such is required to achieve an acceptable level of reliability.”¹⁰⁶ A reliability requirement and a Variable Resource Requirement (VRR) curve are established for each modeled LDA. Effective for the 2014/2015 through 2016/2017 Delivery Years, a Minimum Annual and a Minimum Extended Summer Resource Requirement were established for each modeled LDA. Effective for the 2017/2018 Delivery Year, Sub-Annual and Limited Resource Constraints, replacing the Minimum Annual and a Minimum Extended Summer Resource Requirements, were established for each modeled LDA.¹⁰⁷ ¹⁰⁸ Effective for the 2018/2019 and the 2019/2020 Delivery Years, a Base Capacity Demand Resource Constraint and a Base Capacity Resource Constraint, replacing the Sub-Annual and Limited Resource Constraints, were established for each modeled LDA.

Imports and Exports

Units external to the metered boundaries of PJM can qualify as PJM capacity resources if they meet the requirements to be capacity resources. Generators on the PJM system that do not have a commitment to serve PJM loads in the given delivery year as a result of RPM auctions, FRR capacity plans, locational

¹⁰⁵ Prior to the 2012/2013 Delivery Year, an LDA with a CETL less than 1.05 times CETO was modeled as a constrained LDA in RPM. No additional criteria were used in determining modeled LDAs.

¹⁰⁶ OATT Attachment DD § 5.10 (a) (ii).

¹⁰⁷ 146 FERC ¶ 61,052 (2014).

¹⁰⁸ Locational Deliverability Areas are shown in maps in the *2021 Annual State of the Market Report for PJM*, Volume 2, Section 5: “Capacity Market” at “Locational Deliverability Areas (LDAs)”.

UCAP transactions, and/or are not designated as a replacement resource, are eligible to export their capacity from PJM.¹⁰⁹

The market rules in other balancing authorities should also not create inappropriate barriers to the import or export of capacity. The PJM market rules should ensure that the definition of capacity is enforced including physical deliverability, recallability and the obligation to make competitive offers into the PJM Day-Ahead Energy Market equal to ICAP MW. Physical deliverability can only be assured by requiring that all imports are deliverable to PJM load to ensure that they are full substitutes for internal capacity resources. Selling capacity into the PJM Capacity Market but making energy offers daily of \$999 per MWh would not fulfill the requirements of a capacity resource to make a competitive offer, but would constitute economic withholding. This is one of the reasons that the rules governing the obligation to make a competitive offer in the day-ahead energy market should be clarified for both internal and external resources. The PJM market rules should also not create inappropriate barriers to either the import or export of capacity.

The calculation of CETL should only include capacity imports into PJM where the capacity has an explicit must offer requirement in the PJM Capacity Market. These could include pseudo tied units or resources with a grandfathered obligation. The external capacity that does not have a must offer requirement in the PJM capacity market is not obligated to serve PJM load under all conditions and therefore should not be assumed to be a source of capacity. This capacity should not be included in PJM’s power flow calculations used to derive CETL values between PJM’s LDAs. PJM has modified its CETL calculations to exclude such capacity.

The establishment of a pseudo tie is one requirement for an external resource to be eligible to participate in the PJM Capacity Market. Pseudo tied external resources, regardless of their location, are treated as only meeting the reliability requirements of the rest of RTO and not the reliability requirements of any specific locational deliverability area (LDA). All imports offered in the auction from areas external to PJM are modeled as supply in the rest of RTO and not in any specific zonal or subzonal LDA. The fact that pseudo tied external

¹⁰⁹ OATT Attachment DD § 5.6.6(b).

resources cannot be identified as equivalent to resources internal to specific LDAs illustrates a fundamental issue with capacity imports. Capacity imports are not equivalent to, nor substitutes for, internal resources. All internal resources are internal to a specific LDA.¹¹⁰

Effective May 9, 2017, significantly improved pseudo tie requirements for external generation capacity resources were implemented.¹¹¹ The rule changes include: defining coordination with other Balancing Authorities when conducting pseudo tie studies; establishing an electrical distance requirement; establishing a market to market flowgate test to establish limits on the number of coordinated flowgates PJM must add in order to accommodate a new pseudo tie; a model consistency requirement; the requirement for the capacity market seller to provide written acknowledgement from the external Balancing Authority Areas that such pseudo tie does not require tagging and that firm allocations associated with any coordinated flowgates applicable to the external Generation Capacity Resource under any agreed congestion management process then in effect between PJM and such Balancing Authority Area will be allocated to PJM; the requirement for the capacity market seller to obtain long-term firm point to point transmission service for transmission outside PJM with rollover rights and to obtain network external designated transmission service for transmission within PJM; establishing an operationally deliverable standard; and modifying the nonperformance penalty definition for external generation capacity resources to assess performance at subregional transmission organization granularity.

Generation external to the PJM region is eligible to be offered into an RPM auction if it meets specific requirements.^{112 113 114} Firm transmission service must be acquired from all external transmission providers between the unit and border of PJM and generation deliverability into PJM must be demonstrated prior to the start of the delivery year. In order to demonstrate generation deliverability into PJM, external generators must obtain firm point

to point transmission service on the PJM OASIS from the PJM border into the PJM transmission system or by obtaining network external designated transmission service. In the event that transmission upgrades are required to establish deliverability, those upgrades must be completed by the start of the delivery year. The following are also required: the external generating unit must be in the resource portfolio of a PJM member; 12 months of NERC/GADs unit performance data must be provided to establish an EFORd; the net capability of each unit must be verified through winter and summer testing; and a letter of non-recallability must be provided to assure PJM that the energy and capacity from the unit is not recallable to any other balancing authority.

All external generation resources that have an RPM commitment or FRR capacity plan commitment or that are designated as replacement capacity must be offered in the PJM day-ahead energy market.¹¹⁵

Planned External Generation Capacity Resources are eligible to be offered into an RPM Auction if they meet specific requirements.^{116 117} Planned External Generation Capacity Resources are proposed Generation Capacity Resources, or a proposed increase in the capability of an Existing Generation Capacity Resource, that is located outside the PJM region; participates in the generation interconnection process of a balancing authority external to PJM; is scheduled to be physically and electrically interconnected to the transmission facilities of such balancing authority on or before the first day of the delivery year for which the resource is to be committed to satisfy the reliability requirements of the PJM region; and is in full commercial operation prior to the first day of the delivery year.¹¹⁸ An External Generation Capacity Resource becomes an Existing Generation Capacity Resource as of the earlier of the date that interconnection service commences or the resource has cleared an RPM Auction for a prior delivery year.¹¹⁹

110 External resources are not assigned to any of the five global LDAs or 22 zonal and subzonal LDAs. PJM's current practice is to model external resources in the rest of RTO. The practice is not currently documented by PJM. It was previously documented in "PJM Manual 18: PJM Capacity Market," § 2.3.4 Capacity Import Limits, Rev. 39 (Dec. 21, 2017).

111 161 FERC ¶ 61,197 (2017).

112 See "Reliability Assurance Agreement Among Load Serving Entities in the PJM Region," Schedule 9 & 10.

113 "PJM Manual 18: PJM Capacity Market," § 4.2.2 Existing Generation Capacity Resources – External, Rev. 62 (Dec. 17, 2025).

114 "PJM Manual 18: PJM Capacity Market," § 4.6.4 Importing an External Generation Resource, Rev. 62 (Dec. 17, 2025).

115 OATT Schedule 1 § 1.10.1A.

116 See "Reliability Assurance Agreement among Load Serving Entities in the PJM Region," Section 1.69A.

117 "PJM Manual 18: PJM Capacity Market," § 4.2.4 Planned Generation Capacity Resources – External, Rev. 62 (Dec. 17, 2025).

118 Prior to January 31, 2011, capacity modifications to existing generation capacity resources were not considered planned generation capacity resources. See 134 FERC ¶ 61,065 (2011).

119 Effective January 31, 2011, the RPM rules related to market power mitigation were changed, including revising the definition for Planned Generation Capacity Resource for purposes of the must-offer requirement and market power mitigation. See 134 FERC ¶ 61,065 (2011).

As shown in Table 5-12, of the 1,144.8 MW of imports offered in the 2027/2028 RPM Base Residual Auction, 1,005.9 MW cleared. Of the cleared imports, 695.6 MW (69.2 percent) were from MISO.

Table 5-12 RPM imports: 2007/2008 through 2027/2028 RPM Base Residual Auctions

Base Residual Auction	MISO		UCAP (MW) Non-MISO		Total Imports	
	Offered	Cleared	Offered	Cleared	Offered	Cleared
2007/2008	1,073.0	1,072.9	547.9	547.9	1,620.9	1,620.8
2008/2009	1,149.4	1,109.0	517.6	516.8	1,667.0	1,625.8
2009/2010	1,189.2	1,151.0	518.8	518.1	1,708.0	1,669.1
2010/2011	1,194.2	1,186.6	539.8	539.5	1,734.0	1,726.1
2011/2012	1,862.7	1,198.6	3,560.0	3,557.5	5,422.7	4,756.1
2012/2013	1,415.9	1,298.8	1,036.7	1,036.7	2,452.6	2,335.5
2013/2014	1,895.1	1,895.1	1,358.9	1,358.9	3,254.0	3,254.0
2014/2015	1,067.7	1,067.7	1,948.8	1,948.8	3,016.5	3,016.5
2015/2016	1,538.7	1,538.7	2,396.6	2,396.6	3,935.3	3,935.3
2016/2017	4,723.1	4,723.1	2,770.6	2,759.6	7,493.7	7,482.7
2017/2018	2,624.3	2,624.3	2,320.4	1,901.2	4,944.7	4,525.5
2018/2019	2,879.1	2,509.1	2,256.7	2,178.8	5,135.8	4,687.9
2019/2020	2,067.3	1,828.6	2,276.1	2,047.3	4,343.4	3,875.9
2020/2021	2,511.8	1,671.2	2,450.0	2,326.0	4,961.8	3,997.2
2021/2022	2,308.4	1,909.9	2,162.0	2,141.9	4,470.4	4,051.8
2022/2023	954.9	954.9	603.1	603.1	1,558.0	1,558.0
2023/2024	967.9	836.5	560.1	560.1	1,528.0	1,396.6
2024/2025	949.9	820.4	577.2	577.2	1,527.1	1,397.6
2025/2026	700.5	700.5	568.0	568.0	1,268.5	1,268.5
2026/2027	697.4	697.4	584.3	584.3	1,281.7	1,281.7
2027/2028	695.6	695.6	449.2	310.3	1,144.8	1,005.9

One of the reasons that a Generation Capacity Resource may qualify for an exception to the RPM must offer requirement is by demonstration that it has a financially and physically firm commitment to an external sale of its capacity.¹²⁰ Exporting a Generation Capacity Resource requires a financially and physically firm commitment to load located outside the PJM Region. The PJM Tariff states “In order to establish that a resource has a financially and physically firm commitment to an external sale of its capacity, the Capacity Market Seller must demonstrate that it has entered into a unit-specific

bilateral transaction for service to load located outside the PJM Region, by a demonstration that such resource is identified on a unit-specific basis as a network resource under the transmission tariff for the control area applicable to such external load, or by an equivalent demonstration of a financially and physically firm commitment to an external sale. The Capacity Market Seller additionally shall identify the megawatt amount, export zone, and time period (in days) of the export.”¹²¹

The MMU recommends that the PJM Tariff be modified to explicitly state that in order to qualify, a Capacity Market Seller requesting a must offer exception based on a financially and physically firm commitment to an external sale of its capacity must provide a confirmed firm transmission reservation, covering the entire path from source to sink, for the full requested ICAP MW of the external sale that covers the entire delivery year, by the tariff defined deadline. The MMU recommends that this language apply to all external sales of Generation Capacity Resources, including those where an external balancing authority does not require this level of transmission service in order to consider a PJM resource as a network resource.

Demand Resources

The level of DR products that buy out of their positions after the BRA means that the treatment of DR has a negative impact on generation investment incentives and that the rules governing the requirement to be a physical resource should be more clearly stated and enforced.¹²² If DR displaces new generation resources in BRAs, but then buys out of the position prior to the delivery year, this means potentially replacing new entry generation resources at the high end of the supply curve with other existing but uncleared capacity resources available in Incremental Auctions at reduced offer prices. This suppresses the price of capacity in the BRA compared to the competitive result because it permits the shifting of demand from the BRA to the Incremental Auctions, which is inconsistent with the must offer, must buy rules, and the

¹²¹ Ibid.

¹²² See “Analysis of Replacement Capacity for RPM Commitments: June 1, 2007 to June 1, 2019,” <http://www.monitoringanalytics.com/reports/Reports/2019/IMM_Analysis_of_Replacement_Capacity_for_RPM_Commitments_June_1_2007_to_June_1_2019_20190913.pdf> (September 13, 2019).

¹²⁰ OATT Attachment DD § 6.6(g).

requirement to be an actual, physical resource, governing the BRA. PJM’s sell back of capacity in Incremental Auctions exacerbates the incentive for DR to buy out of its BRA positions in IAs.

Effective with the 2020/2021 Delivery Year, DR includes annual and summer products. Annual Demand Resources are required to be available on any day during the Delivery Year for an unlimited number of interruptions between the hours of 10:00 a.m. and 10:00 p.m. EPT for the months of June through October and the following May and between the hours of 6:00 a.m. and 9:00 p.m. EPT for the months of November through April unless there is a PJM approved maintenance outage during the October through April period.

Summer-Period Demand Resources are required to be available on any day from June through October and the following May of the delivery year for an unlimited number of interruptions between the hours of 10:00 a.m. to 10:00 p.m. EPT.

As shown in Table 5-13, and Table 5-14, committed DR was 5,782.9 MW for June 1, 2025, as a result of cleared capacity for demand resources in RPM auctions for the 2025/2026 Delivery Year (6,265.9 MW) less replacement capacity (483.0 MW).

Table 5-13 RPM load management statistics by LDA: June 1, 2023 to June 1, 2027^{123 124 125 126}

		UCAP (MW)																
		RTO	MAAC	EMAAC	SWMAAC	DPL South	PSEG	PSEG North	Pepco	ATSI	ATSI Cleveland	ComEd	BGE	PPL	DAY	DEOK	Dominion	JCPL
01-Jun-23	DR cleared	8,174.1	2,411.4	975.9	343.6	52.2	272.7	126.1	175.2	916.2	189.4	1,253.2	168.4	583.4	209.3	175.4		
	EE cleared	5,896.4	2,438.6	1,341.4	569.5	59.3	443.4	210.4	298.6	451.8	46.3	961.2	270.9	306.1	102.4	164.3		
	DR net replacements	(466.2)	(229.5)	(3.8)	(4.9)	22.8	3.4	2.6	(25.0)	47.2	(63.4)	160.7	20.1	(123.3)	(24.0)	25.0		
	EE net replacements	(5.3)	(2.2)	(1.0)	7.6	9.0	11.6	13.7	7.6	(15.3)	(0.5)	(20.9)	0.0	(6.2)	(7.9)	0.7		
	RPM load management	13,599.0	4,618.3	2,312.5	915.8	143.3	731.1	352.8	456.4	1,399.9	171.8	2,354.2	459.4	760.0	279.8	365.4		
01-Jun-24	DR cleared	8,064.7	2,497.6	1,004.0	358.5	46.0	285.7	98.2	160.4	682.6	141.6	1,554.0	198.1	603.4	192.9	221.9		
	EE cleared	7,716.0	3,543.5	2,064.9	787.4	99.9	802.9	392.0	398.9	587.6	54.9	1,063.4	388.5	391.4	128.3	188.1		
	DR net replacements	(364.8)	(197.4)	9.1	43.0	35.2	(7.3)	(14.9)	19.3	50.9	(58.3)	(56.0)	23.7	(138.9)	(6.2)	(5.4)		
	EE net replacements	(48.0)	(43.6)	(15.4)	21.3	14.1	(6.5)	(0.1)	9.1	(30.6)	0.0	1.2	12.2	(38.4)	(5.6)	(3.7)		
	RPM load management	15,367.9	5,800.1	3,062.6	1,210.2	195.2	1,074.8	475.2	587.7	1,290.5	138.2	2,562.6	622.5	817.5	309.4	400.9		
01-Jun-25	DR cleared	6,265.9	1,860.8	784.9	304.0	65.0	228.9	65.8	135.7	712.7	97.3	1,090.5	168.3	424.9	141.0	159.6	673.5	
	EE cleared	1,493.2	674.7	433.5	154.7	24.0	184.0	100.0	80.0	69.1	6.6	337.6	74.7	45.7	18.5	24.9	154.2	
	DR net replacements	(483.0)	(140.4)	(60.2)	(11.6)	(30.3)	(10.4)	(14.3)	(15.1)	(39.8)	(11.6)	(29.0)	3.5	(10.2)	(0.2)	(39.9)	(151.0)	
	EE net replacements	(11.6)	32.8	25.7	(2.6)	(1.3)	7.5	3.3	(2.6)	(6.8)	(0.1)	1.0	0.0	10.0	(0.2)	(1.6)	(11.6)	
	RPM load management	7,264.5	2,427.9	1,183.9	444.5	57.4	410.0	154.8	198.0	735.2	99.0	1,400.1	246.5	470.4	159.1	143.0	665.1	
01-Jun-26	DR cleared	5,710.3	1,611.1	620.0	381.5	33.9	179.1	45.6	229.3	597.8	94.4	970.7	152.2	327.5	152.0	116.3	555.1	59.2
	DR net replacements	(18.3)	(5.3)	(0.5)	0.0	0.0	(0.5)	0.0	0.0	(12.0)	0.0	(0.2)	0.0	(1.9)	0.0	0.0	0.0	0.0
	RPM load management	5,692.0	1,605.8	619.5	381.5	33.9	178.6	45.6	229.3	585.8	94.4	970.5	152.2	325.6	152.0	116.3	555.1	59.2
01-Jun-27	DR cleared	7,298.6	1,981.6	799.8	455.5	42.6	234.3	49.1	285.9	672.3	101.7	1,515.9	169.6	421.8	172.1	200.6	768.3	89.3
	DR net replacements	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	RPM load management	7,298.6	1,981.6	799.8	455.5	42.6	234.3	49.1	285.9	672.3	101.7	1,515.9	169.6	421.8	172.1	200.6	768.3	89.3

123 See OATT Attachment DD § 8.4. The reported DR cleared MW may reflect reductions in the level of committed MW due to relief from Capacity Resource Deficiency Charges.

124 Pursuant to OA § 15.1.6(c), PJM Settlement shall attempt to close out and liquidate forward capacity commitments for PJM Members that are declared in collateral default. The reported replacement transactions may include transactions associated with PJM members that were declared in collateral default.

125 EE resources are fully reflected in PJM load forecasts starting with the 2016 load forecast for the 2019/2020 delivery year, and EE resources are not defined to be capacity resources in any way as a result. EE resources do not clear in the capacity auctions.

126 See OATT Attachment DD § 5.14E. The reported DR cleared MW for the 2016/2017, 2017/2018, and 2018/2019 Delivery Years reflect reductions in the level of committed MW due to the Demand Response Legacy Direct Load Control Transition Provision.

Table 5-14 RPM commitments, replacements, and registrations for demand resources: June 1, 2007 to June 1, 2027^{127 128 129}

	UCAP (MW)						Registered DR		
	RPM Cleared	Adjustments to Cleared	Net Replacements	RPM Commitments	RPM Commitment Shortage	RPM Commitments Less Commitment Shortage	ICAP (MW)	UCAP Conversion Factor	UCAP (MW)
01-Jun-07	127.6	0.0	0.0	127.6	0.0	127.6	0.0	1.033	0.0
01-Jun-08	559.4	0.0	(40.0)	519.4	(58.4)	461.0	488.0	1.034	504.7
01-Jun-09	892.9	0.0	(474.7)	418.2	(14.3)	403.9	570.3	1.033	589.2
01-Jun-10	962.9	0.0	(516.3)	446.6	(7.7)	438.9	572.8	1.035	592.6
01-Jun-11	1,826.6	0.0	(1,052.4)	774.2	0.0	774.2	1,117.9	1.035	1,156.5
01-Jun-12	8,752.6	(11.7)	(2,253.6)	6,487.3	(34.9)	6,452.4	7,443.7	1.037	7,718.4
01-Jun-13	10,779.6	0.0	(3,314.4)	7,465.2	(30.5)	7,434.7	8,240.1	1.042	8,586.8
01-Jun-14	14,943.0	0.0	(6,731.8)	8,211.2	(219.4)	7,991.8	8,923.4	1.042	9,301.2
01-Jun-15	15,774.8	(321.1)	(4,829.7)	10,624.0	(61.8)	10,562.2	10,946.0	1.038	11,360.0
01-Jun-16	13,284.7	(19.4)	(4,800.7)	8,464.6	(455.4)	8,009.2	8,961.2	1.042	9,333.4
01-Jun-17	11,870.7	0.0	(3,870.8)	7,999.9	(30.3)	7,969.6	8,681.4	1.039	9,016.3
01-Jun-18	11,435.4	0.0	(3,182.4)	8,253.0	(1.0)	8,252.0	8,512.0	1.091	9,282.4
01-Jun-19	10,703.1	0.0	(2,138.8)	8,564.3	(0.4)	8,563.9	9,229.9	1.090	10,056.0
01-Jun-20	9,445.7	0.0	(2,399.5)	7,046.2	(0.1)	7,046.1	7,867.6	1.088	8,561.5
01-Jun-21	11,427.7	0.0	(4,111.0)	7,316.7	0.0	7,316.7	7,754.2	1.087	8,429.6
01-Jun-22	8,866.2	0.0	(570.0)	8,296.2	(52.1)	8,244.1	8,518.5	1.091	9,290.2
01-Jun-23	8,174.1	0.0	(466.2)	7,707.9	(161.5)	7,546.4	7,383.0	1.093	8,069.6
01-Jun-24	8,064.7	0.0	(364.8)	7,699.9	(507.4)	7,192.5	6,758.7	1.117	7,549.5
01-Jun-25	6,265.9	0.0	(483.0)	5,782.9	(209.4)	5,573.5	7,748.7	0.770	5,966.5
01-Jun-26	5,710.3	0.0	(18.3)	5,692.0	0.0	5,692.0	0.0	0.720	0.0
01-Jun-27	7,298.6	0.0	0.0	7,298.6	0.0	7,298.6	0.0	0.920	0.0

ELCC: The Capacity Value of Resources

Given that many PJM states have aggressive renewable energy targets, a core goal of a competitive market design should be to ensure that the resources required to provide reliability receive appropriate competitive market incentives for entry and for ongoing investment and for exit when uneconomic. A significant level of renewable resources, operating with zero or near zero marginal costs, will result in very low energy prices at times

of high intermittent output. Since renewable resources are intermittent, the contribution of renewables to meeting reliability targets must be analyzed carefully to ensure that the capacity value of renewables is calculated correctly.

The units of measurement for the PJM capacity market auctions are unforced capacity (UCAP). PJM uses conversion factors to convert installed capacity MW (ICAP) into UCAP MW and this process is known as capacity accreditation. Prior to the 2023/2024 Delivery Year, EFORD values for thermal generators were used to convert ICAP to UCAP. Conversion factors for wind and solar generators were based on energy output during summer peak

¹²⁷ See OATT Attachment DD § 8.4. The reported DR adjustments to cleared MW include reductions in the level of committed MW due to relief from Capacity Resource Deficiency Charges.

¹²⁸ See OATT Attachment DD § 5.14C. The reported DR adjustments to cleared MW for the 2015/2016 and 2016/2017 Delivery Years include reductions in the level of committed MW due to the Demand Response Operational Resource Flexibility Transition Provision.

¹²⁹ See OATT Attachment DD § 5.14E. The reported DR adjustments to cleared MW for the 2016/2017, 2017/2018, and 2018/2019 Delivery Years include reductions in the level of committed MW due to the Demand Response Legacy Direct Load Control Transition Provision.

hours. Conversion factors for storage resources were equal to the maximum capability during 10 continuous hours of operation. The conversion factor for Demand Resources was equal to the forecast pool requirement (FPR). On July 30, 2021, FERC approved new PJM rules for defining/derating the capacity value of intermittent and storage resources, based on PJM's interpretation of the effective load carrying capability (ELCC) method.¹³⁰ PJM's average ELCC accreditations for intermittent and storage resources relied on the average capability by resource class for the 2023/2024 and 2024/2025 Delivery Years. Revisions, filed in October 2023, changed the capacity accreditation calculation to a marginal ELCC approach, applicable to all resource types. Beginning with the 2025/2026 Delivery Year, capacity accreditations are based on the revised marginal ELCC approach. The PJM marginal ELCC approach was accepted by FERC in January 2024.¹³¹

PJM's approach to ELCC is based on the correct high level insight that there is a need to calculate the availability of different resource types, but the actual implementation does not do that correctly and results in a set of illogical outcomes. For example, PJM assigned penalties to solar resources during Winter Storm Elliott in December 2022 when solar resources did not generate power after dark. PJM's ELCC calculations rely on a significant overweighting of generator performance during the Polar Vortex in 2014 and Winter Storm Elliott in 2022 that results in artificially suppressed ELCC values for thermal resources and other resource types.

Under the PJM ELCC approach a solar resource is assigned a derating factor, and the derated MW are asserted to be equivalent to a perfect resource accredited at that MW level. PJM assigned penalties to solar resources during Elliott when they did not generate power after dark. This is clearly not correct and illustrates one of the flaws in the ELCC logic. The solar resource is available for sunny hours and not for unsunny hours. A solar resource is not expected to generate at night and should not face penalties for failing to do what it obviously cannot. ELCC does not convert intermittent resources, or any resource, into a perfect resource, or even the equivalent of a perfect resource. This illogical implication of PJM's ELCC means that there is a significant flaw

¹³⁰ See 176 FERC ¶ 61,056.

¹³¹ 186 FERC ¶61,080 (January 30, 2024).

in the ELCC approach. The penalties were assessed because the ELCC method determined that 1 MW of solar nameplate capacity was equivalent to 0.54 MW of perfect capacity, meaning capacity that is always available at the derated level, even in the middle of the night.¹³²

The MMU opposes PJM's ELCC rules because they are an administrative determination by PJM based on a black box model of the capacity value of resources, they rely on significant counterfactual behavioral assumptions for storage and demand response resources, are not unit specific, are not hourly, are not locational, introduce significant volatility to the capacity accreditations, do not recognize the winter capability of thermal resources, overweight unit performance during Winter Storm Elliott, do not recognize actual performance in the delivery year and are an ex ante approach that must assume a capacity resource fleet for determining the ELCC marginal class ratings.¹³³ PJM does not check the actual cleared capacity in capacity market auctions to verify if the cleared capacity is expected to provide the target reliability.

The ELCC approach is not an appropriate way to define the MW capacity value for intermittent and storage resources, or for thermal resources, in a market. ELCC was developed as, and remains, a utility planning tool rather than a market design tool. ELCC was attractive as a possible analytical basis for the derating of intermittent and storage resources to a MW level consistent with their actual availability. The impetus made sense but the actual application of the ELCC planning tool cannot work in markets that include intermittent or thermal resources. The underlying logic makes sense but PJM's implementation does not.

As a result of all these issues, the MMU has concluded that ELCC is not a viable method for determining the reliability contributions of capacity resources. The

¹³² "ELCC Class Ratings for 2024-2025 BRA," PJM Interconnection LLC. (December 28, 2021) <<https://www.pjm.com/planning/resource-adequacy-planning/effective-load-carrying-capability>>.

¹³³ See Protest of the Independent Market Monitor for PJM, Docket ER24-99-000, et al. (November 9, 2023); Comments on Response to Deficiency Notice, Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM, Docket No. ER24-99-000 (December 21, 2023); Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM, Docket No. ER24-99-000 (January 12, 2024); Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM, Docket No. ER24-99-000 (January 24, 2024).

MMU has proposed a replacement for the PJM ELCC approach that is based on the actual hourly availability of all individual generators.^{134 135 136}

The ELCC ratings produced by the marginal approach in general, and by PJM's specific marginal approach specifically, are inherently volatile. PJM has calculated the marginal ELCC class ratings for the 2025/2026 delivery year on five separate occasions. Table 5-15 shows the results of each calculation. Each calculation is dependent upon the load forecast model, the combination of actual historical performance and changes in experienced weather, and the assumed forward looking resource mix. The PJM 2024 load forecast model was used to produce the February 2024, March 2024 and January 2025 ELCC ratings. The ELCC ratings posted on December 31, 2024, used an interim 2025 load forecast model. In early January, PJM removed the posted ELCC ratings from December 31, 2024, and posted recalculated ratings using the 2024 load forecast model. The modified ELCC ratings were posted on January 23, 2025. The January 23, 2025, ratings are the final ELCC ratings for 2025/2026 Delivery Year.¹³⁷ The ELCC rating changes have significant impacts on the amount of cleared capacity. Table 5-16 shows the difference between capacity that cleared the 2025/2026 Base Residual Auction and the updated capacity MW value based on the final ELCC ratings for 2025/2026 posted on January 23, 2025. In total, the capacity values decreased by 928.5 MW (UCAP) or 0.7 percent. Capacity market sellers are obligated to obtain additional capacity prior to the delivery year if they are short as a result of a reduction in ELCC rating between the BRA and the final ELCC rating from PJM's ELCC rating changes. Had PJM used the ELCC ratings posted on December 31, 2024, the capacity values would have decreased by 3,793.3 MW or 2.8 percent.

¹³⁴ For additional details on the MMU proposal see "Executive Summary of the IMM Capacity Market Design Proposal: Sustainable Capacity Market (SCM)", Independent Market Monitor for PJM (August 16, 2023) <http://www.monitoringanalytics.com/reports/Presentations/2023/IMM_RASIF-CIFP_SCM_Executive_Summary_20230816.pdf>.

¹³⁵ Any generation from a resource in excess of its CIR value is equivalent to generation from an energy only resource and should not be included in the calculation of the capacity value of the resource or in the calculation of the derated ELCC class ratings that define the capacity value of the resource. Updated rules beginning with the 2025/2026 Delivery Year require that ELCC accreditations exclude energy in excess of a generator's CIR. See 183 FERC ¶ 61,009 (April 7, 2023).

¹³⁶ New rules beginning with the 2025/2026 Delivery Year correctly limit the delivered energy to the CIR level in the ELCC calculations. The new rules also include a complex transition process that allocates available headroom to intermittent resources with understated CIRs. The new rules apply to Delivery Year 2025/2026 BRA and subsequent delivery years. See 183 FERC ¶ 61,009 (April 7, 2023).

¹³⁷ See Item 5 in Markets and Reliability Committee Meeting Materials, *Installed Reserve Margin (IRM), Forecast Pool Requirement (FPR), and Effective Load Carrying Capability (ELCC) for 2025/2026 3IA* at 2, PJM Interconnection LLC. (January 23, 2025) <<https://www.pjm.com/committees-and-groups/committees/mrc>>.

Table 5-15 Marginal ELCC ratings for the 2025/2026 Delivery Year

ELCC Class	2025/2026 Delivery Year				
	December 2023	February 2024	March 2024	December 2024	January 2025
Onshore Wind	21%	35%	35%	42%	38%
Offshore Wind	39%	60%	60%	71%	62%
Solar Fixed	15%	9%	9%	8%	10%
Solar Tracking	25%	14%	14%	11%	14%
Landfill Intermittent	56%	55%	54%	51%	51%
Hydro Intermittent	41%	36%	37%	37%	37%
4-hr Storage	76%	59%	59%	44%	55%
6-hr Storage	85%	67%	67%	53%	65%
8-hr Storage	89%	69%	68%	58%	68%
10-hr Storage	92%	78%	78%	67%	77%
Demand Response	95%	77%	76%	68%	77%
Nuclear	96%	96%	95%	95%	95%
Coal	86%	85%	84%	83%	83%
Gas Combined Cycle	87%	80%	79%	77%	78%
Gas Combustion Turbine	74%	62%	62%	59%	63%
Gas Combustion Turbine Dual Fuel	90%	78%	79%	78%	79%
Diesel Utility	91%	90%	92%	92%	92%
Steam	78%	70%	75%	73%	74%

Table 5-16 Impact of ratings changes on cleared capacity¹³⁸

	MW (UCAP)	Reduction in capacity value compared to Base Residual Auction	Percent change in capacity value compared to Base Residual Auction
2025/2026 Base Residual Auction Cleared Capacity	135,684.0		
Updated Cleared Capacity based on Jan 23, 2025 ELCC Ratings	134,755.5	(928.5)	(0.7%)
Updated Cleared Capacity based on Dec 31, 2024 ELCC Ratings	131,890.7	(3,793.3)	(2.8%)

The ELCC volatility also affects the reliability requirement calculation. Table 5-17 shows the reliability requirement calculation for the 2025/2026 RPM Base Residual Auction and the update for the Third Incremental Auction for 2025/2026. The pool wide accredited UCAP factor for the Third IA is based on the January 23, 2025, ELCC ratings which use the PJM 2024 load forecast model. These updated ELCC ratings reduced the pool wide accredited

UCAP factor from 0.7969 to 0.7963. The reliability requirement and the FRR obligation both increase, resulting in an increase of 395.7 MW (UCAP) to the reliability requirement adjusted for FRR. PJM needs to procure an additional 395.7 MW (UCAP) of capacity in the Third Incremental Auction.

Table 5-17 PJM Reliability Requirement^{139 140 141}

	2025/2026 Base Residual Auction	2025/2026 Third Incremental Auction	Change
ICAP	191,693.0	188,920.0	(2,773.0)
Solved Load	160,624.0	158,357.0	(2,267.0)
Installed Reserve Margin	17.800%	17.800%	0.0%
Accredited UCAP	152,765.0	150,438.0	(2,327.0)
Pool Wide Accredited UCAP Factor	0.797	0.796	(0.001)
Forecast Pool Requirement	0.939	0.938	(0.001)
Preliminary Forecast Peak Load	153,883.0	154,534.1	651.0
Reliability Requirement	144,450.0	144,953.0	503.0
Fixed Resource Requirement (FRR)	10,886.4	10,993.7	107.3
Reliability Requirement Adjusted for FRR	133,563.6	133,959.3	395.7

PJM filed tariff changes that transfer risk caused by the volatile ELCC ratings from generation owners to the load. ELCC ratings may increase or decrease significantly between the time a generator clears in the RPM Base Residual Auction and the final ELCC rating just prior to the start of the delivery year. Under the new tariff rules, generators will be excused from paying the Capacity Resource Deficiency Charge for a deficiency caused by a decrease in the final ELCC rating. Under the prior rules, a Capacity Market Seller was required to cover its short position by acquiring additional capacity or pay a deficiency penalty equal to 20 percent of the base residual auction clearing price for each MW of shortage. The tariff change was filed by PJM on April

18, 2025, and approved by FERC on June 17, 2025.^{142 143} The MMU opposed the change because the new rule does not mitigate the risk as asserted by PJM but simply transfers the ELCC rating volatility risk to the load.¹⁴⁴ The change is inconsistent with basic market logic under which investors bear the risk associated with the ownership of generation. The new rules are effective beginning with the 2026/2027 Delivery Year.

PJM has calculated and posted marginal ELCC ratings on 11 occasions for the 2025/2026 through 2028/2029 Delivery Years. Figure 5-5 shows the ELCC class ratings for intermittent resources. The horizontal axis shows the delivery year to which the ratings apply and the month the ratings were posted. The ratings change each time they are recalculated. The original rating for onshore wind for the 2025/2026 Delivery Year was 21 percent and the final rating for 2025/2026 Delivery Year was 38 percent, an 80.9 percent increase. The onshore wind rating for the 2027/2028 Delivery Year is 41 percent, a 95.2 percent increase over the initial 2025/2026 rating. Solar has decreased. Solar with tracking technology has decreased from the initial 2025/2026 rating of 25 percent to 8 percent for the 2027/2028 Delivery Year, a 68.0 percent decrease. Solar with fixed panels has decreased 53.3 percent over the same period.

¹³⁸ PJM stated that the 2024 load forecast model was used because it is the "most recently finalized PJM load forecast." The January 23, 2025, ELCC Ratings are based on the PJM 2024 load forecast model. The December 31, 2024, ELCC Ratings are based on an interim PJM 2025 load forecast model.

¹³⁹ *2025/2026 RPM 3rd Incremental Auction Planning Parameters*, PJM Interconnection L.L.C. (January 31, 2025) <<https://www.pjm.com/markets-and-operations/rpm>>.

¹⁴⁰ *Installed Reserve Margin (IRM), Forecast Pool Requirement (FPR), and Effective Load Carrying Capability (ELCC) for BRA at 15, Item 5*, PJM Markets & Reliability Committee meeting, PJM Interconnection L.L.C. (March 20, 2024). <<https://www.pjm.com/committees-and-groups/committees/mrc>>.

¹⁴¹ *Installed Reserve Margin (IRM), Forecast Pool Requirement (FPR), and Effective Load Carrying Capability (ELCC) for 3IA at 7, Item 3*, PJM Members Committee meeting, PJM Interconnection L.L.C. (January 23, 2025). <<https://www.pjm.com/committees-and-groups/committees/mc>>.

¹⁴² *Proposal to Mitigate Impacts From Updates to ELCC Accreditation between the Base Residual Auction and the Final ELCC Accreditation Values*, PJM Interconnection L.L.C., Docket ER25-2002 (April 18, 2025).

¹⁴³ 191 FERC ¶ 61,203 (June 17, 2025).

¹⁴⁴ See *Comments of the Independent Market Monitor for PJM* (May 9, 2025), *Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM* (June 9, 2025), *Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM* (June 16, 2025), Docket ER25-2002-000.

Figure 5-5 Marginal ELCC Class Ratings for Intermittent Resources





Figure 5-6 shows the ELCC rating for thermal resources. Combined cycle resource and combustion turbine ratings have decreased from their initial 2025/2026 ratings. The original rating for combined cycle resources for the 2025/2026 Delivery Year was 87 percent and the final rating for 2025/2026 Delivery Year was 78 percent, a 10.3 percent decrease. The combined cycle rating for the 2027/2028 Delivery Year is 74 percent, a 14.9 percent decrease over the initial 2025/2026 rating. Combustion turbine ratings have also decreased. Ratings for combustion turbines with dual fuel capability have decreased from the initial 2025/2026 rating of 90 percent to 77 percent for the 2027/2028 Delivery Year, a 14.4 percent decrease. Ratings for combustion turbines without dual fuel capability have decreased 17.6 percent over the same period. The change in UCAP for combined cycle and combustion turbine resources from the initial 2025/2026 ELCC ratings to the latest 2027/2028 ratings is a decrease of 11.5 GW. The corresponding change in ICAP is a decrease of 1.2 GW.

PJM could partially offset this loss of capacity in the short run by recognizing the winter capability of thermal resources rather than limiting such resources to summer ratings. Most of the risk recognized in the ELCC model is winter risk but the ELCC accreditation values for thermal resources are capped at the summer ratings. That unnecessarily limits supply and changes the ELCC values for all other resources and changes the system accredited unforced capacity and therefore AUCAP, the maximum level of load that can be served by the existing resources and therefore the reliability requirement. The CIRs of such resources are currently limited by the summer ratings but those rules can and should be changed given the use of the ELCC approach. There is no reason that excess winter CIRs cannot be assigned to these resources immediately.


Figure 5-6 Marginal ELCC Class Ratings for Thermal Resources



Marginal ELCC ratings for storage and demand response resources have also exhibited volatility. Figure 5-7 shows that the storage resource ratings

have decreased. On average across all durations, storage ELCC ratings have decreased 20.4 percent from the initial 2025/2026 Delivery Year ratings to the 2027/2028 Delivery Year ratings. The initial rating for demand response for the 2025/2026 Delivery Year was 95 percent and final rating for the 2025/2026 Delivery Year was 77 percent, an 18.9 percent decrease. Due to recent rule change, the demand response rating for the 2027/2028 Delivery Year is 92 percent.¹⁴⁵

Figure 5-7 Marginal ELCC Class Ratings for Storage and Demand Resources



145 191 FERC ¶61,103 (May 5, 2025).

Market Conduct

Offer Caps

Market power mitigation measures were applied to capacity resources such that the sell offer was set equal to the defined offer cap when the capacity market seller failed the market structure test for the auction, the submitted sell offer exceeded the defined offer cap, and the submitted sell offer, absent mitigation, would have increased the market clearing price.^{146 147 148} For Capacity Performance Resources, for RPM auctions prior to September 2, 2021, offer caps were defined in the PJM Tariff as the applicable zonal Net Cost of New Entry (CONE) times (B) where B is the average of the Balancing Ratios (B) during the Performance Assessment Hours in the three consecutive calendar years that precede the base residual auction for such delivery year, unless net avoidable costs exceed this level, or opportunity costs based on the potential sale of capacity in an external market exceed this level. The Commission issued an order eliminating the prior offer cap and establishing a competitive market seller offer cap set at Net ACR, effective September 2, 2021.¹⁴⁹ The Commission rejected an attempt by PJM to undermine the Market Seller Offer Cap rules by order issued February 6, 2024.¹⁵⁰ The Commission approved changes to the Market Seller Offer Cap that allow Capacity Market Sellers to offer the higher of the net ACR and the Capacity Performance Quantifiable Risk (CPQR)¹⁵¹ and to submit resource specific segmented offer caps.¹⁵² Both changes to the Market Seller Offer Cap give Capacity Market Sellers the ability to offer in excess of the competitive offer and exercise market power as a result.

For RPM Third Incremental Auctions prior to September 2, 2021, capacity market sellers may elect an offer cap equal to the greater of the Net CONE for

146 See OATT Attachment DD § 6.5.

147 Prior to November 1, 2009, existing DR and EE resources were subject to market power mitigation in RPM Auctions. See 129 FERC ¶ 61,081 at P 30 (2009).

148 Effective January 31, 2011, the RPM rules related to market power mitigation were changed, including revising the definition for Planned Generation Capacity Resource and creating a new definition for Existing Generation Capacity Resource for purposes of the must offer requirement and market power mitigation, and treating a proposed increase in the capability of a Generation Capacity Resource the same in terms of mitigation as a Planned Generation Capacity Resource. See 134 FERC ¶ 61,065 (2011).

149 176 FERC ¶ 61,137 (2021), *order denying reh'g*, 178 FERC ¶ 61,121 (2022), *appeal denied*, EPSA, et al. v. FERC, Case No. 21-1214, et al. (DC Cir. October 10, 2023), *cert. denied*.

150 186 FERC ¶ 61,097, *reh'g denied*, 187 FERC ¶ 62,016 (2024).

151 190 FERC ¶ 61,117 (February 20, 2025).

152 *Id.* at 123.

the relevant LDA and delivery year or 1.1 times the BRA clearing price for the relevant LDA and delivery year. For RPM Third Incremental Auctions after September 2, 2021, capacity market sellers may elect an offer cap of 1.1 times the BRA clearing price for the relevant LDA and delivery year.

Avoidable costs are costs that are neither short run marginal costs, like fuel or consumables, nor fixed costs like depreciation and rate of return. Avoidable costs are the costs that a generation owner incurs as a result of operating a generating unit for one year, in particular the delivery year.¹⁵³ As a result, the tariff defines avoidable costs as the costs that a generation owner would not incur if the generating unit did not offer for one year. Although the term mothball is used in the tariff to modify the term ACR, the term mothball is not defined in the tariff. Mothball is an informal term better understood as a metaphor for the cost to operate for one year. Avoidable costs are the costs to operate the unit for one year, regardless of whether the unit plans to retire. Although the tariff includes different mothball and retirement values, the distinction is based on a misunderstanding of the meaning of avoidable costs and should be eliminated. PJM never explained exactly how it calculated mothball and retirement avoidable cost levels. The MMU recommends that major maintenance costs be included in the definition of avoidable costs and removed from energy offers because such costs are avoidable costs and not short run marginal costs.¹⁵⁴ The tariff states that avoidable costs may also include annual capital recovery associated with investments required to maintain a unit as a Generation Capacity Resource, termed Avoidable Project Investment Recovery (APIR), despite the fact that these are not actually avoidable costs, particularly after the first year.

Avoidable cost based offer caps are defined to be net of revenues from all other PJM markets and unit-specific bilateral contracts, including RECs, and expected bonus performance payments/nonperformance charges.¹⁵⁵ Capacity resource owners could provide ACR data by providing their own unit-specific data or, for auctions for delivery years prior to 2020/2021 and auctions held

¹⁵³ OATT Attachment DD § 6.8(b).

¹⁵⁴ *PJM Interconnection LLC, Docket Nos. ER19-210-000 and EL19-8-000, Responses to Deficiency Letter re: Major Maintenance and Operating Costs Recovery* (February 14, 2019).

¹⁵⁵ For details on the competitive offer of a capacity performance resource, see "Analysis of the 2023/2024 RPM Base Residual Auction," <https://www.monitoringanalytics.com/reports/Reports/2022/IMM_Analysis_of_the_20232024_RPM_Base_Residual_Auction_20221028.pdf> (October 28, 2022).

after September 2, 2021, by selecting the default ACR values. The specific components of avoidable costs are defined in the PJM tariff.¹⁵⁶

Effective for the 2018/2019 and subsequent delivery years, the ACR definition includes two additional components, Avoidable Fuel Availability Expenses (AFAE) and Capacity Performance Quantifiable Risk (CPQR).¹⁵⁷ AFAE is available for Capacity Performance Resources. AFAE is defined to include expenses related to fuel availability and delivery. CPQR is available for Capacity Performance Resources and, for the 2018/2019 and 2019/2020 Delivery Years, Base Capacity Resources. CPQR is defined to be the quantifiable and reasonably supported cost of mitigating the risks of nonperformance associated with submission of an offer.

The opportunity cost option allows capacity market sellers to offer based on a documented price available in a market external to PJM, subject to export limits. If the relevant RPM market clears above the opportunity cost, the generation capacity resource is sold in the RPM market. If the opportunity cost is greater than the clearing price and the generation capacity resource does not clear in the RPM market, it is available to sell in the external market.

Effective with the 2026/2027 Delivery Year, the market seller offer cap definition was modified to include unit specific standalone Capacity Performance Quantifiable Risk (CPQR) and segmented unit specific offer caps.¹⁵⁸ For standalone CPQR, the offer cap is defined as the unit specific CPQR with no net revenue offset applied. For segmented unit specific offer caps, the capacity market seller can request that the first segment of the segmented unit specific offer cap be based on either unit specific standalone CPQR or net unit specific ACR. The remaining segments from the second segment up to the tenth segment are defined to be based on standalone CPQR.¹⁵⁹

Allowing offers based on gross CPQR when net revenues are greater than total gross ACR, including CPQR, permits offers greater than the competitive level by allowing resources with a competitive offer of \$0 per MW-day to make positive offers equal to one component of ACR, the gross CPQR component,

¹⁵⁶ OATT Attachment DD § 6.8(a).

¹⁵⁷ 151 FERC ¶ 61,208 (2015).

¹⁵⁸ 190 FERC ¶ 61,117 (2025).

¹⁵⁹ OATT Attachment DD § 6.4(e).

ignoring net revenues entirely. The rule also permits offers greater than the competitive level by allowing resources with a competitive offer greater than \$0 per MW-day but less than gross CPQR to make offers equal to one standalone component of ACR, the gross CPQR component, also ignoring net revenues entirely.

The decision to allow segmented offer caps means allowing the exercise of market power. This is the case first because the segmented offer caps require that all avoidable costs be spread over a first MW segment that is smaller than the full resource, thus inflating the MSOC, and allow offer caps for all segments after the first segment based on gross CPQR with no net revenue offsets. If avoidable costs can be assigned to the first, self defined MW offer segment, and the later MW segments are not defined in the rules, MSOCs are meaningless. Assigning gross CPQRs and no net revenues to one or more undefined MW tail blocks would permit offers that exceed the correctly calculated MSOC by multiples and would permit the exercise of market power. The rule does not use any net revenue offset for the CPQR segments. The competitive level is defined as total gross avoidable costs, net of net revenues, divided by the total MW in the offer.

On October 17, 2024, the Commission issued a final rule, Order No. 904, eliminating separate payments for reactive in all jurisdictional markets, including PJM.¹⁶⁰ As a result, effective with the 2026/2027 Delivery Year, reactive revenues are not included in the net revenue offset for RPM purposes including the VRR curve, market seller offer caps, and MOPR floors.¹⁶¹

Competitive Offers

The competitive offer of a capacity resource is based, regardless of tariff requirements, on a market seller's expectations of the resource's net going forward costs (net ACR) which are the net of the resource's gross ACR and the resource's forward looking net revenues. The gross ACR includes the cost to mitigate the resource's risk of incurring performance assessment penalties (CPQR).

¹⁶⁰ *Compensation for Reactive Power within the Standard Power Factor Range*, Order No. 904, 189 FERC ¶ 61,034 (2024) ("Order No. 904").

¹⁶¹ See Letter Order, FERC Docket No. ER25-682-001 (April 29, 2025).

The competitive offer is based on a forward looking energy and ancillary services (E&AS) net revenue offset rather than the backward looking E&AS net revenue offset currently in the tariff. Forward prices for energy prices and fuel prices are a better guide to market expectations than historical energy and fuel prices but both sources of information should be incorporated. This is particularly important in years, like 2022, when there is a significant change from the historical level of energy market prices. The forward curves reflect this change, but the historical prices do not. However, the PJM method for calculating forward looking net revenues is significantly flawed and overestimates net revenues.

PJM had a forward looking net revenue calculation in the tariff that applied to RPM Auctions for the 2022/2023 Delivery Year.¹⁶² FERC subsequently reversed its approval of that method as part of rejecting PJM's ORDC filing.¹⁶³ PJM's method for calculating forward looking E&AS net revenues was flawed for several reasons. PJM's method included an adjustment based on the prices of long term FTRs for the planning period closest in time to the delivery year which requires an adjustment for monthly average day-ahead congestion price differentials and an adjustment for loss component differentials of historical LMPs. Use of the adjustment based on the prices of long term FTRs adds unnecessary complexity, fails to make the result more accurate, makes the results less transparent, and in some cases make the results less accurate. PJM's use of long term FTRs in the forward energy market price calculation does not use the FTR auction for the desired delivery year as a result of the timing of capacity auctions and FTR auctions when PJM is on its defined three year capacity market auction schedule. It would be simpler, more accurate and more transparent to use forward LMPs calculated using real-time monthly on and off peak forward prices for the delivery year at the PJM Western Hub, adjusted to the zone and hour using the historical zonal, nodal and hourly real-time price differentials for each of the last three years. The MMU and PJM have been implementing this method for years in the calculation of the

¹⁶² 171 FERC ¶ 61,153 (May 21, 2020) and 173 FERC ¶ 61,134 (November 12, 2020).

¹⁶³ Forward energy and ancillary services (E&AS) revenue offsets were applicable from November 12, 2020, as approved in the FERC Order on compliance in Docket Nos. EL19-58-002 and EL19-58-003 until December 22, 2021, when the Commission issued an Order on Voluntary Remand in Docket Nos. EL19-58-006 and ER19-1486-003 reversing its prior determination that PJM should use a forward looking energy E&AS revenue offset and directing PJM to submit a compliance filing restoring the tariff provisions defining the historical E&AS revenue offset.

opportunity costs associated with environmental limits on the operation of generating units.¹⁶⁴

More fundamentally, PJM's forward looking net revenue calculation tends to overestimate forward net revenues. The PJM method is based on a theoretical, unit by unit perfect dispatch based on unit parameters and forward fuel costs and LMPs. The PJM method fails to account for the realities of committing and dispatching units. Nonetheless, it remains correct that generation owners look forward and not backwards when calculating net revenues. The goal is an approach that retains the reality of historical commitment and dispatch while recognizing that future conditions will be different. A better approach would calculate unit forward looking expected energy and ancillary services net revenues using historical revenues that are scaled based on a comparison of forward prices for energy and fuel to the historical prices for energy and fuel.

The competitive offer of a capacity resource is based on a market seller's expectations of market variables during the delivery year, the impact of these variables on the resource's risk, and the cost to mitigate that risk. These market variables are: the number of performance assessment intervals (PAI) in a delivery year where the resource is located; the level of performance required to meet its capacity obligation during those performance assessment intervals, measured as the average Balancing Ratio (B); and the level of the bonus performance payment rate (CPBR) compared to the nonperformance charge rate (PPR). The total capacity revenues earned by a resource are the sum of revenues earned in the forward capacity auctions and additional bonus revenues earned (or penalties paid) during the delivery year, which are a function of unit performance during PAI (A). The level of the bonus performance payment rate depends on the level of underperforming MW net of the underperforming MW excused by PJM during performance assessment intervals for reasons defined in the PJM OATT.¹⁶⁵

The September 2, 2021, Commission order addressed the definition of the market seller offer cap by eliminating the net CONE times B offer cap

and establishing a competitive market seller offer cap of net ACR.¹⁶⁶ The Commission rejected a more recent attempt by PJM to undermine the Market Seller Offer Cap rules by order issued February 6, 2024.¹⁶⁷

In February 2025, PJM filed, and FERC approved, changes to the Market Seller Offer Cap that allow Capacity Market Sellers to offer the higher of the net ACR and the Capacity Performance Quantifiable Risk (CPQR).¹⁶⁸ The changes also allow Capacity Market Sellers to submit resource specific segmented offer caps.¹⁶⁹ Both changes to the Market Seller Offer Cap give Capacity Market Sellers the ability to offer in excess of the competitive offer.

Allowing offers based on gross CPQR when net revenues are greater than total gross ACR, including CPQR, permits offers greater than the competitive level by allowing resources with a competitive offer of \$0 per MW-day to make positive offers equal to one component of ACR, the gross CPQR component, ignoring net revenues entirely. The rule also permits offers greater than the competitive level by allowing resources with a competitive offer greater than \$0 per MW-day but less than gross CPQR to make offers equal to one standalone component of ACR, the gross CPQR component, also ignoring net revenues entirely.

The decision to allow segmented offer caps means allowing the exercise of market power. This is the case first because the segmented offer caps require that all avoidable costs be spread over a first MW segment that is smaller than the full resource, thus inflating the MSOC, and allow offer caps for all segments after the first segment based on gross CPQR with no net revenue offsets. If avoidable costs can be assigned to the first, self defined MW offer segment, and the later MW segments are not defined in the rules, MSOCs are meaningless. Assigning gross CPQRs and no net revenues to one or more undefined MW tail blocks would permit offers that exceed the correctly calculated MSOC by multiples and would permit the exercise of market power. The rule does not use any net revenue offset for the CPQR segments. The

¹⁶⁶ 176 FERC ¶ 61,137 (2021), *order denying reh'g*, 178 FERC ¶ 61,121 (2022), *appeal denied*, EPSA, et al. v. FERC, Case No. 21-1214, et al. (DC Cir. October 10, 2023).

¹⁶⁷ 186 FERC ¶ 61,097, *reh'g denied*, 187 FERC ¶ 62,016 (2024).

¹⁶⁸ 190 FERC ¶ 61,117 (February 20, 2025).

¹⁶⁹ *Id.* at 123.

¹⁶⁴ See "PJM Manual 15: Cost Development Guidelines," § 12.7 IMM Opportunity Cost Calculator, Rev. 47 (Oct. 1, 2025).

¹⁶⁵ OATT Attachment DD § 10A (d).

competitive level is defined as total gross avoidable costs, net of net revenues, divided by the total MW in the offer.

2026/2027 RPM Third Incremental Auction

As shown in Table 5-18, 985 generation resources submitted Capacity Performance offers in the 2026/2027 RPM Third Incremental Auction. Unit specific offer caps were calculated for four generation resources (0.4 percent). Of the 985 generation resources, 816 generation resources elected the offer cap option of 1.1 times the BRA clearing price (82.8 percent), four generation resource had unit specific ACR based offer caps (0.4 percent), 13 Planned Generation Capacity Resources had uncapped offers (1.3 percent), and the remaining 152 generation resources were price takers (15.4 percent). Market power mitigation was applied to zero Capacity Performance sell offers.

Table 5-18 ACR statistics: RPM auctions held in first quarter, 2026

Offer Cap/Mitigation Type	2026/2027 Third Incremental Auction	
	Number of Generation Resources	Percent of Generation Resources Offered
Default ACR	0	0.0%
Unit specific ACR (APIR)	4	0.4%
Unit specific ACR (APIR and CPQR)	0	0.0%
Unit specific ACR (non-APIR)	0	0.0%
Unit specific ACR (non-APIR and CPQR)	0	0.0%
Unit specific standalone CPQR	NA	NA
Unit specific segmented offer caps	NA	NA
Opportunity cost input	0	0.0%
Default ACR and opportunity cost	0	0.0%
Offer cap of 1.1 times BRA clearing price elected	816	82.8%
Uncapped planned uprate and default ACR	0	0.0%
Uncapped planned uprate and opportunity cost	0	0.0%
Uncapped planned uprate and price taker	0	0.0%
Uncapped planned uprate and 1.1 times BRA clearing price elected	0	0.0%
Uncapped planned generation resources	13	1.3%
Existing generation resources as price takers	152	15.4%
Total Generation Capacity Resources offered	985	100.0%

MOPR

By order issued December 19, 2019, the RPM Minimum Offer Price Rule (MOPR) was modified.¹⁷⁰ The rules applying to natural gas fired capacity resources without state subsidies were retained. The changes included expanding the MOPR to new or existing state subsidized capacity resources; establishing a competitive exemption for new and existing resources other than natural gas fired resources while also allowing a resource specific exception process for those that do not qualify for the competitive exemption; defining limited categorical exemptions for renewable resources participating in renewable portfolio standards (RPS) programs, self supply, DR, EE, and capacity storage; defining the region subject to MOPR for capacity resources with state subsidy as the entire RTO; and defining the default offer price floor for capacity resources with state subsidies as 100 percent of the applicable Net CONE or net ACR values.

On September 29, 2021, PJM's FPA section 205 filing in Docket No. ER21-2582-000 revising the Minimum Offer Price Rule (MOPR) was made effective by operation of law.¹⁷¹ The revised MOPR in OATT Attachment DD § 5.14(h-2) became effective for RPM auctions for the 2023/2024 and subsequent delivery years. Under the revised MOPR, a generation resource would be subject to an offer floor if the capacity is deemed to meet the definition of Conditioned State Support or if the capacity market seller plans to use the resource to exercise Buyer-Side Market Power as the term is defined in the tariff through either self certification or a fact specific review initiated by the MMU or PJM. Whether a state program or policy qualifies for Conditioned State Support would be the result of a Commission determination.

The PJM markets would be better off, more competitive, and more efficient with no MOPR than with PJM's approach. PJM's proposal effectively eliminated the MOPR while creating a confusing and inefficient administrative process that effectively makes it both unnecessary and impossible to prove buyer side market power as PJM has defined it.¹⁷²

¹⁷⁰ 169 FERC ¶ 61,239 (2019), *order denying reh'g*, 171 FERC ¶ 61,035 (2020), *aff'd* PJM Power Providers Group, et al. v. FERC, Case No. 21-3068 (3rd Cir. December 1, 2023), *cert denied*.

¹⁷¹ *PJM Interconnection, LLC*, Notice of Filing Taking Effect by Operation of Law, Docket No. ER21-2582 (September 29, 2021).

¹⁷² See Protest of the Independent Market Monitor for PJM, Docket No. ER21-2582-000 (August 20, 2021); Answer and Motion for Leave to Answer of the Independent Market Monitor for PJM, Docket No. ER21-2582-000 (September 22, 2021).

The current form of the MOPR has no meaningful impact. The only function the current MOPR is serving now is to create unnecessary administrative work in the application and compliance screening and to create barriers to entry for generation resources. Generation resources that miss a certification deadline to check a box that they are not receiving state conditioned support and will not exercise market power are then required to offer at uncompetitive net CONE levels or are not allowed to offer because the applicable MOPR floor exceeds the offer cap or no default MOPR floor for the technology is defined. Absent a meaningful change to MOPR, the MMU recommends eliminating the MOPR.

MOPR Statistics

Under the applicable MOPR rules, market power mitigation measures were applied to MOPR Screened Generation Resources such that the sell offer is set equal to the MOPR Floor Offer Price when the submitted sell offer is less than the MOPR Floor Offer Price and an exemption or exception was not granted, or the sell offer is set equal to the agreed upon minimum level of sell offer when the sell offer is less than the agreed upon minimum level of sell offer based on a Unit-Specific Exception or Resource-Specific Exception.

As shown in Table 5-19, there were no unit specific exception requests for MOPR under OATT Attachment DD § 5.14(h-2) for the 2025/2026 RPM Third Incremental Auction. Of the 14.7 MW offered in the 2026/2027 RPM Third Incremental Auction that were subject to MOPR, 14.6 MW cleared and 0.1 MW did not clear.

Table 5-19 MOPR statistics: RPM auctions held in first quarter, 2026

	MOPR Type	Calculation Type	Number of Requests	ICAP (MW)			UCAP (MW)	
				Requested	MMU Agreed	Offered	Offered	Cleared
2026/2027 Third Incremental Auction	OATT Attachment DD § 5.14(h-2)	Unit Specific Exception	0	0.0	0.0	0.0	0.0	0.0
	OATT Attachment DD § 5.14(h-2)	Default	NA	NA	NA	63.8	14.7	14.6
	Total		0	0.0	0.0	63.8	14.7	14.6

Replacement Capacity¹⁷³

When a capacity resource is not available for a delivery year, the owner of the capacity resource may purchase replacement capacity. Replacement capacity is the vehicle used to offset any reduction in capacity from a resource which is not available for a delivery year. But the replacement capacity mechanism may also be used to manipulate the market.

Table 5-20 shows the committed and replacement capacity for all capacity resources for June 1 of each year from 2007 through 2027.

Sellers of demand resources in RPM auctions disproportionately replace those commitments on a consistent basis compared to sellers of other resource types. External generation and internal generation not in service had high rates of replacement in some years and those are also of concern.

The dynamic that can result is that the speculative DR suppresses prices in the BRA and displaces physical generation assets. Those generation assets then have an incentive to offer at a low price, including offers at zero and below cost, in IAs in order to ensure some capacity market revenue for long lived physical

¹⁷³ For more details on replacement capacity, see "Analysis of Replacement Capacity for RPM Commitments: June 1, 2007 to June 1, 2019," <http://www.monitoringanalytics.com/reports/Reports/2019/IMM_Analysis_of_Replacement_Capacity_for_RPM_Commitments_June_1_2007_to_June_1_2019_20190913.pdf> (September 13, 2019).

resources which the owners expect to maintain for multiple years. The result is lower IA prices which permit the buyback of the speculative DR at prices below the BRA prices which encourages the greater use of speculative DR.

PJM's sale of capacity in IAs at very low prices, given that PJM announces the MW quantity and the sell offer price in advance of the auctions, further reduces IA prices and increases the incentive of DR sellers to speculate in the BRAs. The MMU recommends that if PJM sells capacity in incremental auctions, PJM should offer the capacity for sale at the BRA clearing price in order to avoid suppressing the IA price below the competitive level. If the PJM sell offer price is not the BRA clearing price, PJM should not reveal its proposed sell offer price or the MW quantity to be sold prior to the auction.

It has been asserted that selling at a high price in the BRA and buying back at a low price in the IA is just a market transaction and therefore does not constitute a problem. But permitting DR to be an option in the BRA rather than requiring DR to be a commitment to provide a physical asset gives DR an unfair advantage and creates a self fulfilling dynamic that incents more of the same behavior. Only DR is permitted to be an option in the BRA. Generation resources must have met physical milestones in order to offer in the BRA. It is not reasonable to permit DR capacity resources to have a different product definition than generation capacity resources. Even if DR is treated as an annual product, this unique treatment as an option makes DR an inferior resource and not a complete substitute for generation resources. The current approach to DR is also inconsistent with the history of the definition of capacity in PJM, which has always been that capacity is physical and unit specific. The current approach to DR effectively makes DR a virtual participant in the PJM Capacity Market. That option should be eliminated.

The definition of demand side resources in PJM capacity markets is flawed in a variety of ways. The current demand side definition should be replaced with a definition that includes demand on the demand side of the market. There are ways to ensure and enhance the vibrancy of demand side without negatively affecting markets for generation.

Table 5-20 RPM commitments and replacements for all Capacity Resources: June 1, 2007 to June 1, 2027

	UCAP (MW)					RPM
	RPM Cleared	Adjustments to Cleared	Net Replacements	RPM Commitments	RPM Commitment Shortage	Commitments Less Commitment Shortage
01-Jun-07	129,409.2	0.0	0.0	129,409.2	(8.1)	129,401.1
01-Jun-08	130,629.8	0.0	(766.5)	129,863.3	(246.3)	129,617.0
01-Jun-09	134,030.2	0.0	(2,068.2)	131,962.0	(14.7)	131,947.3
01-Jun-10	134,036.2	0.0	(4,179.0)	129,857.2	(8.8)	129,848.4
01-Jun-11	134,182.6	0.0	(6,717.6)	127,465.0	(79.3)	127,385.7
01-Jun-12	141,295.6	(11.7)	(9,400.6)	131,883.3	(157.2)	131,726.1
01-Jun-13	159,844.5	0.0	(12,235.3)	147,609.2	(65.4)	147,543.8
01-Jun-14	161,214.4	(9.4)	(13,615.9)	147,589.1	(1,208.9)	146,380.2
01-Jun-15	173,845.5	(326.1)	(11,849.4)	161,670.0	(1,822.0)	159,848.0
01-Jun-16	179,773.6	(24.6)	(16,157.5)	163,591.5	(924.4)	162,667.1
01-Jun-17	180,590.5	0.0	(13,982.7)	166,607.8	(625.3)	165,982.5
01-Jun-18	175,996.0	0.0	(12,057.8)	163,938.2	(150.5)	163,787.7
01-Jun-19	177,064.2	0.0	(12,300.3)	164,763.9	(9.3)	164,754.6
01-Jun-20	174,023.8	(335.3)	(10,582.7)	163,105.8	(5.7)	163,100.1
01-Jun-21	174,713.0	0.0	(12,963.3)	161,749.7	(316.9)	161,432.8
01-Jun-22	150,465.2	0.0	(5,576.9)	144,888.3	(1,212.7)	143,675.6
01-Jun-23	150,143.9	0.0	(5,517.6)	144,626.3	(2,363.5)	142,262.8
01-Jun-24	154,362.5	0.0	(4,046.2)	150,316.3	(4,377.2)	145,939.1
01-Jun-25	137,733.6	0.0	(1,812.6)	135,921.0	(934.8)	134,986.2
01-Jun-26	137,803.1	0.0	(1,291.5)	136,511.6	0.0	136,511.6
01-Jun-27	134,478.1	0.0	0.0	134,478.1	0.0	134,478.1

Market Performance

Figure 5-8 shows cleared MW weighted average capacity market prices on a delivery year basis including base and incremental auctions for each delivery year, and the weighted average clearing prices by LDA in each Base Residual Auction for the entire history of the PJM capacity markets.

Table 5-21 shows RPM clearing prices for the 2021/2022 through 2027/2028 Delivery Years for all RPM auctions held through 2025, and Table 5-22 shows the RPM cleared MW for the 2021/2022 through 2027/2028 Delivery Years for all RPM auctions held through the first three months of 2026.

Figure 5-9 shows the RPM cleared MW weighted average prices for each LDA from the 2022/2023 Delivery Year to the current delivery year, and all results for auctions for future delivery years that have been held through the first three months of 2026. A summary of these weighted average prices is given in Table 5-23.

Table 5-24 shows RPM revenue by delivery year for all RPM auctions held through the first three months of 2026 based on the unforced MW cleared and the resource clearing prices. For the 2024/2025 Delivery Year, RPM revenue is \$2.6 billion. For the 2025/2026 Delivery Year, RPM revenue is \$14.9 billion.

Table 5-25 shows RPM revenue by calendar year for all RPM auctions held through 2025. In 2024, RPM revenue is \$2.5 billion. In 2025, RPM revenue is \$9.8 billion.

Table 5-26 shows the RPM annual charges to load. For the 2024/2025 Delivery Year, annual charges to load are \$2.5 billion. For the 2025/2026 Delivery Year, annual charges to load are \$14.8 billion.

Table 5-21 Capacity market clearing prices: 2021/2022 through 2027/2028 RPM Auctions

	Product Type	RPM Clearing Price (\$ per MW-day)																
		RTO	MAAC	APS	PPL	EMAAC	SWMAAC	DPL		PSEG			PEPCO	ATSI	COMED	BGE	DUKE	DOM
2021/2022 BRA	Capacity Performance	\$140.00	\$140.00	\$140.00	\$140.00	\$165.73	\$140.00	\$165.73	\$204.29	\$204.29	\$140.00	\$171.33	\$195.55	\$200.30	\$140.00	\$140.00	\$140.00	\$140.00
2021/2022 First Incremental Auction	Capacity Performance	\$23.00	\$23.00	\$23.00	\$23.00	\$25.00	\$23.00	\$25.00	\$45.00	\$219.00	\$23.00	\$23.00	\$23.00	\$60.00	\$23.00	\$23.00	\$23.00	\$23.00
2021/2022 Second Incremental Auction	Capacity Performance	\$10.26	\$10.26	\$10.26	\$10.26	\$15.37	\$10.26	\$15.37	\$125.00	\$125.00	\$10.26	\$10.26	\$10.26	\$70.00	\$10.26	\$10.26	\$10.26	\$10.26
2021/2022 Third Incremental Auction	Capacity Performance	\$20.55	\$20.55	\$20.55	\$20.55	\$26.36	\$20.55	\$26.36	\$31.00	\$31.00	\$20.55	\$20.55	\$20.55	\$39.00	\$20.55	\$20.55	\$20.55	\$20.55
2022/2023 BRA	Capacity Performance	\$50.00	\$95.79	\$50.00	\$95.79	\$97.86	\$95.79	\$97.86	\$97.86	\$97.86	\$95.79	\$50.00	\$68.96	\$126.50	\$71.69	\$50.00	\$50.00	\$50.00
2022/2023 Third Incremental Auction	Capacity Performance	\$19.00	\$35.00	\$19.00	\$35.00	\$35.00	\$96.15	\$35.00	\$35.00	\$35.00	\$35.00	\$19.00	\$19.00	\$35.00	\$19.00	\$19.00	\$19.00	\$19.00
2023/2024 BRA	Capacity Performance	\$34.13	\$49.49	\$34.13	\$49.49	\$49.49	\$49.49	\$69.95	\$49.49	\$49.49	\$49.49	\$34.13	\$34.13	\$69.95	\$34.13	\$34.13	\$34.13	\$34.13
2023/2024 Third Incremental Auction	Capacity Performance	\$37.53	\$49.49	\$37.53	\$49.49	\$146.03	\$49.49	\$146.03	\$146.03	\$146.03	\$49.49	\$37.53	\$37.53	\$79.03	\$37.53	\$37.53	\$37.53	\$37.53
2024/2025 BRA	Capacity Performance	\$28.92	\$49.49	\$28.92	\$49.49	\$53.60	\$49.49	\$426.17	\$53.60	\$53.60	\$49.49	\$28.92	\$28.92	\$73.00	\$96.24	\$28.92	\$28.92	\$28.92
2024/2025 Third Incremental Auction	Capacity Performance	\$58.00	\$80.00	\$58.00	\$80.00	\$175.81	\$80.00	\$175.81	\$175.81	\$175.81	\$80.00	\$58.00	\$58.00	\$155.29	\$58.00	\$58.00	\$58.00	\$58.00
2025/2026 BRA	Capacity Performance	\$269.92	\$269.92	\$269.92	\$269.92	\$269.92	\$269.92	\$269.92	\$269.92	\$269.92	\$269.92	\$269.92	\$269.92	\$269.92	\$466.35	\$269.92	\$444.26	\$444.26
2025/2026 Third Incremental Auction	Capacity Performance	\$323.90	\$323.90	\$323.90	\$323.90	\$323.90	\$323.90	\$323.90	\$323.90	\$323.90	\$323.90	\$323.90	\$323.90	\$323.90	\$559.64	\$323.90	\$323.90	\$323.90
2026/2027 BRA	Capacity Performance	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17	\$329.17
2026/2027 Third Incremental Auction	Capacity Performance	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70	\$164.70
2027/2028 BRA	Capacity Performance	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44	\$333.44

Table 5-22 Capacity market cleared MW: 2021/2022 through 2027/2028 RPM Auctions¹⁷⁴

Delivery Year	Auction	UCAP (MW)														TOTAL
		RTO	MAAC	APS	PPL	EMAAC	DPL South	PSEG	PSEG North	PEPCO	ATSI	COMED	BGE	DUKE	DOM	
2021/2022	BASE	26,552.8	12,565.1	10,136.1	15,368.6	22,286.8	1,673.8	2,237.7	3,134.1	6,013.2	8,010.5	22,358.1	4,200.7	2,746.1	26,343.7	163,627.3
2021/2022	FIRST	118.7	200.4	45.9	27.2	119.0	15.3	18.3	79.1	207.9	739.3	360.4	48.7	87.6	75.4	2,143.2
2021/2022	SECOND	1,082.0	335.8	30.3	55.4	129.9	39.3	97.0	98.1	75.7	1,216.8	205.9	115.5	65.3	160.5	3,707.5
2021/2022	THIRD	1,243.7	168.7	231.6	127.8	911.0	18.3	227.7	244.8	67.2	942.7	221.7	275.9	159.2	394.7	5,235.0
2022/2023	BASE	29,596.0	12,804.7	10,147.4	14,118.7	23,651.2	1,312.9	1,914.3	2,531.1	3,621.8	10,550.7	19,223.7	4,750.9	2,117.7	8,136.3	144,477.3
2022/2023	THIRD	703.3	338.9	84.2	105.7	572.2	9.4	244.3	402.0	27.4	358.0	2,292.3	409.7	44.8	395.7	5,987.9
2023/2024	BASE	28,642.1	10,098.5	8,145.5	14,352.7	22,912.6	1,412.8	2,497.1	3,344.9	3,521.8	9,535.9	25,368.9	5,001.0	1,966.4	8,266.7	145,066.9
2023/2024	THIRD	255.9	1,786.4	395.0	79.3	671.0	24.2	32.4	43.8	15.3	355.8	1,050.0	240.0	68.4	59.8	5,077.0
2024/2025	BASE	28,760.7	10,854.4	8,874.0	14,178.1	23,135.1	1,448.6	2,665.3	3,494.3	3,429.7	9,720.6	25,156.1	5,056.5	2,062.1	8,646.1	147,481.5
2024/2025	THIRD	365.3	744.8	815.6	665.2	963.0	33.2	48.7	60.2	78.7	245.6	2,370.0	222.5	90.2	177.9	6,881.0
2025/2026	BRA	24,573.1	9,490.1	8,481.3	12,368.8	19,043.0	958.7	1,894.3	2,520.1	2,274.4	7,778.5	21,814.2	2,800.6	1,636.7	20,050.2	135,684.0
2025/2026	THIRD	731.3	22.2	90.8	31.9	564.8	26.1	9.0	34.7	79.4	177.2	91.5	8.3	19.8	162.7	2,049.6
2026/2027	BRA	24,888.5	9,213.7	8,476.5	11,939.7	18,861.0	998.0	1,725.3	2,361.6	2,170.2	7,433.9	20,273.0	4,319.1	1,560.1	19,984.8	134,205.3
2026/2027	THIRD	743.4	197.4	149.4	332.3	247.8	31.9	62.4	75.0	98.6	298.3	544.6	89.9	84.9	641.9	3,597.8
2027/2028	BRA	24,711.5	9,147.3	8,542.9	12,146.5	18,754.7	959.6	1,777.6	2,379.7	2,222.2	7,603.6	19,567.1	4,334.2	2,416.6	19,914.6	134,478.1

174 The MW values in this table refer to rest of LDA or RTO values, which are net of nested LDA values.

Table 5-23 Weighted average clearing prices by zone: 2024/2025 through 2027/2028

LDA	Weighted Average Clearing Price (\$ per MW-day)			
	2024/2025	2025/2026	2026/2027	2027/2028
RTO				
AEP	\$29.80	\$270.57	\$324.96	\$333.44
APS	\$29.80	\$270.57	\$324.96	\$333.44
ATSI	\$29.80	\$271.18	\$321.98	\$333.44
Cleveland	\$28.92	\$270.90	\$325.95	\$333.44
COMED	\$31.42	\$270.15	\$324.87	\$333.44
DAY	\$29.13	\$295.05	\$322.41	\$333.44
DUKE	\$94.57	\$270.57	\$320.68	\$333.44
DUQ	\$29.80	\$270.57	\$324.96	\$333.44
DOM	\$29.80	\$443.29	\$324.05	\$333.44
EKPC	\$29.80	\$270.57	\$324.96	\$333.44
MAAC				
EMAAC				
ACEC	\$58.47	\$271.47	\$327.72	\$333.44
DPL	\$58.47	\$271.47	\$327.72	\$333.44
DPL South	\$420.55	\$271.35	\$324.08	\$333.44
JCPLC	\$58.47	\$271.47	\$322.79	\$333.44
PECO	\$58.47	\$271.47	\$327.72	\$333.44
PSEG	\$55.54	\$270.17	\$323.43	\$333.44
PSEG North	\$55.48	\$270.65	\$324.11	\$333.44
REC	\$58.47	\$271.47	\$327.72	\$333.44
SWMAAC				
BGE	\$77.88	\$466.64	\$324.89	\$333.44
PEPCO	\$50.12	\$271.74	\$322.02	\$333.44
WMAAC				
MEC	\$51.07	\$270.01	\$326.00	\$333.44
PE	\$51.07	\$270.01	\$326.00	\$333.44
PPL	\$51.18	\$270.12	\$323.88	\$333.44

Table 5-24 RPM revenue by delivery year: 2007/2008 through 2027/2028¹⁷⁵

Delivery Year	Weighted Average RPM Price (\$ per MW-day)	Weighted Average Cleared UCAP (MW)	Days	RPM Revenue
2007/2008	\$89.78	129,409.2	366	\$4,252,287,381
2008/2009	\$127.67	130,629.8	365	\$6,087,147,586
2009/2010	\$153.37	134,030.2	365	\$7,503,218,157
2010/2011	\$172.71	134,036.2	365	\$8,449,652,496
2011/2012	\$108.63	134,182.6	366	\$5,335,087,023
2012/2013	\$75.08	141,283.9	365	\$3,871,714,635
2013/2014	\$116.55	159,844.5	365	\$6,799,778,047
2014/2015	\$126.40	161,205.0	365	\$7,437,267,646
2015/2016	\$160.01	173,519.4	366	\$10,161,726,902
2016/2017	\$121.84	179,749.0	365	\$7,993,888,695
2017/2018	\$141.19	180,590.5	365	\$9,306,676,719
2018/2019	\$172.09	175,996.0	365	\$11,054,943,851
2019/2020	\$109.82	177,064.2	366	\$7,116,815,360
2020/2021	\$111.07	173,688.5	365	\$7,041,524,517
2021/2022	\$147.33	174,713.0	365	\$9,395,567,946
2022/2023	\$72.33	150,465.2	365	\$3,972,428,671
2023/2024	\$42.01	150,143.9	366	\$2,308,670,914
2024/2025	\$45.57	154,362.5	365	\$2,567,491,013
2025/2026	\$296.98	137,733.6	365	\$14,930,072,430
2026/2027	\$324.88	137,803.1	365	\$16,340,680,278
2027/2028	\$333.44	134,478.1	366	\$16,411,578,225


175 The results for the ATSI Integration Auctions are not included in this table.

Table 5-25 RPM revenue by calendar year: 2007 through 2028¹⁷⁶

Year	Weighted Average RPM Price (\$ per MW-day)	Weighted Average Cleared UCAP (MW)	Effective Days	RPM Revenue
2007	\$89.78	75,665.5	214	\$2,486,310,108
2008	\$111.93	130,332.1	366	\$5,334,880,241
2009	\$142.74	132,623.5	365	\$6,917,391,702
2010	\$164.71	134,033.7	365	\$8,058,113,907
2011	\$135.14	133,907.1	365	\$6,615,032,130
2012	\$89.01	138,561.1	366	\$4,485,656,150
2013	\$99.39	152,166.0	365	\$5,588,442,225
2014	\$122.32	160,642.2	365	\$7,173,539,072
2015	\$146.10	168,147.0	365	\$9,018,343,604
2016	\$137.69	177,449.8	366	\$8,906,998,628
2017	\$133.19	180,242.4	365	\$8,763,578,112
2018	\$159.31	177,896.7	365	\$10,331,688,133
2019	\$135.58	176,338.6	365	\$8,734,613,179
2020	\$110.55	175,368.7	366	\$7,084,072,778
2021	\$132.33	174,289.2	365	\$8,421,703,404
2022	\$103.36	160,496.5	365	\$6,215,973,960
2023	\$54.56	150,036.3	365	\$2,993,266,921
2024	\$44.09	152,857.8	366	\$2,464,115,790
2025	\$192.97	144,613.0	365	\$9,815,689,432
2026	\$313.34	137,774.3	365	\$15,757,113,743
2027	\$329.90	135,638.2	365	\$16,355,957,867
2028	\$333.44	55,848.8	152	\$6,815,737,405

176 The results for the ATSI Integration Auctions are not included in this table.

Figure 5-8 History of capacity prices: 1999/2000 through 2027/2028¹⁷⁷



177 The 1999/2000 through 2006/2007 capacity prices are CCM combined market, weighted average prices. The 2007/2008 through 2027/2028 capacity prices are RPM weighted average prices. The CCM data points plotted are cleared MW weighted average prices for the daily and monthly markets by delivery year. The RPM data points plotted are RPM LDA clearing prices. For the 2014/2015 and subsequent delivery years, only the prices for Annual Resources or Capacity Performance Resources are plotted.

Figure 5-9 Map of RPM capacity prices: 2024/2025 through 2027/2028




Table 5-26 RPM cost to load: 2021/2022 through 2027/2028 RPM Auctions^{178 179}

	Net Load Price (\$ per MW-day)	UCAP Obligation (MW)	Annual Charges
2021/2022			
Rest of RTO	\$142.16	82,768.3	\$4,294,838,410
Rest of EMAAC	\$164.73	23,719.9	\$1,426,178,211
ATSI	\$160.21	13,995.4	\$818,411,597
BGE	\$163.50	7,491.2	\$447,049,048
COMED	\$198.43	22,721.2	\$1,645,630,168
PSEG	\$188.46	10,987.4	\$755,803,998
Total		161,683.4	\$9,387,911,433
2022/2023			
Rest of RTO	\$50.05	50,750.7	\$927,101,691
EMAAC	\$97.93	35,388.1	\$1,264,867,389
WMAAC	\$96.61	15,072.2	\$531,498,382
BGE	\$108.22	7,457.7	\$294,575,131
COMED	\$66.23	24,064.5	\$581,774,443
DEOK	\$59.75	5,090.6	\$111,011,442
PEPCO	\$96.15	6,870.5	\$241,111,291
Total		144,694.3	\$3,951,939,768
2023/2024			
Rest of RTO	\$34.18	78,896.5	\$986,982,057
EMAAC	\$50.96	30,972.7	\$577,657,195
WMAAC	\$49.58	22,401.9	\$406,535,572
Rest of EMAAC	\$57.19	4,375.0	\$91,582,753
BGE	\$59.38	7,496.6	\$162,936,916
Total		144,142.8	\$2,225,694,492
2024/2025			
Rest of RTO	\$29.50	77,398.7	\$833,520,097
EMAAC	\$56.56	32,270.3	\$666,184,144
WMAAC	\$50.22	22,872.2	\$419,263,035
Rest of EMAAC	\$175.22	4,590.0	\$293,561,344
BGE	\$61.53	7,726.0	\$173,527,700
DEOK	\$57.93	5,254.4	\$111,105,639
Total		150,111.7	\$2,497,161,960
2025/2026			
Rest of RTO	\$270.43	108,328.9	\$10,692,932,080
BGE	\$306.84	6,005.7	\$672,628,585
DOM	\$432.48	21,570.5	\$3,405,010,751
Total		135,905.1	\$14,770,571,416
2026/2027			
Rest of RTO	\$329.08	134,490.7	\$16,154,098,654
Total		134,490.7	\$16,154,098,654
2027/2028			
Rest of RTO	\$333.69	134,478.1	\$16,379,008,974
Total		134,478.1	\$16,379,008,974

¹⁷⁸ The RPM annual charges are calculated using the rounded, net load prices as posted in the PJM RPM auction results.

¹⁷⁹ There is no separate obligation for DPL South as the DPL South LDA is completely contained within the DPL Zone. There is no separate obligation for PSEG North as the PSEG North LDA is completely contained within the PSEG Zone. There is no separate obligation for ATSI Cleveland as the ATSI Cleveland LDA is completely contained within the ATSI Zone.

FRR

The states have authority over their generation resources and can choose to remain in PJM capacity markets or to create FRR entities. The existing FRR approach remains an option for utilities with regulated revenues based on cost of service rates, including both privately and publicly owned (including public power entities and electric cooperatives) utilities. Such regulated utilities have had and continue to have the ability to opt out of the capacity market and provide their own capacity. The existing FRR rules were created in 2007 primarily for the specific circumstances of AEP as part of the original RPM capacity market design settlement. The MMU recommends that the FRR rules be revised and updated to ensure that the rules reflect current market realities and that FRR entities do not unfairly take advantage of those customers paying for capacity in the PJM Capacity Market.

The MMU has prepared reports with analysis of the potential impacts on states pursuing the FRR option. In separate reports for Illinois, Maryland, New Jersey, Ohio, Virginia, and the District of Columbia, the cost impacts of the state choosing the FRR option are computed under different FRR capacity price assumptions and different assumptions regarding the composition of the FRR service area.^{180 181 182 183 184 185} The reports showed that the FRR approach is likely to lead to significant increases in payments by customers if it were to replace participation in the PJM markets. The impact on the remaining PJM capacity market footprint is also computed for each scenario. In all but a few scenarios the MMU finds that the FRR leads to higher costs for load included in the FRR service area. In all scenarios the MMU finds that prices in what remains of the PJM Capacity Market would be significantly lower.

¹⁸⁰ See Monitoring Analytics, LLC, "Potential Impacts of the Creation of a ComEd FRR," <http://www.monitoringanalytics.com/reports/Reports/2019/IMM_Potential_Impacts_of_the_Creation_of_a_ComEd_FRR_20191218.pdf> (December 18, 2020).

¹⁸¹ See Monitoring Analytics, LLC, "Potential Impacts of the Creation of Maryland FRRs," <http://www.monitoringanalytics.com/reports/Reports/2020/IMM_Potential_Impacts_of_the_Creation_of_Maryland_FRRs_20200416.pdf> (April 16, 2020).

¹⁸² See Monitoring Analytics, LLC, "Potential Impacts of the Creation of New Jersey FRRs," <http://www.monitoringanalytics.com/reports/Reports/2020/IMM_Potential_Impacts_of_the_Creation_of_New_Jersey_FRRs_20200513.pdf> (May 13, 2020).

¹⁸³ *In the Matter of the Investigation of Resource Adequacy Alternatives*, New Jersey Board of Public Utilities, Docket No. E020030203. Monitoring Analytics, LLC Comments, <http://www.monitoringanalytics.com/filings/2020/IMM_Comments_Docket_No_E020030203_20200520.pdf> (May 20, 2020). Monitoring Analytics, LLC, Reply Comments <http://www.monitoringanalytics.com/filings/2020/IMM_Reply_Comments_Docket_No_E020030203_20200624.pdf> (June 24, 2020). Monitoring Analytics, Answer to Exelon and PSEG, <http://www.monitoringanalytics.com/filings/2020/IMM_Answer_to_Exelon_PSEG_Docket_No_E020030203_20200715.pdf> (July 15, 2020).

¹⁸⁴ See Monitoring Analytics, LLC, "Potential Impacts of the Creation of Ohio FRRs," <http://www.monitoringanalytics.com/reports/Reports/2020/IMM_Potential_Impacts_of_the_Creation_of_Ohio_FRRs_20200717.pdf> (July 17, 2020).

¹⁸⁵ See Monitoring Analytics, LLC, "Potential Impacts of the Creation of Virginia FRRs," <https://www.monitoringanalytics.com/reports/Reports/2021/IMM_VA_FRR_Report_20210518.pdf> (May 18, 2021).

Both FERC and the states have significant and overlapping authority affecting wholesale power markets. While the FERC MOPR approach was designed to ensure that subsidies did not affect the wholesale power markets, the states have ultimate authority over the generation choices made in the states. The FRR explorations by multiple states illustrated a possible path forward. Under that path, the FERC regulated markets would be unaffected by subsidies but many states would withdraw from the FERC regulated markets and create higher cost nonmarket solutions rather than be limited by MOPR. That would not be an efficient outcome and would not serve the interests of customers or generators.

With the elimination of the prior MOPR rules, the capacity market design must accommodate the choices made by states to subsidize renewable resources in a way that maximizes the role of competition to ensure that customers pay the lowest amount possible, consistent with state goals and the costs of providing the desired resources. Such an approach can take several forms, but none require the dismantling of the PJM capacity market design. The PJM capacity market design can adapt to a wide range of state supported resources and state programs. As a simple starting point, states can continue to support selected resources using a range of payment structures and those resources could participate in the capacity auctions. As a broader and more comprehensive option, PJM could create a central PJM RECs market to facilitate the competitive sale and purchase of RECs.

Dominion Energy Virginia elected the FRR option for the 2022/2023 through 2024/2025 delivery years but returned to the capacity market for the 2025/2026 BRA.

CRF Issue¹⁸⁶

As a result of the significant changes to the federal tax code in December 2017, the capital recovery factor (CRF) tables in PJM OATT Attachment DD § 6.8(a) and Schedule 6A were not correct.¹⁸⁷ These tables should have been updated in 2018. Correct CRFs ensure that offer caps and offer floors in the

¹⁸⁶ See related filing on CRF issue in black start: Comments of the Independent Market Monitor for PJM, Docket No. ER21-1635 (April 28, 2021).

¹⁸⁷ The federal tax code was changed in the Tax Cuts and Jobs Act or TCJA.

capacity market are correct. On May 4, 2021, PJM filed updates to the OATT under FPA Section 205.¹⁸⁸ In the filing, PJM proposed new CRFs based on the new tax law and new financial assumptions. The new financial assumptions are identical to the assumptions used in the PJM quadrennial review for the calculation of the cost of new entry (CONE) for the PJM reference resource. The MMU, in comments to the Commission, asked that the following formula be included in the tariff as an efficient alternative to use of tables which require updates whenever tax laws or financial assumptions change:^{189 190}

The MMU also proposed that PJM discontinue the practice of using an average state tax rate in the CRF calculation. The CRF formula allows for the quick and efficient calculation of a unit's CRF using the state tax rate that is applicable to a specific unit.

FERC accepted PJM's filing but also required that the MMU's CRF formula be included in the tariff.¹⁹¹ FERC rejected the MMU's unit specific state tax recommendation. Going forward, PJM will post the CRFs on their website. Table 5-28 shows the CRFs that are currently posted. The values in Table 5-28 were calculated using the formula above and the financial assumptions in Table 5-29. Bonus depreciation assumptions vary by delivery year with 100 percent bonus depreciation assumed in the 2022/2023 Delivery Year. Under the TCJA, the bonus depreciation in each subsequent delivery year is reduced by 20 percent.

Table 5-27 Variable descriptions for the CRF formula

Formula Symbol	Description
r	After tax weighted average cost of capital (ATWACC)
s	Effective tax rate
B	Bonus depreciation percent
N	Cost Recovery Period (years)
L	Lesser of N or 16 (years)
mj	Modified Accelerated Cost Recovery System (MACRS) depreciation factor for year j = 1, ..., 16

¹⁸⁸ "Revisions to Capital Recovery Factor for Avoidable Project Investment Cost Determinations and Request for Waiver of Sixty-Day Notice Requirement," PJM Interconnection LLC, Docket No. ER21-1844-000 (May 4, 2021).

¹⁸⁹ See "Comments of the Independent Market Monitor for PJM," Docket No. ER21-1844-000 (May 25, 2021).

¹⁹⁰ The formula was first introduced in a related Section 205 filing regarding CRFs for black start service. See "Comments of the Independent Market Monitor for PJM" (April 28, 2021) and "Answer and Motion to Answer of the Independent Market Monitor for PJM" (May 19, 2021) in Docket No. ER21-1635-000.

¹⁹¹ 176 FERC ¶61,003 (2021).

On July 4, 2025, with the enactment of the One Big Beautiful Bill Act (“OBBBA”), the bonus depreciation rules changed again. Section 70301 of OBBBA (I.R.C. § 168(k)) allows 100 percent bonus depreciation for “qualified production property (“QPP”) acquired and placed in service on or after January 20, 2025.¹⁹² QPP means nonresidential real property used in manufacturing, production, or refining of tangible personal property in the United States.¹⁹³ QPP includes power production facilities. To be eligible, construction must begin after January 19, 2025, and before January 1, 2029, and the property must be placed in service before January 1, 2031.¹⁹⁴ Table 5-28 shows the CRF values produced by the CRF formula using the parameter assumptions in Table 5-29. The effect of the change in bonus depreciation rules from the OBBBA is reflected in the CRF for 2027/2028 Third IA. The CRF value for the five year recovery period decreases from 0.314 to 0.249, a 20.7 percent decrease.

Table 5-28 Levelized CRF values: Delivery Year 2023/2024 through Delivery Year 2028/2029

Age of Unit (Years)	Cost Recovery Period	2023/2024	2024/2025	2025/2026	2026/2027	2027/2028 BRA	2027/2028 3rd IA	2028/2029
		Bonus Depreciation Percent						
		80%	60%	40%	20%	0%	100%	100%
1 to 5	30	0.091	0.094	0.096	0.105	0.107	0.093	0.099
6 to 10	25	0.096	0.098	0.101	0.110	0.113	0.098	0.103
11 to 15	20	0.104	0.107	0.110	0.118	0.121	0.105	0.110
16 to 20	15	0.119	0.122	0.126	0.134	0.138	0.120	0.124
21 to 25	10	0.152	0.158	0.164	0.174	0.180	0.151	0.155
25 Plus	5	0.258	0.271	0.283	0.301	0.314	0.249	0.253
Mandatory CapEx	4	0.312	0.328	0.345	0.367	0.383	0.300	0.303
40 Plus Alternative	1	1.100	1.100	1.100	1.100	1.100	1.100	1.100

¹⁹² OBBBA § 70301(c)(1).

¹⁹³ OBBBA § 70307(a)(2).

¹⁹⁴ *Id.*

Table 5-29 Financial parameter and tax rate assumptions for CRF calculations

Parameter	Parameter Values			
	Prior to 2026/2027	2026/2027	2027/2028	2028/2029
Equity Funding Percent	45.000%	45.000%	45.000%	45.000%
Debt Funding Percent	55.000%	55.000%	55.000%	55.000%
Equity Rate	13.000%	14.100%	14.100%	16.000%
Debt Interest Rate	6.000%	6.300%	6.300%	5.800%
Federal Income Tax Rate	21.000%	21.000%	21.000%	21.000%
State Income Tax Rate	9.300%	9.933%	9.933%	8.500%
Effective Income Tax Rate	28.347%	28.847%	28.847%	27.715%
After Tax Weighted Average Cost of Capital	8.215%	8.810%	8.810%	9.506%

The 2021 update to the CRF values was calculated using the weighted average cost of capital (WACC) model. The original CRF values, prior to 2021, were calculated using a flow to equity (FTE) model. The WACC model assumes a constant debt to equity ratio during the capital recovery period and therefore assumes that debt holders are paid more quickly than is required. The FTE model recognizes that the debt is repaid according to a predetermined payment schedule with all revenue in excess of taxes and debt payments going to the equity investor. The FTE model accurately reflects the cash flows that occur during capital recovery. Table 5-30 compares CRFs calculated under the two approaches using the assumptions in Table 5-29. The difference between the WACC CRF and FTE CRF is dependent upon the capital recovery term and the level of bonus depreciation. The WACC CRF exceeds the FTE CRF by 16.4 percent under 100 percent bonus depreciation with a 30 year cost recovery term. The FTE model is the correct approach because it accurately captures the cash flows during capital recovery over the defined financial life of the asset.

Table 5-30 Comparison of FTE and WACC CRFs

Capital Recovery Term (years)	WACC CRF						FTE CRF					
	Bonus Percent						Bonus Percent					
	100%	80%	60%	40%	20%	0%	100%	80%	60%	40%	20%	0%
4	0.32	0.312	0.328	0.345	0.361	0.377	0.289	0.307	0.324	0.342	0.360	0.377
5	0.246	0.258	0.271	0.283	0.296	0.308	0.238	0.252	0.266	0.280	0.294	0.308
10	0.147	0.152	0.158	0.164	0.169	0.175	0.138	0.145	0.153	0.160	0.168	0.175
15	0.116	0.119	0.122	0.126	0.129	0.132	0.105	0.111	0.116	0.122	0.127	0.133
20	0.101	0.104	0.107	0.110	0.113	0.115	0.090	0.095	0.100	0.105	0.110	0.115
25	0.093	0.096	0.098	0.101	0.104	0.106	0.081	0.086	0.091	0.096	0.100	0.105
30	0.088	0.091	0.094	0.096	0.099	0.101	0.076	0.081	0.085	0.090	0.095	0.099
Capital Recovery Term (years)	Absolute Change (WACC CRF less FTE CRF)						Relative Change					
	Bonus Percent						Bonus Percent					
	100%	80%	60%	40%	20%	0%	100%	80%	60%	40%	20%	0%
4	0.007	0.005	0.004	0.003	0.001	0.000	2.3%	1.8%	1.2%	0.8%	0.3%	(0.1%)
5	0.007	0.006	0.004	0.003	0.001	0.000	3.1%	2.3%	1.6%	1.0%	0.4%	(0.1%)
10	0.009	0.007	0.005	0.003	0.002	0.000	6.5%	4.9%	3.4%	2.1%	0.9%	(0.2%)
15	0.010	0.008	0.006	0.004	0.002	0.000	9.5%	7.2%	5.0%	3.1%	1.3%	(0.3%)
20	0.011	0.009	0.007	0.005	0.003	0.000	12.2%	9.3%	6.7%	4.4%	2.3%	0.4%
25	0.012	0.010	0.007	0.005	0.003	0.001	14.4%	11.2%	8.2%	5.6%	3.2%	1.1%
30	0.012	0.010	0.008	0.006	0.004	0.002	16.4%	12.8%	9.6%	6.7%	4.1%	1.7%

Timing of Unit Retirements

Generation owners that want to deactivate a unit, either to mothball or permanently retire, must provide notice to PJM and the MMU prior to the proposed deactivation date. Prior to September 2022, generation owners were required to provide deactivation notices at least 90 days before the proposed deactivation date. Beginning in September 2022, PJM and the MMU began reviewing deactivation requests quarterly, and the desired deactivation date is now based on the quarter the request was submitted (Table 5-31). The result is no change to the effective period between the notice and the retirement if notice is provided on the last day of the submittal period, and an increase to six months notice, if notice is given on the first day of the submittal period. The MMU recommends that participants be required to provide a notice of deactivation 12 months prior to an auction in which the unit will not be offered due to the deactivation; and no less than 12 months prior to the date of deactivation.

Table 5-31 Earliest deactivation dates allowed based on quarterly submission

Date Request Submitted	Earliest Deactivation Date Permitted
January 1 to March 31	July 1
April 1 to June 30	October 1
July 1 to September 30	January 1 (following calendar year)
October 1 to December 31	April 1 (following calendar year)

Generation owners seeking a capacity market must offer exemption for a delivery year must submit their deactivation request no later than the December 1 preceding the Base Residual Auction or 120 days before the start of an Incremental Auction for that delivery year.¹⁹⁵ If no reliability issues are found during PJM's analysis of the retirement's impact on the transmission system, and the MMU finds no market power issues associated with the proposed deactivation, the unit may deactivate at any time thereafter.¹⁹⁶

Table 5-32 shows the timing of actual deactivation dates and the initially requested deactivation date, for all deactivation requests submitted from January 2018 through March 2026. Of the 234 deactivation requests submitted, 33 units (14.1 percent) deactivated an average of 158 days earlier than their initially requested date; 34 units (14.5 percent) deactivated an average of 120 days later than the originally requested deactivation date; and 89 units (38.0 percent) deactivated on their initially requested date. Thirty eight (16.2 percent) of the unit deactivations were cancelled an average of 285 days (approximately 41 weeks) before their scheduled deactivation date, and 40 (17.1 percent) of the unit deactivations have not yet reached their target retirement date. Table 5-33 shows this information broken out by fuel types.

Due to the significant increase in the capacity price for the 2025/2026 Delivery Year, several units that were scheduled to deactivate rescinded their deactivation request. In 2024, Middle River Power, LLC, rescinded the deactivation of 483 MW from the Elgin CT 1-4 units. In 2025, 18 other units that were slated to deactivate (216 MW from Gen On Energy Management, LLC rescinding Morgantown CT 3-6; 54.9 MW from Constellation Energy Co. rescinding Perryman 6 unit 1; 15 MW from Tenaska Power Services, Co. rescinding Kenilworth; 272.1 MW from NRG Business Marketing LLC

¹⁹⁵ OATT Attachment DD § 6.6(g).

¹⁹⁶ OATT Part V §113.

rescinding Fisk CT 31- 34 and Waukegan CT 31 & 32; 223.0 MW from Heritage Power, LLC rescinding Sayreville CT 1-4; 31.0 MW from Forked River Power, LLC rescinding Forked River 2), accounting for 812.0 MW, rescinded their deactivation requests.

Table 5-32 Timing of actual unit deactivations compared to requested deactivation date: Requests submitted January 2018 through March 2026¹⁹⁷

Status	Number of Units	Percent	Average Days Deviation from Originally Requested Date
Early	33	14.1%	(158)
Late	34	14.5%	120
On time	89	38.0%	0
Cancelled	38	16.2%	(285)
Pending	40	17.1%	-
Total	234	100.0%	-

¹⁹⁷ Negative values indicate the average number of days the action is taken prior to the requested date.

Table 5-33 Timing of actual unit deactivations compared to requested deactivation date by fuel type: Requests submitted January 2018 through March 2026

Fuel Type	Status	Number of Units	Percent	Average Days Deviation from Originally Requested Date
Biomass	Early	2	40.0%	(4)
	Late	1	20.0%	14
	On time	2	40.0%	-
	Cancelled	0	0.0%	-
	Pending	0	0.0%	-
Total		5	100.0%	-
Coal	Early	15	28.3%	(169)
	Late	10	18.9%	170
	On time	16	30.2%	0
	Cancelled	4	7.5%	(371)
	Pending	8	15.1%	-
Total		53	100.0%	-
Diesel	Early	0	0.0%	-
	Late	0	0.0%	-
	On time	7	100.0%	0
	Cancelled	0	0.0%	-
	Pending	0	0.0%	-
Total		7	100.0%	-
Methane	Early	5	17.9%	(92)
	Late	7	25.0%	71
	On time	11	39.3%	0
	Cancelled	2	7.1%	(190)
	Pending	3	10.7%	-
Total		28	100.0%	-
Natural Gas	Early	4	6.9%	(197)
	Late	8	13.8%	71
	On time	20	34.5%	0
	Cancelled	8	13.8%	(220)
	Pending	18	31.0%	-
Total		58	100.0%	-
Nuclear	Early	0	0.0%	-
	Late	0	0.0%	-
	On time	0	0.0%	-
	Cancelled	10	100.0%	(312)
	Pending	0	0.0%	-
Total		10	100.0%	-
Oil	Early	3	5.8%	(218)
	Late	7	13.5%	188
	On time	24	46.2%	0
	Cancelled	13	25.0%	(317)
	Pending	5	9.6%	-
Total		52	100.0%	-
Solar	Early	0	0.0%	-
	Late	0	0.0%	-
	On time	1	1.9%	0
	Cancelled	0	0.0%	-
	Pending	0	0.0%	-
Total		1	1.9%	-
Solid Waste	Early	0	0.0%	-
	Late	0	0.0%	-
	On time	1	100.0%	0
	Cancelled	0	0.0%	-
	Pending	0	0.0%	-
Total		1	100.0%	-
Storage	Early	4	21.1%	(194)
	Late	1	5.3%	-
	On time	7	36.8%	0
	Cancelled	1	5.3%	-
	Pending	6	31.6%	-
Total		19	100.0%	-

Part V Reliability Service (RMR)

PJM must make out of market payments to units that want to retire (deactivate) but that PJM requires to remain in service, for limited operation, for a defined period because the unit is needed for reliability.¹⁹⁸ This provision has been known as Reliability Must Run (RMR) service but RMR is not defined in the PJM tariff, and the PJM market design has important distinguishing features relative to other regions where arrangements referred to as RMR are used. Here the term Part V reliability service is used. The need to retain uneconomic units in service reflects a flawed market design and/or planning process problems. The current capacity market design fails to include transmission constraints inside LDAs with the result that units needed for reliability do not clear in capacity auctions and that prices are suppressed and an RMR is then required. The current approach does not adequately look forward and attempt to address foreseeable unit retirements, whether for economic or regulatory reasons. The result is the wrong price signal for either investing in the existing resource or investing in new resources to provide locational reliability. The answer is not to artificially increase prices during the RMR while the transmission alternative is under construction but to provide an actionable price signal in advance of retirement as a signal to new generation to enter and compete with the transmission solution. It is essential that the deactivation provisions of the tariff be evaluated and modified, both to provide rules that better anticipate deactivations in the markets and rules that reasonably compensate Part V reliability service if it is still needed. Recent changes to the rules fail to address these issues.¹⁹⁹ It is also essential that queue processes that effectively prevent competition from new generation to replace the old generation be modified.

To improve coordination of deactivations and PJM transmission system planning, the MMU recommends that the same reliability standard be used in capacity auctions as is used by PJM transmission planning which means recognizing transmission constraints inside LDAs when they create reliability issues. One result of the current design is that a unit may fail to clear in a BRA, decide to retire as a result, but then be found to be needed for reliability by

¹⁹⁸ OATT Part V §114.

¹⁹⁹ See Deactivation Enhancements Senior Task Force (DESTF), which can be accessed at: <<https://www.pjm.com/committees-and-groups/task-forces/destf>>.

PJM planning and paid under Part V of the OATT (RMR) to remain in service while transmission upgrades are made. This result indicates a significant market design flaw.

The MMU recommends that PJM treat the inclusion of RMR resources in the capacity market consistently. PJM currently includes RMR units in the reliability analysis for RPM auctions but does not include the RMR units in the supply curves. This approach is internally inconsistent. It would be internally consistent to leave the RMR units out of the CETO/CETL analysis. It would also be internally consistent to include the RMR units in the supply of capacity and in the CETO/CETL analysis. Including RMR resources in the capacity supply curve does not mean forcing unit owners to offer or to take on PAI risk, for example. It simply means that PJM would recognize the fact that PJM treats RMR resources as a source of reliability. The goal is to ensure that the underlying supply and demand fundamentals are included in the capacity market prices. These two options have very different implications for capacity market prices. There are times early in the process when a price signal for the entry of generation is appropriate, e.g. when the goal is to allow generation to compete to replace the transmission option, in whole or in part, and there is enough time to permit such new entry. There are times later in the process when a price signal for the entry of generation is not needed or appropriate, e.g. when PJM has committed to the construction of new transmission that will eliminate the price signal when complete or when there is not enough time to permit such new entry. The relevant rules can and should be changed.²⁰⁰

The planning process should, to the extent possible, evaluate the impact of the loss of units at risk and determine in advance whether transmission upgrades are required.²⁰¹ It is essential that PJM look forward and attempt to plan for foreseeable unit retirements, whether for economic or regulatory reasons.

²⁰⁰ While PJM filed for and FERC accepted the inclusion of RMR resources Brandon Shores and Wagner plants in the 2026/2027 BRA and 2027/2028 BRA, that does not require that RMR resources be included in capacity market auction clearing in future auctions for these or other RMR resources. See Letter Order, FERC Docket No. ER25-682-001 (April 29, 2025).

²⁰¹ See, e.g., 140 FERC ¶ 61,237 at P 36 (2012) (“The evaluation of alternatives to an SSR designation is an important step that deserves the full consideration of MISO and its stakeholders to ensure that SSR Agreements are used only as a ‘limited, last-resort measure.’”); 118 FERC ¶ 61,243 at P 41 (2007) (“the market participants that pay for the agreements pay out-of-market prices for the service provided under the RMR agreements, which broadly hinders market development and performance.[footnote omitted] As a result of these factors, we have concluded that RMR agreements should be used as a last resort.”); 110 FERC ¶ 61,315 at P 40 (2005) (“The Commission has stated on several occasions that it shares the concerns . . . that RMR agreements not proliferate as an alternative pricing option for generators, and that they are used strictly as a last resort so that units needed for reliability receive reasonable compensation.”).

While not all retirements are completely foreseeable, improvement is needed in the process for ensuring that planning is looking at the probability of retirements, especially of resources that are critical to locational reliability in order to minimize the duration of any RMR requirement.

The actual implementation of Part V of the tariff has resulted in overpayment of the RMR resources. It is essential that the compensation provisions of Part V of the tariff be modified to ensure payment of all but only the actual costs incurred by the generation owner to provide the service, plus an incentive. Generators operating in competitive markets should be required, as an obligation of receiving interconnection service and having the ability to participate in competitive markets, to provide service under Part V on an incremental cost plus incentive basis when they are needed for reliability.

When notified of an intended deactivation, the MMU performs a market power study to ensure that the deactivation is economic, not an exercise of market power through withholding, and consistent with competition.²⁰² If the MMU determines that expected revenues exceed avoidable costs and therefore that the deactivation is not economic, the MMU will inform the unit owner that there is a market power issue. The MMU has no authority to prevent the retirement. The MMU can pursue the matter at FERC. Part V status by itself creates market power for the retiring resource. The owners of Part V resources have threatened to shut down the resources and put the grid at risk if they do not receive their requested level of Part V payments. Such exercises of market power have been effective in increasing payments to Part V units during the settlement proceedings that have resolved all Part V filings, generally on a black box basis.

PJM performs a system study to determine whether the system can accommodate the deactivation on the desired date, and if not, when it could.²⁰³ If PJM determines that it needs a unit for a period beyond the intended deactivation date, PJM will request a unit to remain in service for a defined period.²⁰⁴ The PJM market rules do not require an owner to remain in service. Owners must provide notice of a proposed deactivation at least twelve months prior to

²⁰² OATT § 113.2; OATT Attachment M § IV.1.

²⁰³ OATT § 113.2.

²⁰⁴ *Id.*

the desired deactivation date, although the advance notice can be too short to permit new generation to enter (See Table 5-31).²⁰⁵ ²⁰⁶ The owner of a generation capacity resource must provide notice of a proposed deactivation in order to avoid a requirement to offer in RPM auctions.²⁰⁷ In order to avoid submitting an offer for a unit in the next three-year forward RPM base residual auction based on retirement, an owner must submit a preliminary RPM must offer exception request no later than September 1 preceding the BRA and a final RPM must offer exception request demonstrating “a documented plan in place to retire the resource,” including a notice of deactivation filed with PJM no later than December 1 preceding the BRA.²⁰⁸

Under the current rules, a unit remaining in service at PJM’s request can recover its costs of continuing to operate under either the deactivation avoidable cost rate (DACR), which is a formula rate, or the cost of service recovery rate. The deactivation avoidable cost rate is designed to permit the recovery of the costs of the unit’s “continued operation,” termed “avoidable costs,” plus an incentive adder.²⁰⁹ Avoidable costs are defined to mean “incremental expenses directly required for the operation of a generating unit.”²¹⁰ The incentives escalate for each year of service (first year, 10 percent; second year, 20 percent; third year, 35 percent; fourth year, 50 percent).²¹¹ The rules provide terms for the repayment of project investment by owners of units that choose to keep units in service after the defined period ends.²¹² The amount of project investment recovered cannot exceed the actual amount of the PI.²¹³ The cost of service rate is designed to permit the recovery of the unit’s “cost of service rate to recover the entire cost of operating the generating unit” if the generation owner files a separate rate schedule at FERC.²¹⁴

²⁰⁵ See Letter Order, FERC Docket No. ER25-1501-000 (April 15, 2025).

²⁰⁶ OATT § 113.1.

²⁰⁷ OATT Attachment DD § 6.6(g).

²⁰⁸ *Id.*

²⁰⁹ OATT § 114 (Deactivation Avoidable Credit = ((Deactivation Avoidable Cost Rate + Applicable Multiplier) * MW capability of the unit * Number of days in the month) + (APIR * First Year Multiplier) – Actual Net Revenues).

²¹⁰ OATT § 115.

²¹¹ *Id.*

²¹² OATT § 118.

²¹³ OATT §§ 115.

²¹⁴ OATT § 119.

The DACR is unnecessarily prescriptive about the nature of the incremental costs needed to provide service, and includes unsupported escalation to extremely high incentive rates.

Table 5-34 shows units that have provided Part V reliability service to PJM, including the Indian River 4 unit, which began providing RMR service on June 1, 2022, and ended on February 24, 2025, and Brandon Shores 1 and 2 and Wagner 3 and 4 which began providing RMR service on June 1, 2025.²¹⁵ Only two of nine owners have used the deactivation avoidable cost rate approach. The other seven owners used the cost of service recovery rate. For units using the cost of service recovery rate option, revenues have averaged about 2.9 times the corresponding market price of capacity while for units using the deactivation avoidable cost rate, revenues have averaged about 1.6 times the corresponding market price of capacity.²¹⁶

Table 5-34 Part V reliability service summary

Unit Names	Owner	Fuel Type	ICAP (MW)	Cost Recovery Method	Docket Numbers	Start of Term	End of Term
Brandon Shores 1	Talen Energy Corporation	Coal	635.0	Cost of Service Recovery Rate	ER24-1790	01-Jun-25	31-Dec-28
Brandon Shores 2	Talen Energy Corporation	Coal	638.0	Cost of Service Recovery Rate	ER24-1790	01-Jun-25	31-Dec-28
Wagner 3	Talen Energy Corporation	Coal	305.0	Cost of Service Recovery Rate	ER24-1787	01-Jun-25	31-Dec-28
Wagner 4	Talen Energy Corporation	Oil	397.0	Cost of Service Recovery Rate	ER24-1787	01-Jun-25	31-Dec-28
Indian River 4	NRG Power Marketing LLC	Coal	410.0	Cost of Service Recovery Rate	ER22-1539	01-Jun-22	24-Feb-25
B.L. England 2	RC Cape May Holdings, LLC	Coal	150.0	Cost of Service Recovery Rate	ER17-1083	01-May-17	01-May-19
Yorktown 1	Dominion Virginia Power	Coal	159.0	Deactivation Avoidable Cost Rate	ER17-750	06-Jan-17	13-Mar-18
Yorktown 2	Dominion Virginia Power	Coal	164.0	Deactivation Avoidable Cost Rate	ER17-750	06-Jan-17	13-Mar-18
B.L. England 3	RC Cape May Holdings, LLC	Oil	148.0	Cost of Service Recovery Rate	ER17-1083	01-May-17	24-Jan-18
Ashtabula	FirstEnergy Service Company	Coal	210.0	Deactivation Avoidable Cost Rate	ER12-2710	01-Sep-12	11-Apr-15
Eastlake 1	FirstEnergy Service Company	Coal	109.0	Deactivation Avoidable Cost Rate	ER12-2710	01-Sep-12	15-Sep-14
Eastlake 2	FirstEnergy Service Company	Coal	109.0	Deactivation Avoidable Cost Rate	ER12-2710	01-Sep-12	15-Sep-14
Eastlake 3	FirstEnergy Service Company	Coal	109.0	Deactivation Avoidable Cost Rate	ER12-2710	01-Sep-12	15-Sep-14
Lakeshore	FirstEnergy Service Company	Coal	190.0	Deactivation Avoidable Cost Rate	ER12-2710	01-Sep-12	15-Sep-14
Elrama 4	GenOn Power Midwest, LP	Coal	171.0	Cost of Service Recovery Rate	ER12-1901	01-Jun-12	01-Oct-12
Niles 1	GenOn Power Midwest, LP	Coal	109.0	Cost of Service Recovery Rate	ER12-1901	01-Jun-12	01-Oct-12
Cromby 2 and Diesel	Exelon Generation Company, LLC	Natural gas/oil, Diesel	203.7	Cost of Service Recovery Rate	ER10-1418	01-Jun-11	01-Jan-12
Eddystone 2	Exelon Generation Company, LLC	Coal	309.0	Cost of Service Recovery Rate	ER10-1418	01-Jun-11	01-Jun-12
Brunot Island CT2A, CT2B, CT3 and CC4	Orion Power MidWest, L.P.	Natural gas	244.0	Cost of Service Recovery Rate	ER06-993	16-May-06	05-Jul-07
Hudson 1	PSEG Energy Resources & Trade LLC and PSEG Fossil LLC	Natural gas	355.0	Cost of Service Recovery Rate	ER05-644, ER11-2688	25-Feb-05	08-Dec-11
Sewaren 1-4	PSEG Energy Resources & Trade LLC and PSEG Fossil LLC	Natural gas	453.0	Cost of Service Recovery Rate	ER05-644	25-Feb-05	01-Sep-08

²¹⁵ See PJM, "Informational Filing Regarding Formal Notice of Termination of Reliability Must-Run Service," Docket Nos. ER22-2539-000 and ER23-2688-000 (December 23, 2024); See 191 FERC ¶ 61,098 (2025); Offer of Settlement, Docket No. ER24-1787, -1790 (January 1, 2025), Exhibit 2.

²¹⁶ The final rates for Brandon Shores and Wagner have not been established.

Table 5-35 Part V reliability service cost summary^{217 218 219}

Unit Names	Owner	Initial Filing		Actual		Weighted Average RPM Clearing Price (\$ per MW-day)
		Total Cost	Cost per MW-day	Total Cost	Cost per MW-day	
Brandon Shores 1	Talen Energy Corporation	\$327,039,342	\$393.45	\$137,708,201	\$794.37	\$318.45
Brandon Shores 2	Talen Energy Corporation	\$328,584,409	\$393.45	\$138,358,791	\$794.37	\$318.45
Wagner 3	Talen Energy Corporation	\$64,791,528	\$162.29	\$32,517,154	\$390.53	\$318.45
Wagner 4	Talen Energy Corporation	\$84,335,202	\$162.29	\$42,325,606	\$390.53	\$318.45
Indian River 4	NRG Power Marketing LLC	\$357,065,662	\$871.76	\$198,617,019	\$484.92	\$54.04
B.L. England 2	RC Cape May Holdings, LLC	\$35,953,561	\$328.34	\$51,779,892	\$472.88	\$154.51
Yorktown 1	Dominion Virginia Power	\$9,739,434	\$142.12	\$8,427,011	\$122.97	\$134.64
Yorktown 2	Dominion Virginia Power	\$10,045,705	\$142.12	\$9,529,149	\$134.81	\$134.64
B.L. England 3	RC Cape May Holdings, LLC	\$28,710,481	\$723.84	\$10,058,665	\$253.60	\$138.95
Ashtabula	FirstEnergy Service Company	\$35,236,541	\$176.25	\$25,177,042	\$125.94	\$107.91
Eastlake 1	FirstEnergy Service Company	\$20,842,416	\$257.01	\$18,484,399	\$227.93	\$102.73
Eastlake 2	FirstEnergy Service Company	\$20,182,025	\$248.87	\$17,683,994	\$218.06	\$102.73
Eastlake 3	FirstEnergy Service Company	\$20,192,938	\$249.00	\$17,391,797	\$214.46	\$102.73
Lakeshore	FirstEnergy Service Company	\$33,993,468	\$240.47	\$20,532,969	\$145.25	\$102.73
Elrama 4	GenOn Power Midwest, LP	\$15,435,472	\$739.88	\$7,576,435	\$363.17	\$75.08
Niles 1	GenOn Power Midwest, LP	\$9,510,580	\$715.19	\$4,829,423	\$363.17	\$75.08
Cromby 2 and Diesel	Exelon Generation Company, LLC	\$20,213,406	\$463.70	\$17,776,658	\$407.80	\$108.63
Eddystone 2	Exelon Generation Company, LLC	\$165,993,135	\$1,467.74	\$85,364,570	\$754.81	\$108.63
Brunot Island CT2A, CT2B, CT3 and CC4	Orion Power MidWest, L.P.	\$60,933,986	\$601.76	\$23,507,795	\$232.15	\$89.78
Hudson 1	PSEG Energy Resources Et Trade LLC and PSEG Fossil LLC	\$28,934,341	\$32.90	\$62,364,359	\$70.92	\$132.72
Sewaren 1-4	PSEG Energy Resources Et Trade LLC and PSEG Fossil LLC	\$47,633,115	\$81.89	\$79,580,435	\$136.82	\$97.39

In each of the cost of service recovery rate filings for Part V reliability service, the scope of recovery permitted under the cost of service approach defined in Section 119 has been a significant issue. Owners have sought to recover fixed costs, incurred prior to the noticed deactivation date, in addition to the cost of operating the generating unit. Owners have cited the cost of service reference to mean that the unit is entitled to file to recover sunk costs that it was unable to recover in the competitive markets, in addition to recovery of costs of actually providing the Part V reliability service.

The cost of service recovery rate approach has been interpreted by the companies using that approach to allow the company to develop the type of rate case filing used by regulated utilities, using a test year with adjustments, to establish a rate base including investment in the existing plant and new investment necessary to remain in service and to earn a return on that rate base and receive depreciation of that rate base, plus guarantee recovery of estimated operation and maintenance expenses without verification of actual expenses. Despite the asserted reliance on traditional cost of service ratemaking principles, in practice generators seek approval of high rates that have weak or non-existent support in law and fact relative to what has been traditionally required to justify of cost

²¹⁷ Actual cost data includes RMR charges through February 28, 2026.

²¹⁸ The actual cost data for Indian River 4 include a refund of the difference between the filed rate that was collected pending resolution and the RMR settlement amount.

²¹⁹ The data reported for Brandon Shores and Wagner are the Settlement gross costs. See 191 FERC ¶ 61,098 (2025); Offer of Settlement, Docket No. ER24-1787, -1790 (January 1, 2025), Exhibit 2.

of service rates. Companies developing the cost of service recovery rate have ignored the tariff's limitation to the costs of operating the unit during the Part V reliability service period and have included costs incurred prior to the decision to deactivate and costs associated with closing the unit that would have been incurred regardless of the Part V reliability service period.²²⁰ In some cases, the filing included costs that already had been written off, or impaired, on the company's public books.^{221 222} In another case, the filing ignored evidence of actual book value based on market purchase of the asset.²²³ The cost of service recovery rates substantially exceed the actual costs of operating to provide the reliability required by PJM. The costs are generally not subject to review, audit and verification. The Commission has approved black box settlement rates (i.e., no explicit basis for the rate is stated) that included arbitrarily inflated asset values and costs, despite protests.²²⁴

Because such units are needed by PJM for reliability reasons, and the provision of the service is voluntary in PJM, owners of units that PJM needs to remain in service after the desired retirement date have significant market power in establishing the terms of this reliability service which have generally been set through settlements.

This reliability service should be provided to PJM customers at reasonable rates, which reflect the relatively low risk nature of providing such service to owners, the reliability need for such service and the opportunity for owners to be guaranteed recovery of 100 percent of the actual incremental costs required to operate to provide the service plus an incentive.

The MMU recommends elimination of both the cost of service recovery rate in OATT Section 119 and the deactivation avoidable cost rate in Part V, and their replacement with clear language that provides for the recovery of 100 percent of the actual incremental costs required to operate to provide the service plus an incentive.

²²⁰ See, e.g., FERC Dockets Nos. ER10-1418-000, ER12-1901-000 and ER17-1083-000.

²²¹ See GenOn Filing, Docket No. ER12-1901-000 (May 31, 2012) at Exh. No. GPM-1 at 9:16-21.

²²² See NRG Filing, Docket No. ER22- 1539-000 (April 1, 2022).

²²³ See Brandon Shores, H.A. Wagner, Docket No. ER24-1787-000, et al. (April 18, 2024); Comments of the Independent Market Monitor for PJM in Opposition to Settlement, Docket No. ER24-1787-000, et al. (February 18, 2025).

²²⁴ See 190 FERC ¶ 61,026 (2025), *reh'g denied*, 191 FERC ¶ 61,170 (2025), *appeal pending* (D.C. Cir. Case No. 25-1260); 191 FERC ¶ 61,098 (2025), *reh'g denied*, 191 FERC ¶ 62,189 (2025).

The MMU recommends that units recover all and only the incremental costs, including incremental investment costs without a cap, required to provide Part V reliability service (RMR service) that the unit owner would not have incurred if the unit owner had deactivated its unit as it proposed, plus a defined incentive payment. Customers should bear no responsibility for paying previously incurred (sunk) costs, including a return on or of prior investments.

The Indian River RMR was effective from June 1, 2022, through February 24, 2025. After the RMR ended, Indian River submitted additional bills until the final invoice for October 2025. Additional costs beyond February 2025 were incurred for the removal of remaining coal inventory and chemicals. The MMU was unable to review all costs charged to the project because NRG refused to provide supporting documentation after several requests from the MMU. NRG only provided invoices over \$10,000 starting January 2024. NRG did not provide supporting documentation for costs prior to January 2024 and for costs under \$10,000. As a result, the MMU was unable to determine if all costs charged to the project were reasonable. On February 20, 2026, the MMU filed a Petition with FERC to require NRG to produce the requested cost documentation.²²⁵

Department of Energy (DOE) 202(c) Orders Eddystone

On May 30, 2025, the Department of Energy (DOE) issued an order under Section 202(c) of the Federal Power Act stating that the operational availability and economic dispatch of Eddystone units 3 and 4 is necessary to meet an emergency and serve the public interest.²²⁶ The order requires that Constellation Energy, LLC and PJM take measures to ensure that Eddystone units 3 and 4 are available to operate from May 30, 2025, initially through 5:03 PM EDT on August 28, 2025.²²⁷ The term of operation was extended,

²²⁵ See *Petition of Monitoring Analytics, LLC, LLC for Order Directing Production of Information*, Docket No. EL26-xx (February 20, 2026).

²²⁶ 16 U.S.C. § 824a(c).

²²⁷ Department of Energy, Order No. 202-25-4 (May 30, 2025) <<https://www.energy.gov/ceser/federal-power-act-section-202c-pjm-interconnection>> .

including to May 24, 2026, in subsequent orders.^{228 229} Eddystone Units 3 and 4 were previously scheduled to retire on May 31, 2025.

PJM and Constellation notified the Commission by letter dated June 26, 2025, that they had agreed to a rate for service under Section 202(c) based on a modified version of the Deactivation Avoidable Cost Credit method included in Section 114 of the OATT. The modified approach ensure rates based on the actual fuel costs for operating the units and a reasonable approximation of actual avoidable costs rather than the arbitrary regulated cost of service model in recent RMR cases.

On January 25, 2026, in response to an application filed by PJM, DOE issued an emergency order pursuant to section 202(c) allowing PJM to run all electric generating units located within the PJM Region up to their maximum generation output levels, notwithstanding air quality or other permit limitations or fuel shortages, from January 25 to January 31, 2026.²³⁰

Wagner

On July 28, 2025, the Department of Energy (DOE) issued an order under Section 202(c) of the Federal Power Act stating that the operational availability and economic dispatch of H.A. Wagner Unit 4 is necessary to meet an emergency and serve the public interest.²³¹ The order required that PJM take measures in coordination with Talen Energy, the owner, to ensure that H.A. Wagner Unit 4 remain available to operate from July 28, 2025, initially through October 26, 2026.²³² The term of operation was extended to January 1, 2026, in a subsequent order.²³³

²²⁸ Department of Energy, Order No. 202-25-8 (August 28, 2025), <https://www.energy.gov/ceser/federal-power-act-section-202c-pjm-interconnection-pjm>; <Department of Energy, Order No. 202-25-10 (November 26, 2025), <<https://www.energy.gov/ceser/federal-power-act-section-202c-pjm-interconnection-pjm-order-no-202-25-10>>; Department of Energy, Order No. 202-26-17 (February 23, 2026), <<https://www.energy.gov/ceser/federal-power-act-section-202c-pjm-interconnection-llc-pjm-order-no-202-26-17>> .

²²⁹ On June 9, 2025, the PJM Board of Managers initiated a Critical Issue Fast Path (CIFF) stakeholder process to address the allocation of costs associated with the payments to Constellation for continuing to operate Eddystone units 3 and 4. On August 15, 2025, FERC issued an order accepting PJM's cost allocation methodology related to the retention of Eddystone units 3 and 4. 192 FERC ¶ 61,159 (2025).

²³⁰ Order No. 202-26-02, < <https://www.energy.gov/documents/order-no-202-26-2-pjm>> .

²³¹ Department of Energy, Order No. 202-25-6 (July 28, 2025), <<https://www.energy.gov/sites/default/files/2025-07/PJM%27s%20202%28c%29%20Order%20No.%20202-25-6.pdf>> .

²³² *Id.*

²³³ Department of Energy, Order No. 202-25-6A (October 24, 2025), <https://www.energy.gov/sites/default/files/2025-10/202c%20Order%20No.%20202-25-6A_0.pdf> .

Generator Performance

Generator performance results from the interaction between the physical characteristics of the units and the level of expenditures made to maintain the capability of the units, which in turn is a function of incentives from energy, ancillary services and capacity markets. Generator performance indices include those based on total hours in a period (generator performance factors) and those based on hours when units are needed to operate by the system operator (generator forced outage rates).

Capacity Factor

Capacity factor measures the actual output of a power plant over a period of time compared to the potential output of the unit had it been running at full nameplate capacity for every hour during that period. Table 5-36 shows the capacity factors by unit type for January through March, 2025 and 2026. In the first three months of 2026, nuclear units had a capacity factor of 97.7 percent, compared to a capacity factor of 97.1 percent in the first three months of 2025; combined cycle units had a capacity factor of 67.4 percent in the first three months of 2026, compared to a capacity factor of 67.3 percent in the first three months of 2025; coal units had a capacity factor of 48.7 percent in the first three months of 2026, compared to a capacity factor of 48.3 percent in the first three months of 2025.

Table 5-36 Capacity factor (By unit type (GWh)): January through March, 2025 and 2026^{234 235 236}

Unit Type	2025 (Jan-Mar)		2026 (Jan-Mar)		Change in Capacity Factor
	Generation (GWh)	Capacity Factor	Generation (GWh)	Capacity Factor	
Battery	16.2	2.2%	30.9	3.3%	1.0%
Combined Cycle	83,969.0	67.3%	85,400.0	67.4%	0.1%
Single Fuel	74,560.3	74.7%	74,754.9	72.0%	(2.7%)
Dual Fuel	9,408.7	37.9%	10,645.1	46.6%	8.7%
Combustion Turbine	4,421.5	7.2%	6,448.3	10.5%	3.3%
Single Fuel	2,763.8	6.5%	4,112.0	9.6%	3.2%
Dual Fuel	1,657.6	8.7%	2,336.3	12.3%	3.6%
Diesel	78.7	10.0%	75.0	10.3%	0.3%
Single Fuel	69.3	9.8%	60.1	9.2%	(0.6%)
Dual Fuel	9.5	12.7%	15.0	20.2%	7.4%
Diesel (Landfill gas)	189.7	43.2%	181.1	41.3%	(1.9%)
Fuel Cell	53.3	93.3%	52.5	91.8%	(1.4%)
Nuclear	68,374.1	97.1%	68,769.7	97.7%	0.5%
Pumped Storage Hydro	1,835.3	15.7%	1,934.3	16.5%	0.8%
Run of River Hydro	2,151.1	48.5%	1,977.3	36.3%	(12.1%)
Solar	4,666.9	17.6%	5,343.8	16.6%	(1.0%)
Steam	42,937.8	42.8%	44,294.0	44.6%	1.9%
Biomass	1,263.9	66.6%	1,228.5	64.2%	(2.4%)
Coal	38,978.1	48.3%	39,151.5	48.7%	0.4%
Single Fuel	38,978.1	48.8%	39,151.5	49.6%	0.7%
Dual Fuel	0.0	0.0%	0.0	0.0%	0.0%
Natural Gas	2,431.8	46.1%	3,467.2	48.0%	1.9%
Single Fuel	113.7	56.2%	33.7	55.7%	(0.6%)
Dual Fuel	2,318.0	22.5%	3,433.5	28.8%	6.2%
Oil	264.0	4.1%	446.8	7.7%	3.7%
Wind	11,250.1	14.1%	10,724.0	21.6%	7.5%
Total	219,943.7	51.3%	225,230.9	51.6%	0.2%

Generator Performance Factors

Generator outages fall into three categories: planned, maintenance, and forced. The scheduling of planned and maintenance outages must be approved by PJM. The approval may be withdrawn in order to maintain system reliability.²³⁷ The PJM Market Rules do not specify any consequences if the planned outage continues after PJM withdraws approval. If PJM withdraws approval for a maintenance outage during the outage and the unit cannot operate, the

²³⁴ The capacity factors in this table are based on nameplate capacity values, and are calculated based on when the units come on line.

²³⁵ The subcategories of steam units are consolidated consistent with confidentiality rules. Coal is comprised of coal and waste coal.

Natural gas is comprised of natural gas and propane. Oil is comprised of both heavy and light oil. Biomass is comprised of biomass, landfill gas, and municipal solid waste.


²³⁶ Hours in which batteries have net negative generation do not count toward their runtime.

²³⁷ *PJM Manual 10: Pre-Scheduling Operations," § 2.3.2 Maintenance Outage Rules, Rev. 65 (July 23, 2025).

outage is defined to be a forced outage.²³⁸ Outages that are approved by PJM may be extended. An extension to a planned outage that enters the peak period is treated as a forced outage. A maintenance outage that is extended to more than nine days during the peak period is treated as a forced outage.

The MW on outage vary during the year. For example, the MW on planned outage are generally highest in the spring and fall, as shown in Figure 5-10, as a result of restrictions on planned outages during the winter and summer. The Peak Period Maintenance Season, shown in Figure 5-10 as the peak season, runs from the weeks containing the twenty-fourth through thirty-sixth Wednesdays of the year. Planned outages cannot start in nor extend into this period. In 2026, the period runs from Monday, June 15 through Friday, September 11. The effect of the seasonal variation in outages can be seen in the monthly generator performance metrics in Figure 5-13.

Figure 5-10 Outages (MW): 2012 through March 2026



²³⁸ OATT, Attachment K (Appendix) § 1.9.3 (b).

Table 5-37 shows the total MWh by outage type. In the first three months of 2026, forced outage MWh were 62.0 percent higher, planned outage MWh were 1.1 percent lower, and maintenance outage MWh were 25.8 percent lower than in the first three months of 2025.

Table 5-37 Outages (MWh): January through March, 2012 through 2026


Jan-Mar	Forced MWh	Planned MWh	Maintenance MWh
2012	644,946	880,150	593,152
2013	746,299	994,855	373,523
2014	1,318,183	867,621	366,702
2015	864,686	853,173	331,012
2016	521,638	918,511	466,628
2017	597,092	662,031	538,223
2018	664,070	723,938	513,340
2019	494,156	695,494	495,231
2020	460,855	614,706	557,296
2021	706,413	500,537	620,203
2022	544,111	641,062	506,777
2023	433,641	592,430	618,364
2024	260,401	596,660	434,870
2025	394,908	566,426	397,087
2026	639,919	560,328	294,455
Change in 2026 from 2025	62.0%	(1.1%)	(25.8%)

Performance factors include the equivalent availability factor (EAF), the equivalent maintenance outage factor (EMOF), the equivalent planned outage factor (EPOF) and the equivalent forced outage factor (EFOF). These four factors add to 100 percent for any generating unit. The EAF is the proportion of hours in a year when a unit is available to generate at full capacity while the three outage factors include all the hours when a unit is unavailable. The EMOF is the proportion of hours in a year when a unit is unavailable because of maintenance outages and maintenance deratings. The EPOF is the proportion of hours in a year when a unit is unavailable because of planned outages and planned deratings. The EFOF is the proportion of hours in a year when a unit is unavailable because of forced outages and forced deratings.

The PJM aggregate EAF, EFOF, EPOF, and EMOF are shown in Figure 5-11. Metrics by unit type are shown in Table 5-38. The PJM aggregate equivalent

availability factor in the first three months of 2026 was 84.4 percent, a decrease from 86.1 percent in the first three months of 2025.

Figure 5-11 Equivalent outage and availability factors: January through March, 2007 through 2026



The PJM aggregate equivalent availability factor in the first three months of 2026 was 84.4 percent, a decrease from 86.1 percent in the first three months of 2025.

Table 5-38 EFOF, EPOF, EMOF and EAF by unit type: January through March, 2007 through 2026

Jan-Mar	Coal				Combined Cycle				Combustion Turbine				Diesel				Hydroelectric				Nuclear				Other				Total			
	EFOF	EPOF	EMOF	EAF	EFOF	EPOF	EMOF	EAF	EFOF	EPOF	EMOF	EAF	EFOF	EPOF	EMOF	EAF	EFOF	EPOF	EMOF	EAF	EFOF	EPOF	EMOF	EAF	EFOF	EPOF	EMOF	EAF	EFOF	EPOF	EMOF	EAF
2007	7%	6%	2%	85%	1%	7%	2%	90%	6%	3%	3%	89%	8%	0%	2%	90%	1%	8%	2%	89%	0%	5%	0%	94%	8%	5%	3%	85%	5%	5%	2%	88%
2008	8%	6%	2%	83%	2%	3%	1%	93%	4%	4%	1%	90%	10%	0%	1%	89%	1%	9%	1%	89%	2%	7%	1%	91%	3%	7%	3%	86%	5%	6%	2%	87%
2009	7%	6%	4%	83%	4%	6%	1%	89%	1%	3%	2%	94%	7%	0%	2%	91%	2%	11%	1%	87%	4%	3%	1%	91%	5%	6%	7%	82%	5%	5%	3%	87%
2010	7%	9%	4%	81%	2%	5%	1%	92%	2%	2%	1%	95%	4%	1%	1%	94%	1%	9%	1%	89%	1%	7%	0%	92%	3%	7%	2%	88%	4%	7%	2%	87%
2011	10%	7%	4%	78%	4%	9%	0%	86%	1%	2%	1%	95%	3%	0%	4%	94%	2%	10%	1%	87%	2%	3%	1%	94%	4%	5%	3%	88%	5%	6%	2%	86%
2012	8%	8%	8%	76%	2%	7%	2%	90%	1%	2%	1%	95%	2%	0%	1%	97%	2%	4%	1%	93%	1%	6%	1%	93%	5%	6%	4%	86%	4%	6%	4%	86%
2013	7%	10%	4%	79%	1%	9%	4%	86%	5%	3%	0%	92%	4%	0%	1%	95%	0%	4%	2%	93%	0%	3%	0%	96%	8%	7%	2%	83%	4%	7%	2%	86%
2014	11%	6%	4%	80%	4%	10%	1%	85%	15%	4%	1%	80%	15%	0%	2%	82%	1%	9%	6%	84%	1%	5%	0%	94%	11%	8%	4%	77%	8%	6%	3%	83%
2015	9%	6%	4%	82%	2%	9%	1%	88%	4%	3%	1%	92%	10%	0%	2%	88%	2%	10%	1%	87%	2%	5%	1%	93%	9%	11%	4%	76%	5%	6%	2%	86%
2016	8%	6%	7%	80%	2%	4%	2%	92%	2%	2%	2%	94%	6%	0%	3%	91%	2%	5%	4%	89%	0%	5%	0%	94%	4%	16%	4%	77%	4%	6%	3%	87%
2017	10%	7%	9%	75%	3%	5%	1%	91%	1%	2%	2%	95%	5%	0%	1%	94%	2%	6%	4%	88%	0%	5%	1%	94%	2%	5%	5%	88%	4%	5%	4%	87%
2018	11%	7%	8%	74%	2%	2%	1%	95%	2%	2%	2%	94%	6%	1%	3%	90%	3%	4%	2%	90%	0%	5%	0%	95%	5%	8%	7%	81%	5%	5%	4%	87%
2019	9%	4%	7%	80%	1%	5%	2%	92%	2%	5%	2%	92%	6%	1%	3%	90%	1%	6%	3%	90%	0%	5%	1%	94%	3%	9%	7%	80%	3%	5%	4%	88%
2020	4%	4%	11%	81%	6%	5%	1%	88%	2%	4%	1%	93%	7%	0%	3%	90%	3%	4%	2%	91%	2%	4%	1%	93%	3%	9%	4%	84%	4%	5%	4%	88%
2021	9%	5%	11%	76%	2%	5%	2%	91%	1%	4%	2%	93%	6%	0%	3%	91%	16%	1%	2%	81%	0%	4%	2%	94%	14%	5%	2%	79%	5%	4%	4%	86%
2022	11%	7%	9%	74%	2%	6%	3%	89%	2%	4%	2%	92%	10%	1%	5%	85%	5%	3%	2%	90%	0%	4%	1%	94%	4%	6%	4%	86%	4%	5%	4%	86%
2023	7%	6%	11%	76%	3%	5%	2%	90%	2%	4%	2%	92%	13%	0%	4%	83%	2%	17%	6%	75%	0%	4%	2%	94%	5%	9%	9%	77%	3%	6%	5%	88%
2024	4%	7%	7%	82%	2%	5%	2%	91%	2%	4%	2%	92%	9%	0%	2%	89%	3%	18%	3%	77%	1%	4%	3%	93%	3%	11%	2%	83%	2%	6%	3%	88%
2025	9%	7%	9%	74%	2%	5%	2%	91%	4%	3%	2%	91%	13%	2%	1%	84%	2%	11%	6%	81%	0%	5%	2%	93%	7%	9%	4%	80%	4%	6%	4%	86%
2026	13%	8%	6%	73%	4%	7%	2%	87%	8%	4%	2%	86%	16%	4%	4%	76%	1%	6%	4%	89%	1%	4%	2%	94%	16%	9%	4%	71%	7%	6%	3%	84%

Generator Outage Rates

The most fundamental forced outage rate metric is the equivalent demand forced outage rate (EFORD). EFORD is a measure of the probability that a generating unit will fail, either partially or totally, to perform when it is needed to operate. EFORD measures the forced outage rate during periods of demand, and does not include planned or maintenance outages. A period of demand is a period during which a generator is running or needed to run. EFORD calculations use historical performance data, including equivalent forced outage hours, service hours, average forced outage duration, average run time, average time between unit starts, available hours and period hours.²³⁹ The EFORD metric includes all forced outages, regardless of the reason for those outages.

The average PJM EFORD in the first three months of 2026 was 8.6 percent, an increase from 6.0 percent in the first three months of 2025. Figure 5-12 shows the average EFORD since 1999 for all units in PJM.²⁴⁰

²³⁹ Equivalent forced outage hours are the sum of all forced outage hours in which a generating unit is fully inoperable and all partial forced outage hours in which a generating unit is partially inoperable, prorated to full hours.

²⁴⁰ The universe of units in PJM changed as the PJM footprint expanded and as units retired from and entered PJM markets. See the 2019 *State of the Market Report for PJM*, Appendix A: "PJM Overview" for details.

Figure 5-12 Equivalent demand forced outage rates (EFORd): 1999 through March, 2026




Table 5-39 shows the class average EFORd by unit type.

Table 5-39 EFORd by unit type: January through March, 2007 through 2026

	Jan-Mar																			
	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025	2026
Coal	7.8%	8.8%	8.5%	8.4%	12.2%	9.9%	8.7%	12.0%	10.0%	9.6%	12.7%	14.1%	11.9%	6.2%	11.8%	12.1%	11.3%	6.4%	11.5%	16.3%
Combined Cycle	8.5%	7.4%	5.6%	3.0%	5.3%	2.6%	1.1%	6.8%	2.4%	3.3%	3.3%	3.0%	2.8%	6.3%	2.4%	3.3%	4.3%	2.9%	2.6%	4.9%
Combustion Turbine	22.6%	18.5%	15.0%	11.6%	13.3%	6.0%	18.3%	30.5%	17.5%	8.6%	4.4%	10.9%	9.7%	5.4%	4.8%	7.0%	5.4%	8.9%	8.9%	12.5%
Diesel	9.2%	10.2%	8.3%	6.3%	5.3%	2.8%	3.9%	16.0%	11.0%	7.1%	6.1%	6.7%	6.8%	7.6%	6.3%	10.2%	14.8%	11.5%	16.0%	18.7%
Hydroelectric	1.6%	3.0%	2.0%	0.9%	2.2%	2.8%	0.6%	1.5%	2.4%	3.2%	3.1%	3.6%	1.2%	4.0%	16.9%	6.4%	1.6%	3.3%	5.7%	1.2%
Nuclear	0.4%	1.6%	4.0%	0.8%	1.7%	0.8%	0.2%	1.1%	1.6%	0.5%	0.5%	0.4%	0.3%	2.3%	0.2%	0.5%	0.1%	0.7%	0.3%	0.9%
Other	11.2%	10.1%	10.9%	5.1%	13.4%	4.6%	10.4%	19.6%	17.4%	6.4%	6.3%	12.9%	6.6%	2.9%	29.9%	11.2%	4.5%	4.8%	9.0%	20.0%
Total	8.3%	8.3%	8.2%	6.1%	9.1%	5.9%	7.4%	12.3%	8.9%	5.8%	6.0%	8.1%	6.3%	4.8%	7.9%	6.6%	5.1%	4.5%	6.0%	8.6%

EFORd vs EAF

EFORd is not an adequate measure of unit availability because EFORd measures only forced outages and does not account for planned or maintenance outages. Forced outage rates can be managed under the existing outage rules. The EAF (Equivalent Availability Factor), which reflects all forced, planned, and maintenance outages, is a more accurate measure of the capacity actually available to meet load.

Table 5-40 shows the differences between EFORd and EAF by unit type.

Table 5-40 EFORd and EAF by unit type: January through March, 2012 through 2026

Jan-Mar	Unit Types															
	Coal		Combined Cycle		Combustion Turbine		Diesel		Hydroelectric		Nuclear		Other		All	
	EFORd	1-EAF	EFORd	1-EAF	EFORd	1-EAF	EFORd	1-EAF	EFORd	1-EAF	EFORd	1-EAF	EFORd	1-EAF	EFORd	1-EAF
2012	9.9%	23.6%	2.6%	10.5%	6.0%	4.7%	2.8%	2.8%	2.8%	7.2%	0.8%	7.3%	4.6%	14.1%	5.9%	14.3%
2013	8.7%	21.3%	1.1%	13.9%	18.3%	8.2%	3.9%	5.0%	0.6%	6.6%	0.2%	3.8%	10.4%	17.4%	7.4%	13.6%
2014	12.0%	20.4%	6.8%	15.1%	30.5%	19.6%	16.0%	17.7%	1.5%	16.5%	1.1%	5.8%	19.6%	23.3%	12.3%	16.6%
2015	10.0%	18.1%	2.4%	12.2%	17.5%	8.2%	11.0%	12.3%	2.4%	13.5%	1.6%	6.8%	17.4%	23.9%	8.9%	13.7%
2016	9.6%	20.4%	3.3%	8.0%	8.6%	6.2%	7.1%	9.0%	3.2%	11.3%	0.5%	6.0%	6.4%	23.2%	5.8%	13.0%
2017	12.7%	25.4%	3.3%	8.7%	4.4%	5.1%	6.1%	6.3%	3.1%	11.5%	0.5%	5.7%	6.3%	11.9%	6.0%	13.0%
2018	14.1%	26.0%	3.0%	4.9%	10.9%	5.8%	6.7%	9.9%	3.6%	9.6%	0.4%	5.5%	12.9%	19.1%	8.1%	13.4%
2019	11.9%	20.0%	2.8%	8.5%	9.7%	8.2%	6.8%	10.3%	1.2%	9.8%	0.3%	6.3%	6.6%	19.7%	6.3%	12.4%
2020	6.2%	18.9%	6.3%	12.4%	5.4%	7.4%	7.6%	9.8%	4.0%	8.8%	2.3%	7.3%	2.9%	16.3%	4.8%	12.3%
2021	11.8%	24.5%	2.4%	8.5%	4.8%	7.0%	6.3%	9.1%	16.9%	19.1%	0.2%	5.5%	29.9%	21.5%	7.9%	13.5%
2022	12.1%	26.3%	3.3%	11.5%	7.0%	8.2%	10.2%	15.3%	6.4%	10.5%	0.5%	5.7%	11.2%	14.0%	6.6%	13.9%
2023	11.3%	24.1%	4.3%	10.2%	5.4%	7.7%	14.8%	17.4%	1.6%	24.8%	0.1%	5.6%	4.5%	23.2%	5.1%	14.0%
2024	6.4%	17.9%	2.9%	8.6%	8.9%	7.8%	11.5%	11.2%	3.3%	22.9%	0.7%	7.2%	4.8%	16.6%	4.5%	11.7%
2025	11.5%	25.6%	2.6%	8.8%	8.9%	8.8%	16.0%	15.8%	5.7%	19.0%	0.3%	7.2%	9.0%	20.1%	6.0%	13.9%
2026	16.3%	27.4%	4.9%	12.8%	12.5%	13.9%	18.7%	23.6%	1.2%	11.4%	0.9%	6.1%	20.0%	28.7%	8.6%	15.6%
Average	11.0%	22.7%	3.5%	10.3%	10.6%	8.5%	9.7%	11.7%	3.8%	13.5%	0.7%	6.1%	11.1%	19.5%	6.9%	13.7%

Outage Analysis

The MMU analyzed the causes of outages for the PJM system. The metric used was lost generation, which is the product of the duration of the outage and the size of the outage reduction. Lost generation can be converted into lost system equivalent availability.²⁴¹ On a system wide basis, the resultant lost equivalent availability from forced outages is equal to the equivalent forced outage factor (EFOF), the resultant lost equivalent availability from maintenance outages is equal to the equivalent maintenance outage factor (EMOF), and the resultant lost equivalent availability from planned outages is equal to the equivalent planned outage factor (EPOF).

The PJM EFOF was 6.6 percent in the first three months of 2026. Table 5-41 shows the causes of EFOF by unit type. Forced outages for boiler tube leaks, 13.9 percent of the system EFOF, were the largest single contributor to average system EFOF across all unit types.

²⁴¹ For any unit, lost generation can be converted to lost equivalent availability by dividing lost generation by the product of the generating units' capacity and period hours. This can also be done on a system basis.

Table 5-41 Contribution to PJM EFOF by unit type by cause: January through March, 2026

	Combined		Combustion				Other	System
	Coal	Cycle	Turbine	Diesel	Hydroelectric	Nuclear		
Boiler Tube Leaks	22.2%	6.0%	0.0%	0.0%	0.0%	0.0%	15.7%	13.9%
Boiler Air and Gas Systems	10.6%	0.0%	0.0%	0.0%	0.0%	0.0%	43.4%	11.5%
Personnel or Procedure Errors	18.4%	0.1%	0.0%	2.4%	0.0%	0.0%	0.0%	9.1%
Electrical	1.3%	4.8%	20.8%	1.1%	0.8%	73.1%	0.0%	8.2%
Wet Scrubbers	15.2%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	7.5%
Economic	0.0%	1.1%	31.3%	14.0%	43.9%	0.0%	0.5%	6.9%
Miscellaneous (Gas Turbine)	0.0%	31.9%	9.4%	0.0%	0.0%	0.0%	0.0%	5.3%
Low Pressure Turbine	3.9%	0.0%	0.0%	0.0%	0.0%	0.0%	7.6%	3.0%
Stack Emission	4.6%	0.6%	0.1%	0.0%	0.0%	0.0%	4.8%	3.0%
Fuel, Ignition and Combustion Systems	0.0%	6.2%	9.3%	0.0%	0.0%	0.0%	0.0%	2.5%
Miscellaneous (Jet Engine)	0.0%	0.0%	12.5%	0.0%	0.0%	0.0%	0.0%	2.5%
Valves	3.7%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	1.8%
Circulating Water Systems	2.4%	4.2%	0.0%	0.0%	0.0%	0.2%	1.3%	1.8%
Generator	0.0%	15.2%	0.0%	0.1%	1.5%	0.0%	0.0%	1.7%
Miscellaneous (Generator)	0.2%	0.0%	0.2%	26.0%	7.1%	0.0%	7.2%	1.4%
Miscellaneous (Steam Turbine)	1.6%	1.9%	0.0%	0.0%	0.0%	0.0%	2.9%	1.4%
Exciter	1.0%	1.6%	2.4%	0.0%	0.8%	0.0%	0.5%	1.2%
Fuel Quality	1.9%	0.0%	0.0%	8.6%	0.0%	0.0%	1.5%	1.2%
Cooling System	2.2%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	1.1%
All Other Causes	10.8%	26.3%	13.8%	47.8%	45.8%	26.8%	14.6%	14.9%
Total	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

The PJM EMOF was 3.1 percent in the first three months of 2026. Table 5-42 shows the causes of EMOF by unit type. Maintenance outages for boiler tube leaks, 10.7 percent of the system EMOF, were the largest single contributor to average system EMOF across all unit types, although miscellaneous gas turbine issues were the largest contributors to EMOF for combustion turbines.

Table 5-42 Contribution to EMOF by unit type by cause: January through March, 2026

	Combined		Combustion				Nuclear	Other	System
	Coal	Cycle	Turbine	Diesel	Hydroelectric				
Boiler Tube Leaks	17.5%	13.8%	0.0%	0.0%	0.0%	0.0%	14.3%	10.7%	
Miscellaneous (Reactor)	0.0%	0.0%	0.0%	0.0%	0.0%	69.3%	0.0%	10.2%	
Turbine	0.0%	21.1%	0.0%	0.0%	70.4%	0.0%	0.0%	8.0%	
Boiler Air and Gas Systems	15.0%	0.0%	0.0%	0.0%	0.0%	0.0%	8.1%	7.6%	
Miscellaneous (Gas Turbine)	0.0%	11.5%	36.4%	0.0%	0.0%	0.0%	0.0%	5.5%	
Feedwater System	9.6%	8.0%	0.0%	0.0%	0.0%	0.0%	0.5%	5.3%	
Core/Fuel	0.0%	0.0%	0.0%	0.0%	0.0%	30.1%	0.0%	4.4%	
Cooling System	9.5%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	4.3%	
Boiler Tube Fireside Slagging or Fouling	9.3%	0.0%	0.0%	0.0%	0.0%	0.0%	0.4%	4.3%	
Miscellaneous (Balance of Plant)	3.9%	1.6%	2.8%	0.3%	0.0%	0.0%	22.5%	4.2%	
Slag and Ash Removal	7.6%	0.0%	0.0%	0.0%	0.0%	0.0%	1.4%	3.6%	
Electrical	0.4%	1.0%	13.7%	20.0%	19.0%	0.1%	0.0%	3.5%	
NOx Reduction Systems	6.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0.6%	2.8%	
Auxiliary Systems	0.4%	0.0%	19.6%	0.0%	0.7%	0.0%	0.0%	2.5%	
Boiler Internals and Structures	5.4%	0.0%	0.0%	0.0%	0.0%	0.0%	0.3%	2.5%	
Lube Oil	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	27.3%	2.3%	
Valves	3.8%	1.7%	0.0%	0.0%	0.0%	0.0%	0.5%	2.0%	
Fuel, Ignition and Combustion Systems	0.0%	10.0%	5.8%	0.0%	0.0%	0.0%	0.0%	1.8%	
Boiler Piping System	3.7%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	1.7%	
All Other Causes	7.7%	31.4%	21.7%	79.7%	9.9%	0.5%	24.1%	12.7%	

PJM EPOF was 5.9 percent in the first three months of 2026. Table 5-43 shows the causes of EPOF by unit type. Planned outages for miscellaneous balance of plant, 27.1 percent of the system EPOF, were the largest single contributor to average system EPOF across all unit types, although miscellaneous gas turbine issues were the largest contributors to EPOF for combustion turbines.


Table 5-43 Contribution to EPOF by unit type and cause: January through March, 2026

	Combined		Combustion	Diesel	Hydroelectric	Nuclear	Other	System
	Coal	Cycle	Turbine					
Miscellaneous (Balance of Plant)	33.5%	31.0%	15.7%	0.0%	0.8%	0.0%	79.4%	27.1%
Miscellaneous (Gas Turbine)	0.0%	40.9%	77.5%	0.0%	0.0%	0.0%	0.0%	19.2%
Core/Fuel	0.0%	0.0%	0.0%	0.0%	0.0%	95.4%	0.0%	15.2%
Miscellaneous (Steam Turbine)	22.9%	8.3%	0.0%	0.0%	0.0%	0.0%	0.4%	9.6%
Boiler Overhaul and Inspections	11.2%	7.3%	0.0%	0.0%	0.0%	0.0%	16.5%	6.8%
Miscellaneous	0.0%	0.0%	0.0%	0.0%	92.8%	0.0%	0.0%	6.0%
Feedwater System	10.8%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	3.6%
Stack Emission	8.9%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	3.0%
Wet Scrubbers	8.4%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	2.8%
Turbine	0.0%	9.0%	0.0%	0.0%	5.5%	0.0%	0.0%	2.4%
Miscellaneous (Pollution Control Equipment)	4.2%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	1.4%
Miscellaneous (Generator)	0.0%	3.3%	0.1%	0.0%	0.0%	0.0%	0.1%	0.8%
Miscellaneous (Reactor)	0.0%	0.0%	0.0%	0.0%	0.0%	4.5%	0.0%	0.7%
Miscellaneous (Jet Engine)	0.0%	0.0%	5.4%	0.0%	0.0%	0.0%	0.0%	0.7%
Slag and Ash Removal	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	2.7%	0.2%
Electrical	0.0%	0.0%	0.8%	0.0%	0.9%	0.0%	0.0%	0.2%
Engine	0.0%	0.0%	0.0%	67.5%	0.0%	0.0%	0.0%	0.1%
Fuel, Ignition and Combustion Systems	0.0%	0.0%	0.4%	0.0%	0.0%	0.0%	0.0%	0.1%
Miscellaneous (Boiler)	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.5%	0.0%
All Other Causes	0.1%	0.0%	0.0%	32.5%	0.0%	0.1%	0.4%	0.1%
Total	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%

Performance by Month

Monthly values for EAF, EFOF, EMOF and EPOF are shown in Figure 5-13.

Figure 5–13 Monthly generator performance factors: 2025 through March 2026



Generator Testing Issues

PJM Manual 21: Rules and Procedures for Determination of Generating Capacity describes how generators are to be tested. PJM's testing requirements are not well designed, permit excessive generator discretion, and do not require adequate winter testing. As a result of the introduction of ELCC, winter capability is much more significant in defining the value of capacity that can be sold in the capacity market, especially for thermal resources. That fact makes it even more essential that PJM require winter testing and include the results of that testing in the calculation of ELCC values.

Net Capability Verification Testing data, meant to demonstrate that a unit has the ICAP claimed, are submitted for the summer and winter testing periods.²⁴² These periods run from the start of June until September and the start of

²⁴² PJM. "PJM Manual 18: PJM Capacity Market," § 8.5 Summer/Winter Capability Testing, Rev. 62 (December 17, 2025).

December until March. If a unit is on a planned or maintenance outage for the entire testing period, it is expected to perform an out of period test once the outage ends. Out of period tests can be performed from the start of September until December for summer tests and from the start of March until June for winter tests. Hydroelectric generators only perform summer tests.²⁴³ Wind and solar resources do not perform verification tests to prove capability.²⁴⁴

While data must be submitted for the winter testing period, PJM permits the use of summer test data adjusted for ambient winter conditions in lieu of actual winter test data. The MMU recommends that PJM require actual seasonal tests as part of the Summer/Winter Capability Testing rules and that the ambient conditions under which the tests are performed be defined.

Results, including failed test results, must be submitted to PJM via eGADS. Failing to submit data before the deadline can result in a Data Submission Charge of \$500 per day late.²⁴⁵

Failure to demonstrate the claimed net capability results in a forced outage or derating effective from the beginning of the testing period and lasting until either a reduced claimed ICAP is in effect, the beginning of the next testing period, or, except for failures due to environmental constraints or a lack of resources, a successful out of period test.

Failed test results must be accompanied by a derating or outage in eGADS and in eDART. Failure to report failed tests and failure to derate the unit can result in a Generation Resource Rating Test Failure Charge, equal to the Daily Deficiency Rate multiplied by: the daily ICAP shortfall multiplied by one minus the effective EFORD for unlimited resources; the UCAP for the daily ICAP shortfall, for limited duration resources and combination resources.²⁴⁶ Nine resources were assessed for generation resource rating test failure charges in 2024. No resources were assessed for generation resource rating test failure charges in 2025 or the first three months of 2026.

²⁴³ PJM. "PJM Manual 18: PJM Capacity Market," § 8.5 Summer/Winter Capability Testing, Rev. 62 (December 17, 2025).

²⁴⁴ PJM. "PJM Manual 18: PJM Capacity Market," Appendix B: Calculating Capacity Values for Wind and Solar Capacity Resources, Rev. 62 (December 17, 2025).

²⁴⁵ "Reliability Assurance Agreement Among Load Serving Entities in the PJM Region," Schedule 12, Section A.

²⁴⁶ PJM. "PJM Manual 18: PJM Capacity Market," § 9.1.5 Generation Resource Rating Test Failure Charge, Rev. 62 (December 17, 2025).

The Daily Deficiency Rate in dollars per MW-day is equal to the weighted average capacity resource clearing price from the RPM auction that resulted in the resource's commitment plus the greater of 20 percent of that clearing price or 20 dollars per MW-day.²⁴⁷

While generation owners are required to report failed tests and to derate their unit in eGADS, owners can perform an unlimited number of tests before submitting a successful result. The MMU recommends that PJM limit the number of tests that can be made before submitting final results and that the data be collected by PJM's Power Meter instead of being submitted in eGADS. The MMU recommends that PJM select the time and day for testing a unit, not the unit owner, and that this testing not be communicated in advance. Instead, a unit would be tested by how well it follows its dispatch signal. Under the current testing rules, generation owners have the opportunity to perform tests during more favorable conditions to achieve better performance.

Generator output is also assessed during Performance Assessment Intervals (PAIs), which occur when PJM declares an emergency action as listed in Manual 18, Section 8.4A. If a unit fails to perform as expected, generators may incur a Non-Performance Charge, which is equal to the performance shortfall multiplied by the Non-Performance Charge Rate.²⁴⁸ In 2022, PAIs occurred on June 13, June 14, June 15, December 23, and December 24. For the December 23 and 24 PAIs, PJM total nonperformance charges were approximately \$1.796 billion, reduced to \$1.226 billion in a settlement agreement.²⁴⁹ There were no such charges assessed in 2023, 2024, 2025, or the first three months of 2026.

For each day of a delivery year, generators are required to meet their daily unforced capacity commitments. Generation owners have the option to buy replacement capacity that satisfies the same locational requirements.^{250 251} Failure to meet this commitment can result in a Daily Capacity Resource

Deficiency Charge.^{252 253} This charge is equal to the Daily Deficiency Rate multiplied by the difference between a resource's daily commitments and daily position. Thirty resources were assessed for deficiency charges in 2021, 65 resources were assessed for deficiency charges in 2022, 176 resources were assessed for deficiency charges in 2023, 432 resources were assessed for deficiency charges in 2024, 577 resources were assessed for deficiency charges in 2025, and 321 resources were assessed for deficiency charges in the first three months of 2026. The increase in the number of resources subject to deficiency charges is a result of the implementation of class average ELCC in the 2023/2024 Delivery Year and marginal ELCC starting in the 2025/2026 Delivery Year.

Changing Outage Types

Capacity resource owners have an incentive to minimize their forced outages to maximize capacity revenue and minimize penalties. Generation owners have had the ability to change the designation of the outage type after the initial submission to the eGADS database since 2014. Table 5-44 shows that from 2014 through March 2026, of all the changes in outage status, 96.2 percent of the outages and 86.8 percent of the outage MW were changed from either planned or maintenance to forced outage status. Of those changes to forced outage status, 41.2 percent of the outages and 82.5 percent of the MW were for coal and hydro plants.

247 OATT, Attachment DD (Reliability Pricing Model) § 7.

248 OATT, Attachment DD (Reliability Pricing Model) § 10A.

249 See Settlement Agreement, Docket No. ER23-2975-000 (September 29, 2023), which can be accessed at: <<https://pjm.com/-/media/documents/ferc/filings/2023/20230929-er23-2975-000.ashx>>.

250 "PJM Manual 21: Rules and Procedures for Determination of Generating Capability," § 1.3.6 Impacts of Test Results, Rev. 19 (June 27, 2024).

251 OATT, Attachment DD (Reliability Pricing Model) § 7 (a).

252 PJM. "PJM Manual 18: PJM Capacity Market," § 8.2 RPM Commitment Compliance, Rev. 62 (December 17, 2025).

253 OATT, Attachment DD (Reliability Pricing Model) § 8.

Table 5-44 Changed outages by unit type: 2014 through March 2026²⁵⁴

Unit Type	Year	Forced to Maintenance		Forced to Planned		Maintenance or Planned to Forced	
		No. Outages	MWh	No. Outages	MWh	No. Outages	MWh
Coal	2014	5	270,049	0	NA	1	2,794
	2015	0	NA	0	NA	25	876,920
	2016	1	271,304	0	NA	74	1,983,852
	2017	2	151,085	0	NA	48	1,246,484
	2018	1	1,520	0	NA	30	837,286
	2019	2	71,234	0	NA	43	618,382
	2020	1	8,587	0	NA	12	170,807
	2021	0	NA	0	NA	0	NA
	2022	0	NA	0	NA	0	NA
	2023	1	13,211	0	NA	0	NA
	2024	1	18,908	0	NA	0	NA
	2025	0	NA	0	NA	0	NA
	2026 (Jan-Mar)	0	NA	0	NA	0	NA
Total		14	805,898	0	NA	233	5,736,526
Combined Cycle	2014	1	3,803	2	1,105	1	28,067
	2015	2	24,685	0	NA	3	3,330
	2016	0	NA	1	65,664	24	145,432
	2017	3	5,786	0	NA	19	400,606
	2018	1	416	0	NA	16	52,214
	2019	0	NA	0	NA	11	94,756
	2020	0	NA	0	NA	13	19,037
	2021	0	NA	7	303,061	0	NA
	2022	0	NA	1	3,817	2	208
	2023	0	NA	0	NA	0	NA
	2024	3	2,625	0	NA	0	NA
	2025	0	NA	0	NA	2	191,610
	2026 (Jan-Mar)	0	NA	0	NA	0	NA
Total		10	37,315	11	373,648	91	935,260
Combustion Turbine	2014	9	26,990	3	15,027	22	25,865
	2015	0	NA	0	NA	13	27,567
	2016	0	NA	0	NA	48	55,233
	2017	0	NA	0	NA	19	29,586
	2018	0	NA	2	41,737	25	24,433
	2019	0	NA	1	340	28	37,483
	2020	0	NA	0	NA	27	41,312
	2021	0	NA	0	NA	5	25,094
	2022	0	NA	0	NA	5	25,497
	2023	0	NA	0	NA	4	270,336
	2024	1	11,786	0	NA	6	191,667
	2025	0	NA	0	NA	3	3,222
	2026 (Jan-Mar)	0	NA	0	NA	0	NA
Total		10	38,777	6	57,104	205	757,294
Diesel	2014	0	NA	0	NA	77	4,550
	2015	15	47	0	NA	182	5,439
	2016	0	NA	0	NA	217	5,579
	2017	2	145	0	NA	175	5,883
	2018	2	15	0	NA	235	4,414
	2019	0	NA	0	NA	238	23,066
	2020	2	311	0	NA	163	6,113
	2021	3	137	0	NA	3	27,059
	2022	4	5,492	0	NA	10	305
	2023	0	NA	0	NA	0	NA
	2024	0	NA	0	NA	0	NA
	2025	0	NA	0	NA	0	NA
	2026 (Jan-Mar)	0	NA	0	NA	0	NA
Total		28	6,147	0	NA	1,300	82,408

Continued

254 Year describes the year in which the outage started and not the year in which the outage designation was changed.

Unit Type	Year	Forced to Maintenance		Forced to Planned		Maintenance or Planned to Forced	
		No. Outages	MWh	No. Outages	MWh	No. Outages	MWh
Hydroelectric	2014	1	3	0	NA	124	1,383,319
	2015	1	162	0	NA	152	952,608
	2016	4	780	0	NA	315	1,433,851
	2017	2	52,080	0	NA	123	598,766
	2018	4	82,395	0	NA	72	405,549
	2019	0	NA	0	NA	34	148,629
	2020	0	NA	0	NA	59	281,976
	2021	0	NA	0	NA	33	263,525
	2022	0	NA	0	NA	1	4,887
	2023	0	NA	0	NA	9	196,512
	2024	0	NA	0	NA	0	NA
	2025	0	NA	0	NA	0	NA
	2026 (Jan-Mar)	0	NA	0	NA	0	NA
Total	12	135,420	0	NA	922	5,669,622	
Nuclear	2014	0	NA	1	177,618	0	NA
	2015	0	NA	1	573	0	NA
	2016	0	NA	0	NA	0	NA
	2017	0	NA	0	NA	0	NA
	2018	0	NA	0	NA	0	NA
	2019	0	NA	0	NA	0	NA
	2020	0	NA	0	NA	2	22,903
	2021	0	NA	0	NA	0	NA
	2022	0	NA	0	NA	0	NA
	2023	0	NA	0	NA	0	NA
	2024	0	NA	2	168,615	0	NA
	2025	0	NA	0	NA	0	NA
	2026 (Jan-Mar)	0	NA	0	NA	0	NA
Total	0	NA	4	346,807	2	22,903	
Other	2014	5	103,981	0	NA	1	866
	2015	0	NA	0	NA	2	176,599
	2016	1	11,680	0	NA	18	159,781
	2017	2	231	1	28,636	12	85,071
	2018	3	7,555	0	NA	1	268
	2019	1	128,664	1	8,658	9	61,297
	2020	0	NA	0	NA	4	82,250
	2021	0	NA	0	NA	0	NA
	2022	0	NA	0	NA	0	NA
	2023	2	17,023	0	NA	0	NA
	2024	0	NA	0	NA	0	NA
	2025	0	NA	0	NA	0	NA
	2026 (Jan-Mar)	0	NA	0	NA	4	53,730
Total	14	269,134	2	37,294	51	619,863	
All Units	2014	21	404,826	6	193,750	226	1,445,461
	2015	18	24,894	1	573	377	2,042,463
	2016	6	283,764	1	65,664	696	3,783,728
	2017	11	209,328	1	28,636	396	2,366,397
	2018	11	91,901	2	41,737	379	1,324,165
	2019	3	199,897	2	8,998	363	983,612
	2020	3	8,898	0	NA	280	624,398
	2021	3	137	7	303,061	41	315,679
	2022	4	5,492	1	3,817	18	30,896
	2023	3	30,234	0	NA	13	466,848
	2024	5	33,319	2	168,615	6	191,667
	2025	0	NA	0	NA	5	194,832
	2026 (Jan-Mar)	0	NA	0	NA	4	53,730
Total	88	1,292,689	23	814,853	2,804	13,823,876	